

SCHERGER RAAF, Australia

WMO: 941710

Lat: 12.617S

Lon: 142.087E

Elev: 40

StdP: 100.84

Time Zone: 10.00 (E10)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.8	17.8	10.4	7.9	29.7	12.0	8.8	28.6	9.1	28.8	8.3	28.5	1.0	170	0.342

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	11.8	36.1	23.0	35.2	23.1	34.5	23.2	27.0	30.8	26.6	30.4	26.3	30.0	4.2	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.1	21.6	28.7	25.7	21.1	28.4	25.2	20.5	27.9	85.2	30.8	83.6	30.8	82.4	30.3	36.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.1	7.2	6.4	DB	14.4	38.0	1.1	0.6	13.6	38.4	13.0	38.7	12.3	39.1	11.5	39.5	(4)
(5)			WB	13.0	28.8	1.5	2.7	11.9	30.7	11.0	32.3	10.2	33.8	9.1	35.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.1	27.9	27.7	27.6	27.2	26.2	25.1	24.6	25.3	26.8	28.4	29.4	29.1	(6)	
	DBStd	1.91	1.34	1.15	1.04	0.92	1.16	1.31	1.37	1.36	1.30	1.17	0.94	1.21	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD10.0	6244	554	496	546	515	503	452	454	474	506	571	582	592	(10)	
	CDD18.3	3202	296	262	287	265	244	202	196	216	256	313	332	333	(11)	
	CDH23.3	31330	2864	2492	2604	2531	2154	1568	1548	1970	2644	3483	3817	3654	(12)	
	CDH26.7	12755	1013	839	863	936	762	480	482	772	1254	1751	1932	1669	(13)	
(14) Wind	WSAvg	2.8	2.2	2.2	2.1	2.7	3.2	3.3	3.3	3.1	3.2	3.2	2.7	2.3	(14)	
(15) Precipitation	PrecAvg	1596	421	405	317	102	22	11	7	5	2	21	80	238	(15)	
	PrecMax	2107	682	655	617	321	144	49	28	22	11	103	263	669	(16)	
	PrecMin	1187	257	118	122	8	0	1	0	0	0	0	5	51	(17)	
	PrecStd	260	98	119	127	84	31	11	6	6	3	27	79	135	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.2	34.0	33.7	33.5	33.0	32.0	32.0	33.5	35.6	36.9	37.2	37.0	(19)	
		MCWB	24.7	25.5	25.8	24.9	24.6	23.0	21.9	21.7	21.5	22.7	23.4	23.0	(20)	
	2%	DB	33.7	33.0	32.8	32.6	32.0	31.1	31.1	32.3	34.3	35.8	36.2	35.7	(21)	
		MCWB	25.3	25.6	25.7	24.6	24.0	22.7	21.4	21.2	21.4	22.4	23.2	23.7	(22)	
	5%	DB	32.5	32.1	31.9	31.9	31.2	30.3	30.2	31.6	33.5	34.9	35.2	34.5	(23)	
		MCWB	25.6	25.8	25.6	24.4	23.6	22.4	21.4	21.0	21.4	22.6	23.2	24.2	(24)	
	10%	DB	31.3	31.1	31.0	31.1	30.5	29.5	29.4	30.7	32.6	33.9	34.4	33.3	(25)	
		MCWB	25.9	25.9	25.8	24.3	23.3	22.1	21.2	21.0	21.5	22.5	23.4	24.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.2	27.2	27.3	26.9	26.0	24.9	24.2	24.3	25.0	25.6	26.7	27.1	(27)	
		MCDB	30.9	30.7	30.9	30.9	30.1	29.7	29.1	29.9	31.3	31.7	31.3	31.4	(28)	
	2%	WB	26.7	26.7	26.7	26.1	25.1	24.1	23.6	23.5	24.1	24.8	26.1	26.6	(29)	
		MCDB	30.3	30.2	30.4	29.7	29.9	28.7	28.4	29.1	30.0	31.2	31.0	30.8	(30)	
	5%	WB	26.5	26.3	26.3	25.7	24.5	23.5	22.8	22.9	23.6	24.4	25.7	26.2	(31)	
		MCDB	30.0	29.8	29.8	29.2	29.4	28.2	27.7	28.5	29.5	30.6	30.7	30.4	(32)	
	10%	WB	26.1	26.1	26.0	25.2	24.0	23.0	22.2	22.3	22.9	23.9	25.2	25.9	(33)	
		MCDB	29.6	29.5	29.4	28.9	28.9	27.7	27.2	28.0	29.2	30.1	30.4	30.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.1	6.9	7.4	8.8	9.5	9.9	10.7	12.1	13.1	12.8	11.8	9.7	(35)	
		MCDBR	9.4	8.7	8.8	9.9	10.4	10.8	11.7	13.1	14.1	13.8	12.7	11.5	(36)	
	5% WB	MCWBR	3.1	3.0	3.2	3.5	3.8	4.1	4.1	4.2	4.1	3.7	3.4	3.3	(37)	
		MCWBR	7.4	7.2	7.7	7.9	9.0	8.9	9.1	10.3	11.9	12.1	10.8	9.2	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.408	0.404	0.391	0.389	0.379	0.371	0.361	0.373	0.393	0.405	0.412	0.408	(40)	
		taud	2.515	2.527	2.565	2.547	2.549	2.561	2.578	2.524	2.452	2.424	2.431	2.481	(41)	
	Ebn at Noon	Ebn at Noon	936	933	927	897	874	865	884	899	911	920	925	933	(42)	
		Edh at Noon	114	112	105	101	96	92	92	102	115	122	123	117	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	5.04	5.09	5.08	5.26	4.84	4.41	4.66	5.45	6.32	6.82	6.74	6.01	(44)	
	RadStd	RadStd	0.60	0.79	0.39	0.46	0.29	0.32	0.27	0.36	0.29	0.37	0.42	0.66	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		N/A	N/A	N/A	+0.38	N/A	N/A	N/A	N/A	+112	+109

Nomenclature: See separate page