

HORN ISLAND, Australia

WMO: 941740

Lat: 10.5844S

Lon: 142.2900E

Elev: 5

StdP: 101.26

Time Zone: 10.00 (E10)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	21.8	22.5	16.4	11.7	24.9	17.3	12.3	24.9	11.3	27.7	10.8	27.8	2.7	150	0.527

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	5.0	32.1	26.0	31.8	25.9	31.2	25.9	27.7	29.7	27.2	29.7	26.8	29.5	6.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.2	23.0	28.5	26.6	22.2	28.4	26.1	21.5	28.3	88.6	29.8	86.1	29.8	84.5	29.7	31.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
(4) 10.4	9.9	9.3	19.0	33.3	1.6	0.6	17.9	33.7	16.9	34.1	16.0	34.4	14.8	34.8		
(5)			17.6	28.6	1.3	1.2	16.6	29.5	15.8	30.2	15.1	30.9	14.1	31.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.3	27.9	27.7	27.7	27.8	27.3	26.4	25.8	26.6	27.5	28.5	28.8	(6)	
(7)		DBStd	1.35	1.09	1.03	0.99	0.91	0.89	0.88	0.91	1.04	1.00	1.04	0.90	1.08	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6317	554	496	548	533	536	492	490	489	498	544	554	582	(10)
(11)		CDD18.3	3276	296	263	289	283	278	242	232	231	248	286	304	323	(11)
(12)		CDH23.3	32814	3360	2929	3132	3061	2707	1967	1609	1602	2089	2888	3521	3949	(12)
(13)		CDH26.7	9120	1092	886	904	861	614	311	206	225	416	789	1244	1574	(13)
(14)	Wind	WSAvg	5.4	3.9	3.5	3.3	4.8	6.1	6.3	6.6	6.6	7.0	6.7	5.8	4.2	(14)
(15)	Precipitation	PrecAvg	1755	429	382	368	209	39	21	9	5	4	7	32	244	(15)
(16)		PrecMax	2614	863	707	649	717	145	122	32	15	14	37	185	795	(16)
(17)		PrecMin	912	169	127	90	16	3	0	1	0	0	0	0	4	(17)
(18)		PrecStd	386	175	149	146	167	38	26	7	4	4	9	45	201	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.2	32.0	32.1	31.4	30.9	30.1	29.5	30.0	30.8	31.8	32.6	33.1	(19)
(20)			MCWB	26.3	26.7	26.7	26.2	25.9	24.6	24.3	24.4	25.1	25.3	26.4	26.1	(20)
(21)		2%	DB	31.5	31.2	31.2	31.0	30.2	29.3	28.9	29.1	30.0	31.0	31.9	32.2	(21)
(22)			MCWB	26.2	26.4	26.5	26.3	25.4	24.3	23.6	23.5	24.3	25.2	25.7	25.9	(22)
(23)		5%	DB	31.0	30.8	30.7	30.4	29.9	28.9	28.3	28.4	29.2	30.4	31.2	31.9	(23)
(24)			MCWB	26.2	26.3	26.3	25.9	25.2	24.1	23.1	22.9	23.5	24.7	25.4	25.8	(24)
(25)		10%	DB	30.3	30.1	30.0	30.0	29.2	28.3	27.9	28.0	28.8	29.9	30.8	31.2	(25)
(26)			MCWB	26.0	26.1	26.0	25.6	24.7	23.7	22.9	22.5	23.2	24.4	25.3	25.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.7	28.4	28.5	28.1	28.5	26.2	25.7	25.4	25.7	26.6	27.9	27.2	(27)
(28)			MCDWB	30.1	29.5	30.3	29.6	28.7	28.0	27.4	28.1	29.3	29.4	30.2	30.8	(28)
(29)		2%	WB	27.1	27.5	27.2	27.1	26.4	25.3	24.7	24.6	25.1	26.1	27.0	26.7	(29)
(30)			MCDWB	29.8	29.4	29.7	29.4	28.7	27.9	27.1	27.5	28.3	29.2	30.1	30.3	(30)
(31)		5%	WB	26.7	27.0	26.7	26.7	25.8	24.8	24.3	24.0	24.6	25.6	26.4	26.5	(31)
(32)			MCDWB	29.4	29.4	29.2	29.0	28.5	27.6	26.9	27.0	27.9	28.9	29.6	30.0	(32)
(33)		10%	WB	26.4	26.5	26.4	26.2	25.4	24.4	23.8	23.5	24.0	25.2	26.0	26.2	(33)
(34)			MCDWB	29.1	28.9	28.8	28.5	28.2	27.2	26.6	26.7	27.6	28.6	29.3	29.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.6	4.4	4.5	4.3	4.4	4.5	4.7	5.0	5.0	5.0	5.0	5.0	(35)
(36)			MCDBR	5.3	5.2	5.3	4.8	4.6	4.7	4.8	5.1	5.1	5.3	5.3	5.5	(36)
(37)			MCWBR	2.2	2.3	2.3	2.2	2.1	1.9	1.9	2.0	1.9	2.0	2.0	2.1	(37)
(38)		5% WB	MCDBR	4.8	4.7	4.8	4.5	4.3	4.4	4.3	4.8	4.9	5.1	5.0	5.2	(38)
(39)			MCWBR	2.4	2.5	2.4	2.4	2.2	1.9	1.9	2.1	1.9	2.0	2.0	2.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.408	0.406	0.397	0.403	0.410	0.404	0.396	0.400	0.411	0.415	0.417	0.410	(40)	
(41)		taud	2.559	2.564	2.594	2.564	2.520	2.531	2.545	2.522	2.480	2.464	2.475	2.524	(41)	
(42)		Ebn at Noon	934	931	923	887	850	840	856	878	896	912	919	930	(42)	
(43)		Edh at Noon	108	108	102	101	100	96	96	103	113	117	117	112	(43)	
(44)	All-Sky Solar Radiation	RadAvg	4.92	5.09	4.76	4.84	4.80	4.45	4.71	5.44	6.03	6.53	6.47	5.86	(44)	
(45)		RadStd	0.56	0.62	0.32	0.55	0.35	0.28	0.27	0.41	0.38	0.32	0.49	0.73	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page