

FITZROY CROSSING, Australia

WMO: 942060

Lat: 18.1814S

Lon: 125.5619E

Elev: 377

StdP: 14.50

Time Zone: 8.00 (E08)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	48.3	51.2	13.3	11.0	82.6	17.5	13.4	81.4	18.2	75.1	16.6	76.3	2.9	110	0.445

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	25.6	108.4	69.0	106.6	69.6	104.8	70.2	80.7	91.1	79.7	90.1	78.9	89.4	8.8	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.6	150.4	83.8	77.4	144.7	83.0	76.5	140.3	82.7	44.8	91.0	43.6	90.0	42.8	89.4	89.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.6	16.4	14.5	43.0	111.9	2.7	1.6	41.0	113.0	39.4	114.0	37.9	114.9	35.9	116.1		
(5)			36.1	82.4	2.1	2.5	34.6	84.2	33.3	85.7	32.1	87.1	30.6	88.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.5	88.1	87.1	86.5	83.7	76.4	71.1	70.9	73.8	82.1	88.8	91.3	90.0
	DBStd	8.42	4.02	3.69	3.33	4.14	5.21	5.24	4.82	4.80	4.64	3.85	3.45	4.32
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	20	0	0	0	0	1	10	8	1	0	0	0	0
	CDD50	11843	1180	1040	1131	1012	819	632	647	737	964	1203	1238	1240
	CDD65	6389	715	620	666	562	356	192	190	273	514	738	788	775
	CDH74	90056	9777	8123	8721	7524	4396	2393	2686	4019	7416	11240	12374	11387
	CDH80	53787	5703	4579	4956	4518	2305	983	1166	2088	4573	7411	8294	7211
Wind	WSAvg	7.2	7.8	7.3	6.4	5.9	6.6	6.9	6.5	6.9	7.5	7.7	8.4	8.4
Precipitation	PrecAvg	21.9	6.3	5.8	3.7	0.9	0.5	0.3	0.1	0.0	0.0	0.3	1.1	3.1
	PrecMax	33.7	18.1	16.0	15.3	6.9	3.1	3.2	2.3	0.7	0.2	2.9	10.1	9.9
	PrecMin	7.4	0.4	0.6	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	7.8	4.6	4.2	3.8	1.5	0.8	0.7	0.4	0.2	0.0	0.5	1.7	2.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	108.3	106.9	105.4	103.9	99.2	93.7	93.6	98.3	104.2	108.8	110.5	111.3
		MCWB	70.6	72.3	71.2	68.2	67.5	66.7	63.7	65.1	65.6	66.8	67.3	70.0
	2%	DB	105.0	104.2	102.9	101.7	96.6	91.0	91.5	95.5	101.9	106.8	108.3	108.1
		MCWB	73.2	74.9	72.2	68.5	65.0	65.0	62.7	63.3	65.6	67.1	68.1	71.5
	5%	DB	102.3	101.4	100.7	99.7	94.3	88.8	89.4	93.1	100.0	105.0	106.3	105.1
		MCWB	74.9	75.8	72.9	69.0	65.0	63.5	61.9	62.2	64.6	67.1	69.3	71.9
	10%	DB	99.2	97.9	98.0	97.6	91.7	86.1	87.0	90.7	98.1	103.0	104.2	102.0
		MCWB	75.9	76.3	74.2	69.0	64.5	61.8	61.1	60.9	64.1	67.2	70.1	73.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.1	83.2	82.7	79.2	76.2	72.1	70.8	70.7	72.3	76.5	79.1	79.7
		MCDB	92.6	93.1	91.4	88.6	83.0	84.1	84.6	88.0	92.3	89.8	93.6	91.1
	2%	WB	79.9	80.6	80.7	77.0	73.3	69.3	67.6	67.5	70.0	74.6	76.9	78.6
		MCDB	90.6	90.9	90.3	87.8	83.2	82.3	84.5	86.2	91.9	88.9	89.6	90.6
	5%	WB	79.1	79.5	79.4	75.6	70.6	67.2	65.1	65.3	68.5	73.4	75.7	77.8
		MCDB	89.5	89.9	89.5	87.7	84.2	82.2	83.1	86.8	91.0	90.0	89.9	89.6
	10%	WB	78.4	78.7	78.3	74.3	68.5	64.7	63.0	63.2	66.8	72.2	74.6	77.1
		MCDB	88.8	89.1	88.3	87.1	84.8	82.2	82.5	85.8	90.1	90.4	90.2	88.9
Mean Daily Temperature Range	5% DB	MDBR	20.3	20.3	21.7	27.5	29.0	29.7	31.9	33.8	31.9	28.4	25.6	22.4
		MCDBR	25.3	25.8	26.9	29.4	31.5	30.6	33.6	34.8	32.5	30.6	28.2	26.9
		MCWBR	6.8	7.7	7.6	9.0	10.9	12.2	13.3	13.3	11.2	9.8	8.3	6.9
	5% WB	MCDBR	19.7	20.2	20.5	22.2	23.1	24.9	27.8	29.7	28.5	25.5	24.3	21.2
		MCWBR	6.1	7.1	7.7	7.5	8.6	10.5	11.8	11.8	10.8	8.3	7.7	5.7
Clear-Sky Solar Irradiance	taub	0.406	0.400	0.390	0.372	0.360	0.340	0.344	0.357	0.409	0.418	0.422	0.411	
	taud	2.459	2.480	2.495	2.474	2.441	2.471	2.435	2.360	2.262	2.280	2.327	2.422	
	Ebn at Noon	298	297	292	286	277	278	279	286	282	288	291	296	
	Edh at Noon	38	37	35	34	32	30	32	37	44	45	43	40	
All-Sky Solar Radiation	RadAvg	2138	2127	1984	1896	1638	1538	1630	1920	2200	2353	2371	2228	
	RadStd	145	181	206	77	113	83	96	58	60	95	97	133	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	+2.57	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page