

ROWLEY SHOALS, Australia

WMO: 942070

Lat: 17.520S

Lon: 118.945E

Elev: 8

StdP: 101.23

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	21.9	22.6	N/A	N/A	N/A	N/A	N/A	N/A	14.2	22.9	13.4	23.6	8.8	110	0.530

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	1.6	31.1	N/A	30.7	N/A	30.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	4.4	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.4	12.0	10.8	20.7	32.0	0.9	0.9	20.1	32.7	19.5	33.2	19.0	33.7	18.4	34.3		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.1	28.6	28.7	29.2	29.0	27.4	25.6	24.8	24.4	25.0	26.4	27.4	28.3
	DBStd	1.96	0.93	0.93	0.92	0.80	1.16	1.20	1.01	0.90	0.88	1.18	1.00	1.06
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6231	576	524	594	571	541	467	459	448	451	510	523	568
	CDD18.3	3189	317	291	336	321	282	217	201	189	201	252	273	310
	CDH23.3	32930	3941	3666	4338	4110	3077	1640	1124	880	1212	2283	2922	3738
	CDH26.7	9546	1474	1436	1866	1715	737	87	10	1	12	282	639	1287
Wind	WSAvg	5.6	6.3	5.8	5.1	4.5	5.9	6.6	6.2	5.7	5.2	5.2	5.4	5.6
Precipitation	PrecAvg	456	87	118	78	36	37	26	13	6	3	3	2	47
	PrecMax	883	372	329	350	172	147	145	60	44	25	10	8	201
	PrecMin	155	1	2	4	1	0	2	1	0	0	0	0	0
	PrecStd	181	88	92	89	42	42	34	16	10	5	2	2	54
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.0	31.2	31.5	31.4	30.5	28.5	27.6	26.7	27.6	29.4	30.5	31.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	30.5	30.6	31.0	30.9	29.8	27.9	26.9	26.3	27.1	28.8	29.8	30.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	30.1	30.2	30.7	30.5	29.4	27.5	26.5	26.1	26.7	28.4	29.2	30.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	29.8	29.9	30.4	30.2	29.0	27.2	26.2	25.7	26.3	28.0	28.8	29.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	1.5	1.6	1.6	1.6	1.6	1.5	1.5	1.6	1.5	1.6	1.5	1.4
		MCDBR	1.7	1.8	1.8	1.8	1.7	1.7	1.6	1.7	1.8	2.0	2.0	1.8
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.415	0.404	0.383	0.359	0.359	0.342	0.329	0.326	0.359	0.385	0.388	0.392	
	taud	2.513	2.556	2.614	2.646	2.598	2.642	2.652	2.609	2.525	2.473	2.505	2.562	
	Ebn at Noon	931	931	929	916	881	881	903	936	937	938	949	952	
	Edh at Noon	114	108	99	90	88	81	82	91	106	116	114	109	
All-Sky Solar Radiation	RadAvg	6.85	6.67	6.36	5.93	5.04	4.67	5.05	6.04	6.86	7.53	7.84	7.51	
	RadStd	0.68	0.75	0.64	0.35	0.36	0.39	0.29	0.12	0.17	0.12	0.16	0.36	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page