

ADELE ISLAND, Australia

WMO: 942100

Lat: 15.511S

Lon: 123.156E

Elev: 18

StdP: 14.69

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	61.4	63.5	N/A	N/A	N/A	N/A	N/A	N/A	22.7	74.0	21.0	75.1	4.3	170	0.426

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	9.0	92.5	N/A	91.7	N/A	90.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	9.4	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.1	21.0	18.6	DB	60.4	93.5	6.0	2.3	56.1	95.2	52.6	96.6	49.2	97.9	44.9	99.6	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.2	84.3	83.9	84.0	83.6	80.1	76.3	75.0	75.9	79.1	82.2	84.7	85.3
	DBStd	4.32	2.23	2.07	1.89	2.13	3.00	3.40	3.08	2.54	1.94	1.79	1.50	1.91
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11382	1064	948	1054	1008	934	789	776	802	872	999	1042	1094
	CDD65	5907	599	528	589	558	469	339	311	337	422	534	592	629
	CDH74	66338	7580	6526	7367	6887	4953	2822	2388	2606	3751	5877	7412	8169
	CDH80	25118	3219	2595	3065	3035	1773	642	394	515	944	1964	3208	3764
Wind	WSAvg	9.0	12.2	11.1	9.3	6.9	7.4	8.1	7.9	7.6	8.4	9.0	9.5	11.0
Precipitation	PrecAvg	42.4	11.7	11.1	7.2	2.0	1.1	0.5	0.2	0.0	0.0	0.5	1.1	6.9
	PrecMax	67.1	29.1	20.8	20.3	8.4	8.0	4.3	2.7	0.6	0.4	2.6	3.4	13.8
	PrecMin	17.4	4.4	3.4	1.7	0.1	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.6
	PrecStd	11.1	5.7	5.0	5.0	2.0	2.3	0.9	0.5	0.1	0.1	0.5	0.8	3.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.0	92.0	92.4	92.7	91.5	87.6	86.4	86.4	89.0	91.5	93.3	93.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	91.7	90.8	91.0	91.6	89.8	86.4	84.8	85.3	87.3	89.9	91.8	92.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	90.6	89.8	90.1	90.6	88.5	85.2	83.5	84.3	86.3	88.7	90.9	91.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	89.4	88.5	88.9	89.5	87.0	83.7	82.3	83.1	85.0	87.4	89.8	90.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	8.5	8.0	9.0	11.6	13.4	14.2	14.6	14.6	12.0	10.2	10.1	9.0
		MCDBR	10.8	10.2	11.4	13.7	16.0	16.2	17.0	17.5	14.5	12.4	11.7	11.3
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.422	0.409	0.392	0.375	0.368	0.344	0.333	0.344	0.393	0.425	0.418	0.412
	taud		2.509	2.555	2.604	2.608	2.584	2.628	2.638	2.577	2.461	2.395	2.451	2.523
	Ebn at Noon		293	294	293	287	278	280	287	292	288	286	292	296
	Edh at Noon		36	34	32	30	29	27	27	30	36	40	38	36
All-Sky Solar Radiation	RadAvg		1891	1969	1921	1908	1651	1581	1670	1916	2155	2297	2374	2154
	RadStd		242	229	235	77	108	86	74	36	36	53	71	163

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page