

ADELE ISLAND, Australia

WMO: 942100

Lat: 15.511S

Lon: 123.156E

Elev: 6

StdP: 101.26

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.3	17.5	N/A	N/A	N/A	N/A	N/A	N/A	10.2	23.3	9.4	23.9	1.9	170	0.426

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	5.0	33.6	N/A	33.2	N/A	32.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	4.2	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.2	9.4	8.3	DB	15.8	34.2	3.3	1.3	13.4	35.1	11.4	35.9	9.6	36.6	7.2	37.6	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.3	29.1	28.8	28.9	28.7	26.7	24.6	23.9	24.4	26.2	27.9	29.3	29.6
	DBStd	2.40	1.24	1.15	1.05	1.18	1.66	1.89	1.71	1.41	1.08	1.00	0.83	1.06
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6323	591	527	586	560	519	438	431	446	484	555	579	608
	CDD18.3	3282	333	293	327	310	261	188	173	187	234	297	329	349
	CDH23.3	36854	4211	3626	4093	3826	2752	1568	1327	1448	2084	3265	4118	4538
	CDH26.7	13954	1788	1442	1703	1686	985	357	219	286	524	1091	1782	2091
Wind	WSAvg	4.0	5.5	5.0	4.1	3.1	3.3	3.6	3.5	3.4	3.8	4.0	4.2	4.9
Precipitation	PrecAvg	1076	296	282	183	52	29	12	6	1	1	12	29	174
	PrecMax	1705	739	529	516	213	204	109	69	15	10	67	87	350
	PrecMin	441	113	87	44	3	0	0	0	0	0	1	3	15
	PrecStd	282	145	128	128	50	58	23	13	3	2	13	20	93
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.9	33.4	33.6	33.7	33.0	30.9	30.2	30.2	31.6	33.0	34.0	34.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	33.2	32.7	32.8	33.1	32.1	30.2	29.4	29.6	30.7	32.1	33.2	33.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	32.6	32.1	32.3	32.5	31.4	29.5	28.6	29.0	30.2	31.5	32.7	33.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	10%	DB	31.9	31.4	31.6	31.9	30.6	28.7	28.0	28.4	29.5	30.8	32.1	32.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	4.7	4.4	5.0	6.4	7.4	7.9	8.1	8.1	6.7	5.7	5.6	5.0
		MCDBR	6.0	5.7	6.3	7.6	8.9	9.0	9.5	9.7	8.1	6.9	6.5	6.3
	5% WB	MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Clear-Sky Solar Irradiance	taub	0.422	0.409	0.392	0.375	0.368	0.344	0.333	0.344	0.393	0.425	0.418	0.412
		taud	2.509	2.555	2.604	2.608	2.584	2.628	2.638	2.577	2.461	2.395	2.451	2.523
Ebn at Noon		924	928	924	905	877	884	905	922	908	902	921	932	
Edh at Noon		114	108	100	94	91	84	85	95	114	126	120	113	
All-Sky Solar Radiation	RadAvg	5.96	6.21	6.05	6.01	5.21	4.98	5.27	6.04	6.79	7.24	7.48	6.79	
	RadStd	0.76	0.72	0.74	0.24	0.34	0.27	0.23	0.12	0.11	0.17	0.22	0.51	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page