

HALLS CREEK, Australia

WMO: 942120

Lat: 18.2291S

Lon: 127.6640E

Elev: 1391

StdP: 13.97

Time Zone: 8.00 (E08)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	49.9	52.4	6.5	8.1	82.0	11.6	10.5	76.0	20.2	62.9	18.6	65.3	3.5	100	0.385

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	22.4	104.0	66.6	102.3	66.9	100.7	67.2	77.0	86.2	76.3	85.5	75.6	84.8	8.5	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.2	139.3	78.9	74.4	135.5	78.7	73.7	132.0	78.5	41.6	86.2	40.9	85.2	40.3	84.5	96.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.0	15.9	14.1	45.0	107.4	3.1	2.4	42.8	109.1	40.9	110.6	39.2	111.9	37.0	113.7		
(5)			36.0	81.8	2.3	5.2	34.4	85.5	33.1	88.6	31.8	91.5	30.2	95.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	79.8	85.8	84.6	83.9	80.8	73.6	68.2	68.3	71.8	80.5	85.9	87.6	87.0
	DBStd	8.35	4.17	3.94	3.42	4.23	4.91	5.18	4.66	4.96	4.95	4.22	3.95	4.44
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	54	0	0	0	0	3	24	21	6	0	0	0	0
	CDD50	10877	1109	969	1051	924	732	547	567	676	914	1112	1128	1148
	CDD65	5455	644	549	586	474	270	121	123	216	464	647	678	683
	CDH74	69756	8174	6635	7201	5712	2637	1136	1295	2509	6019	9285	9818	9335
	CDH80	38019	4511	3509	3827	2996	1040	306	348	975	3313	5678	6022	5494
Wind	WSAvg	6.1	6.4	6.2	5.8	5.7	6.2	6.6	6.0	5.9	6.0	6.0	6.2	6.4
Precipitation	PrecAvg	23.3	6.4	5.7	3.8	0.7	0.5	0.1	0.2	0.0	0.2	0.7	1.6	3.5
	PrecMax	46.8	17.4	21.0	15.0	7.4	4.1	1.8	2.8	0.3	3.3	4.1	6.9	8.2
	PrecMin	8.0	0.5	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2
	PrecStd	9.3	4.0	4.8	4.1	1.5	0.9	0.2	0.6	0.1	0.5	1.0	1.5	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	104.3	103.3	101.3	99.0	93.3	89.6	88.8	93.7	99.9	104.4	105.4	107.6
		MCWB	69.3	68.0	68.9	66.0	64.9	64.2	61.3	62.1	62.9	64.9	65.0	66.4
	2%	DB	101.5	100.8	98.8	97.1	90.8	86.4	86.2	90.8	97.6	102.4	103.5	104.2
		MCWB	69.8	69.4	68.5	65.6	62.8	62.9	60.3	60.9	63.0	64.4	65.4	68.1
	5%	DB	99.3	98.4	96.8	95.1	88.7	83.7	84.0	88.3	95.8	100.6	101.7	101.3
		MCWB	70.4	70.2	68.7	65.4	62.3	60.5	58.8	59.7	62.5	64.2	66.2	68.9
	10%	DB	96.8	95.2	94.7	92.8	86.2	80.8	81.5	85.7	93.9	98.8	99.6	98.4
		MCWB	71.5	71.4	69.4	65.4	61.5	58.9	57.8	58.0	61.8	63.9	66.7	69.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.0	77.4	77.3	74.4	73.1	69.3	68.6	68.4	70.7	72.9	77.8	77.1
		MCDB	87.9	86.8	86.7	83.1	79.6	79.1	78.0	80.5	82.2	85.0	84.8	86.5
	2%	WB	76.9	76.6	76.2	72.9	70.3	66.0	64.7	65.0	68.0	71.7	74.0	75.8
		MCDB	86.6	85.4	84.7	82.8	79.7	81.7	80.6	82.8	88.7	84.8	86.7	85.7
	5%	WB	76.2	76.0	75.4	71.8	67.9	63.6	62.0	62.6	66.3	70.5	72.8	75.1
		MCDB	85.8	84.8	83.8	83.4	79.9	79.4	78.7	83.5	88.2	85.7	86.2	85.3
	10%	WB	75.5	75.4	74.6	70.3	65.3	61.2	59.5	60.3	64.6	69.3	71.9	74.4
		MCDB	85.1	84.1	83.2	84.1	80.5	77.4	77.5	82.9	88.4	86.8	86.2	85.1
Mean Daily Temperature Range	5% DB	MDBR	19.3	18.9	20.0	22.7	22.9	23.3	25.0	26.7	25.7	24.3	22.4	20.5
		MCDBR	23.3	23.6	23.8	25.1	25.4	25.3	27.7	28.6	26.1	26.5	24.8	24.5
		MCWBR	6.2	6.7	6.3	7.3	8.6	10.0	11.1	11.0	9.2	9.0	7.5	7.1
	5% WB	MCDBR	18.2	17.5	17.6	18.5	19.0	21.8	22.8	24.1	22.4	21.1	21.2	19.0
		MCWBR	5.1	5.2	5.1	5.8	7.2	9.6	9.7	10.1	8.6	6.6	5.9	5.1
Clear-Sky Solar Irradiance	taub	0.386	0.383	0.373	0.348	0.343	0.323	0.330	0.343	0.399	0.409	0.418	0.396	
	taud	2.513	2.527	2.541	2.533	2.483	2.513	2.463	2.398	2.284	2.292	2.339	2.464	
	Ebn at Noon	304	302	298	293	283	284	284	290	285	291	292	301	
	Edh at Noon	36	35	34	32	31	29	31	36	43	44	43	38	
All-Sky Solar Radiation	RadAvg	2124	2085	1961	1905	1642	1535	1624	1914	2155	2270	2266	2135	
	RadStd	141	197	202	91	128	77	98	63	88	129	135	126	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	-4.36	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	-4.12	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page