

HALLS CREEK, Australia

WMO: 942120

Lat: 18.2291S

Lon: 127.6640E

Elev: 424

StdP: 96.34

Time Zone: 8.00 (E08)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	9.9	11.3	-14.2	1.2	27.8	-11.3	1.5	24.4	9.0	17.2	8.3	18.5	1.6	100	0.385

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	12.4	40.0	19.2	39.1	19.4	38.2	19.6	25.0	30.1	24.6	29.7	24.2	29.3	3.8	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.0	19.9	26.1	23.6	19.4	25.9	23.1	18.9	25.8	78.9	30.1	77.2	29.6	75.8	29.2	35.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.0	7.1	6.3	DB	7.2	41.9	1.7	1.4	6.0	42.9	5.0	43.7	4.0	44.4	2.8	45.4	(4)
(5)			WB	2.2	27.6	1.3	2.9	1.3	29.7	0.6	31.4	-0.1	33.1	-1.0	35.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.6	29.9	29.2	28.8	27.1	23.1	20.1	20.2	22.1	26.9	29.9	30.9	30.6	(6)	
	DBStd	4.64	2.32	2.19	1.90	2.35	2.73	2.88	2.59	2.76	2.75	2.34	2.19	2.47	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	30	0	0	0	0	2	13	12	3	0	0	0	0	(9)	
	CDD10.0	6043	616	538	584	513	407	304	315	376	508	618	627	638	(10)	
	CDD18.3	3031	358	305	326	263	150	67	68	120	258	359	377	379	(11)	
	CDH23.3	38753	4541	3686	4001	3173	1465	631	719	1394	3344	5158	5454	5186	(12)	
(13)	CDH26.7	21122	2506	1949	2126	1664	578	170	193	542	1841	3154	3346	3052	(13)	
(14)	Wind	WSAvg	2.7	2.9	2.8	2.6	2.6	2.8	2.9	2.7	2.6	2.7	2.8	2.8	(14)	
(15) Precipitation	PrecAvg	591	163	145	96	19	13	2	5	1	5	19	41	90	(15)	
	PrecMax	1189	441	534	381	189	105	45	71	8	85	103	175	208	(16)	
	PrecMin	203	13	2	0	0	0	0	0	0	0	0	0	5	(17)	
	PrecStd	235	102	121	105	38	23	6	14	2	13	25	39	49	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.2	39.6	38.5	37.2	34.1	32.0	31.6	34.3	37.7	40.2	40.8	42.0	(19)	
		MCWB	20.7	20.0	20.5	18.9	18.3	17.9	16.3	16.7	17.2	18.3	18.3	19.1	(20)	
	2%	DB	38.6	38.2	37.1	36.2	32.7	30.2	30.1	32.7	36.4	39.1	39.7	40.1	(21)	
		MCWB	21.0	20.8	20.3	18.7	17.1	17.1	15.7	16.0	17.2	18.0	18.6	20.0	(22)	
	5%	DB	37.4	36.9	36.0	35.0	31.5	28.7	28.9	31.3	35.5	38.1	38.7	38.5	(23)	
		MCWB	21.3	21.2	20.4	18.6	16.8	15.8	14.9	15.4	17.0	17.9	19.0	20.5	(24)	
	10%	DB	36.0	35.1	34.8	33.8	30.1	27.1	27.5	29.9	34.4	37.1	37.5	36.9	(25)	
		MCWB	21.9	21.9	20.8	18.6	16.4	15.0	14.3	14.4	16.6	17.7	19.3	21.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.5	25.2	25.2	23.5	22.8	20.7	20.4	20.2	21.5	22.7	25.4	25.1	(27)	
		MCDB	31.1	30.5	30.4	28.4	26.4	26.2	25.5	26.9	27.9	29.5	29.3	30.3	(28)	
	2%	WB	24.9	24.8	24.5	22.7	21.3	18.9	18.2	18.3	20.0	22.0	23.4	24.3	(29)	
		MCDB	30.3	29.7	29.3	28.2	26.5	27.6	27.0	28.2	31.5	29.3	30.4	29.8	(30)	
	5%	WB	24.6	24.5	24.1	22.1	20.0	17.6	16.7	17.0	19.1	21.4	22.7	23.9	(31)	
		MCDB	29.9	29.4	28.8	28.5	26.6	26.4	25.9	28.6	31.2	29.9	30.1	29.6	(32)	
	10%	WB	24.2	24.1	23.7	21.3	18.5	16.2	15.3	15.7	18.1	20.7	22.2	23.6	(33)	
		MCDB	29.5	29.0	28.4	29.0	27.0	25.2	25.3	28.3	31.3	30.4	30.1	29.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.7	10.5	11.1	12.6	12.7	13.0	13.9	14.9	14.3	13.5	12.4	11.4	(35)	
		MCDBR	12.9	13.1	13.2	13.9	14.1	14.1	15.4	15.9	14.5	14.7	13.8	13.6	(36)	
	5% WB	MCWBR	3.4	3.7	3.5	4.1	4.8	5.6	6.2	6.1	5.1	5.0	4.2	4.0	(37)	
		MCWBR	10.1	9.7	9.8	10.3	10.6	12.1	12.6	13.4	12.4	11.7	11.8	10.5	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.386	0.383	0.373	0.348	0.343	0.323	0.330	0.343	0.399	0.409	0.418	0.396	(40)	
		taud	2.513	2.527	2.541	2.533	2.483	2.513	2.463	2.398	2.284	2.292	2.339	2.464	(41)	
	Ebn at Noon	Ebn at Noon	958	951	938	924	891	894	896	915	898	916	922	949	(42)	
		Edh at Noon	114	111	106	100	97	91	98	112	135	139	135	120	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	6.70	6.57	6.18	6.01	5.18	4.84	5.12	6.03	6.79	7.16	7.14	6.73	(44)	
	RadStd	RadStd	0.45	0.62	0.64	0.29	0.40	0.24	0.31	0.20	0.28	0.41	0.43	0.40	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	-2.42	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	-2.29	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page