

WYNDHAM, Australia

WMO: 942140

Lat: 15.483S

Lon: 128.117E

Elev: 16

StdP: 101.13

Time Zone: 8.00 (E08)

Period: 82-99

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 15.3	(c) 16.6	(d) -6.4	(e) 2.2	(f) 27.0	(g) -3.8	(h) 2.7	(i) 25.4	(j) 12.0	(k) 23.6	(l) 9.4	(m) 24.2	(n) 0.2	(o) N/A	(p) 0.362

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	10.6	40.9	23.8	39.9	24.0	39.0	23.9	27.9	34.2	27.4	33.4	27.0	32.8	1.7	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.5	22.1	30.2	26.0	21.4	29.9	25.6	20.9	29.8	89.3	34.4	87.0	33.3	85.3	32.8	34.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 9.1	(b) 7.2	(c) 5.4	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	29.5	31.3	30.6	30.9	29.7	27.6	24.7	24.2	26.4	30.1	32.6	33.3	32.4
	DBStd	3.63	2.41	2.14	1.92	1.98	1.92	2.56	2.26	2.41	1.64	1.39	1.77	2.62
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	7106	660	576	648	590	546	441	440	508	603	701	699	694
	CDD18.3	4064	402	343	390	340	287	191	182	249	353	443	449	436
	CDH23.3	53803	5584	4539	5377	4497	3347	1889	1772	2772	4645	6383	6690	6308
	CDH26.7	30336	3201	2411	3032	2465	1632	763	696	1318	2628	3968	4319	3903
(14) Wind	WSAvg	1.4	1.3	1.1	1.0	1.2	1.4	1.5	1.4	1.5	1.6	1.8	1.6	1.3
(15) Precipitation	PrecAvg	759	169	193	144	29	7	2	4	0	3	20	56	137
	PrecMax	1429	363	377	428	149	98	23	84	0	48	107	174	312
	PrecMin	463	36	43	0	0	0	0	0	0	0	0	2	15
	PrecStd	217	83	84	107	36	19	5	15	0	9	29	46	90
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.2	40.2	39.6	38.2	36.3	34.5	35.0	36.0	39.1	41.0	42.5	41.9
		MCWB	23.2	25.6	24.7	22.4	21.6	22.1	19.9	20.2	21.8	22.9	22.8	24.1
	2%	DB	39.4	38.2	38.2	37.0	35.2	33.4	33.2	34.8	37.8	39.7	41.0	40.4
		MCWB	24.8	25.7	24.2	22.2	21.3	20.8	19.2	20.4	21.3	22.6	23.8	24.3
	5%	DB	37.9	36.8	37.4	36.0	34.3	32.4	32.0	33.8	36.7	38.7	39.9	39.2
		MCWB	25.4	25.9	24.1	22.2	21.1	20.1	18.4	19.9	21.3	22.4	23.9	24.7
	10%	DB	36.2	35.3	36.2	35.0	33.3	31.2	30.7	32.8	35.7	37.7	38.7	37.7
		MCWB	25.7	25.9	24.1	21.7	20.7	19.1	17.3	19.3	21.1	22.7	24.2	25.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.2	28.4	28.1	27.7	26.0	24.2	22.9	23.3	25.2	28.0	27.7	28.5
		MCDB	35.2	34.1	34.5	32.0	30.7	32.1	30.8	31.3	31.7	35.3	34.3	36.4
	2%	WB	27.5	27.7	27.2	26.2	24.1	22.6	21.6	22.5	24.2	26.4	27.0	27.3
		MCDB	33.9	33.4	32.5	30.9	31.0	30.2	29.3	31.2	31.6	33.5	34.3	33.8
	5%	WB	27.1	27.2	26.7	25.5	23.5	21.6	20.6	21.8	23.6	25.6	26.5	26.8
		MCDB	33.1	32.7	31.8	30.6	30.8	29.5	28.8	30.6	31.7	32.8	33.8	33.1
	10%	WB	26.7	26.8	26.3	25.0	22.7	20.6	19.4	21.2	23.1	25.0	26.0	26.4
		MCDB	32.6	32.1	31.7	30.4	30.4	29.2	28.1	29.7	31.7	32.2	33.3	32.8
(35) Mean Daily Temperature Range	5% DB	MDBR	8.8	8.5	9.5	10.6	11.3	11.9	12.8	12.7	12.3	11.0	10.6	9.4
		MCDBR	11.2	10.9	11.2	11.6	12.0	12.3	13.7	13.3	12.8	12.3	12.0	11.6
		MCWBR	3.4	2.8	3.0	3.5	4.0	4.0	4.7	4.3	3.9	3.6	3.0	3.5
	5% WB	MCDBR	9.2	9.0	9.3	8.7	10.0	11.2	12.6	12.0	11.3	10.6	10.2	9.4
		MCWBR	3.1	3.0	3.1	3.3	3.7	4.3	4.9	4.3	3.7	3.9	3.3	3.2
(40) Clear-Sky Solar Irradiance	taub		0.417	0.413	0.399	0.380	0.374	0.344	0.348	0.364	0.424	0.446	0.455	0.425
	taud		2.468	2.479	2.517	2.506	2.455	2.498	2.465	2.399	2.283	2.259	2.286	2.425
	Ebn at Noon		929	923	917	899	869	882	887	901	879	883	888	920
	Edh at Noon		119	117	109	104	103	95	100	114	136	144	142	124
(44) All-Sky Solar Radiation	RadAvg		6.19	6.18	6.02	5.95	5.39	5.10	5.41	6.16	6.79	7.06	6.96	6.41
	RadStd		0.49	0.77	0.70	0.41	0.35	0.22	0.19	0.18	0.27	0.36	0.30	0.40

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	+0.65	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page