

ARGYLE, Australia

WMO: 942170

Lat: 16.6381S

Lon: 128.4517E

Elev: 541

StdP: 14.41

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	54.7	57.4	13.4	11.1	79.5	17.6	13.6	76.8	15.9	73.4	14.4	74.9	4.1	90	0.398

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	19.6	104.7	70.6	103.0	71.0	101.4	71.3	86.0	90.9	81.2	89.3	79.0	87.8	9.2	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
85.0	188.0	89.2	79.1	154.2	85.5	77.1	143.8	82.1	51.3	90.9	45.4	88.8	43.0	88.1	98.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.7	14.4	13.0	50.5	107.5	2.4	2.1	48.8	109.0	47.4	110.2	46.1	111.4	44.4	112.9		
(5)			40.3	93.4	1.6	5.0	39.1	97.1	38.2	100.0	37.3	102.8	36.1	106.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	83.1	87.3	86.4	86.1	84.1	78.0	73.1	73.1	76.5	85.0	89.4	90.2	88.6
	DBStd	7.48	4.09	4.09	3.70	3.89	5.00	5.63	4.94	4.95	4.30	3.88	3.99	4.55
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	8	0	0	0	0	0	5	3	0	0	0	0	0
	CDD50	12092	1156	1019	1120	1023	867	693	717	823	1050	1222	1206	1196
	CDD65	6626	691	599	655	573	403	249	254	358	600	757	756	731
	CDH74	86367	9284	7689	8558	7187	4186	2280	2388	3891	8066	11235	11297	10306
	CDH80	47902	5163	4095	4598	3805	1851	812	849	1737	4638	7071	7158	6125
Wind	WSAvg	6.4	7.0	6.3	5.8	5.8	6.0	6.0	5.8	6.2	6.5	7.0	7.1	7.1
Precipitation	PrecAvg	29.7	6.8	7.7	4.6	1.1	0.4	0.2	0.0	0.0	0.2	1.2	2.4	5.4
	PrecMax	58.1	12.1	15.7	18.7	5.1	4.0	2.6	0.3	0.2	1.4	6.3	5.3	10.7
	PrecMin	13.0	1.1	0.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.4	0.4
	PrecStd	9.2	2.6	4.5	5.3	1.5	0.8	0.5	0.1	0.0	0.3	1.6	1.4	3.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	104.3	103.7	102.4	100.3	95.9	92.9	92.6	96.3	102.0	105.6	106.8	107.4
		MCWB	72.2	73.7	71.8	70.2	68.8	66.8	65.6	66.0	67.8	70.1	68.8	70.9
	2%	DB	101.6	101.1	99.7	98.1	93.7	90.2	90.1	93.5	99.8	103.5	104.5	104.1
		MCWB	74.4	73.6	72.8	70.7	67.7	65.6	63.7	65.0	67.1	69.0	69.8	72.9
	5%	DB	99.2	98.7	97.6	96.3	91.5	87.7	87.6	91.2	98.2	101.7	102.7	101.1
		MCWB	74.9	74.7	73.1	70.5	66.8	64.2	62.0	63.4	66.8	68.9	70.6	74.2
	10%	DB	96.7	95.7	95.4	94.3	89.2	85.1	85.2	88.9	96.3	99.9	100.7	98.4
		MCWB	75.8	75.2	73.3	70.3	65.4	62.4	60.9	62.0	66.4	68.8	71.0	74.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	90.1	84.6	88.2	90.5	84.6	72.4	70.2	71.1	81.0	87.2	86.1	87.6
		MCDB	94.1	95.6	92.4	92.6	86.9	81.4	85.0	88.3	90.5	93.5	86.7	94.7
	2%	WB	81.7	79.7	80.0	82.0	75.4	69.3	67.8	69.0	74.2	77.2	78.0	81.4
		MCDB	88.2	88.4	88.0	88.9	82.1	84.2	84.9	87.5	87.2	89.8	89.0	92.0
	5%	WB	79.1	78.8	78.3	77.0	72.5	67.1	65.7	67.2	71.8	75.0	76.7	78.7
		MCDB	88.1	87.1	86.2	85.0	84.0	84.2	82.4	86.0	88.1	88.1	88.9	88.3
	10%	WB	78.2	78.1	77.5	75.3	70.0	65.1	63.4	65.2	70.1	73.8	75.8	77.7
		MCDB	87.5	86.5	85.5	85.1	84.0	81.7	80.7	84.4	89.4	88.3	88.6	87.6
Mean Daily Temperature Range	5% DB	MDBR	16.6	16.8	17.2	19.5	21.1	22.0	23.4	23.9	22.3	20.5	19.6	17.6
		MCDBR	20.0	20.8	20.2	21.0	22.0	21.9	24.0	24.0	22.6	21.9	21.6	21.1
		MCWBR	6.1	5.7	5.7	7.0	7.7	7.6	8.8	8.1	7.1	7.2	6.1	6.4
	5% WB	MCDBR	16.7	16.4	16.0	17.1	17.6	19.4	20.7	20.9	19.8	19.2	18.8	17.6
		MCWBR	6.3	5.1	6.1	11.4	11.2	7.7	9.4	7.9	8.8	7.8	5.9	6.4
Clear-Sky Solar Irradiance	taub	0.407	0.402	0.390	0.368	0.360	0.339	0.343	0.358	0.424	0.435	0.443	0.416	
	taud	2.484	2.500	2.529	2.522	2.482	2.503	2.467	2.399	2.260	2.269	2.311	2.439	
	Ebn at Noon	298	296	293	288	279	280	282	287	278	283	285	295	
	Edh at Noon	37	36	34	32	31	30	31	36	44	45	44	39	
All-Sky Solar Radiation	RadAvg	2036	2022	1934	1902	1686	1587	1682	1941	2149	2256	2229	2083	
	RadStd	147	219	219	110	122	69	69	58	98	124	106	118	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page