

DELAMERE WEAPONS RANGE, Australia

WMO: 942250

Lat: 15.7442S

Lon: 131.9183E

Elev: 727

StdP: 14.31

Time Zone: 9.50 (AUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	54.8	57.3	14.6	11.8	76.0	18.5	14.4	74.2	17.0	71.5	16.3	71.7	6.2	120	0.405

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	21.0	102.5	69.3	100.9	69.9	99.3	70.4	80.0	90.1	78.8	89.1	78.0	87.9	9.1	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.7	147.7	84.1	76.3	141.2	82.4	75.5	137.4	81.6	44.3	90.5	43.0	89.1	42.2	88.3	95.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.4	14.8	13.7	49.8	105.7	2.3	2.4	48.1	107.4	46.7	108.8	45.4	110.1	43.7	111.8		
(5)			39.8	80.6	1.7	0.8	38.6	81.2	37.6	81.6	36.6	82.1	35.4	82.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	81.1	84.5	84.2	83.8	81.9	76.9	72.2	72.4	74.6	82.2	86.8	87.5	86.4		
	DBStd	6.62	3.31	3.37	2.80	3.36	4.23	4.76	4.49	4.37	4.20	3.33	3.38	3.92		
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD65	7	0	0	0	0	0	5	2	0	0	0	0	0		
	CDD50	11343	1068	956	1048	956	835	666	693	761	966	1139	1125	1130		
	CDD65	5876	603	536	583	506	370	221	231	296	516	674	675	665		
	CDH74	72311	7096	6284	6762	6001	3709	1974	2286	3310	6810	9804	9592	8683		
	CDH80	37458	3446	3092	3286	3051	1576	643	801	1434	3748	5874	5702	4805		
(14) Wind	WSAvg	7.2	6.7	6.4	6.2	6.8	7.6	8.0	7.9	7.7	7.6	7.6	6.9	6.6		
(15) Precipitation	PrecAvg	37.4	8.1	9.2	6.1	0.8	0.2	0.1	0.0	0.0	0.2	1.3	3.0	8.1		
	PrecMax	54.0	14.3	21.8	13.9	7.0	2.0	2.1	0.2	0.0	1.1	5.4	5.7	16.0		
	PrecMin	22.9	4.1	1.6	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.7	1.9		
	PrecStd	8.7	2.5	5.9	4.1	1.7	0.5	0.5	0.0	0.0	0.3	1.5	1.3	3.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	101.9	100.7	100.1	97.0	93.8	90.9	91.1	94.5	99.5	103.5	104.1	105.5		
		MCWB	73.3	71.6	73.2	70.6	68.0	66.6	66.9	66.5	67.3	67.1	68.6	69.4		
	2%	DB	98.5	98.5	97.0	95.5	91.7	88.4	88.7	92.2	97.6	101.5	102.1	102.5		
		MCWB	75.1	73.4	73.0	70.2	67.4	66.1	64.4	65.0	66.9	67.5	69.5	70.2		
	5%	DB	96.1	96.3	95.2	94.2	90.2	86.4	86.8	89.8	96.2	99.8	100.6	99.7		
		MCWB	75.6	74.4	73.6	69.9	66.9	65.0	63.2	62.9	66.3	67.6	70.1	72.3		
	10%	DB	93.6	93.8	93.0	92.7	88.2	84.1	84.8	87.6	94.6	98.1	98.6	96.8		
		MCWB	76.2	75.1	73.7	69.5	65.9	63.1	62.0	62.0	65.7	67.6	70.8	73.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.1	80.5	79.6	76.8	74.5	70.7	70.5	70.8	73.5	75.3	89.3	82.4		
		MCDB	90.6	90.8	89.9	90.4	84.2	84.5	86.5	87.2	89.8	89.8	97.3	91.8		
	2%	WB	79.7	78.9	78.3	75.3	72.8	68.6	68.3	68.9	72.1	74.2	78.0	79.0		
		MCDB	89.8	89.4	88.2	85.9	83.4	83.9	84.5	86.3	88.7	88.9	89.9	89.5		
	5%	WB	78.7	78.1	77.4	74.4	71.1	67.1	66.3	66.8	71.0	73.3	76.1	77.9		
		MCDB	88.6	88.0	86.6	85.1	83.7	83.1	82.2	85.5	88.3	88.1	89.0	88.4		
	10%	WB	77.9	77.3	76.7	73.5	69.3	65.2	64.2	64.5	69.6	72.4	75.1	77.0		
		MCDB	87.4	86.6	85.4	84.6	83.3	81.0	81.2	83.5	88.4	87.9	88.0	87.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	16.4	17.0	17.6	21.2	21.5	22.3	23.7	25.3	24.1	22.6	21.0	18.5		
		MCDBR	20.6	21.6	21.2	23.0	23.0	23.6	24.6	26.5	24.5	24.1	23.6	23.0		
		MCWBR	5.2	5.4	5.3	6.1	8.3	9.4	10.2	10.5	9.4	9.2	8.2	6.4		
	5% WB	MCDBR	16.9	16.4	16.5	17.9	18.4	21.3	22.9	22.9	20.6	20.0	19.5	17.6		
		MCWBR	5.4	5.2	4.8	4.8	6.5	8.7	10.2	10.3	8.5	7.1	6.1	5.2		
(40) Clear-Sky Solar Irradiance	taub		0.402	0.401	0.388	0.365	0.347	0.326	0.325	0.339	0.410	0.432	0.451	0.424		
	taud		2.501	2.501	2.531	2.546	2.531	2.546	2.531	2.466	2.292	2.268	2.279	2.414		
	Ebn at Noon		299	297	294	290	284	285	289	294	283	284	283	292		
	Edh at Noon		36	36	34	32	30	29	30	34	43	45	45	40		
(44) All-Sky Solar Radiation	RadAvg		1988	1973	1947	1886	1692	1597	1695	1937	2134	2219	2162	2041		
	RadStd		157	234	191	126	99	82	61	64	108	129	80	136		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	+0.88	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page