

LAJAMANU, Australia

WMO: 942310

Lat: 18.3325S

Lon: 130.6358E

Elev: 1039

StdP: 14.15

Time Zone: 9.50 (AUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	44.1	47.0	9.4	9.2	76.1	13.7	11.5	73.8	28.8	68.8	20.8	65.8	4.4	120	0.455

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	22.4	106.2	67.4	104.4	67.6	102.7	67.7	77.2	86.4	76.5	85.8	75.9	85.5	10.0	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.4	138.2	79.6	74.5	134.1	79.6	73.7	130.3	79.6	41.6	86.4	40.9	85.4	40.3	85.2	81.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.2	18.5	16.5	38.6	109.3	2.6	2.1	36.7	110.8	35.2	112.0	33.7	113.2	31.8	114.7		
(5)			32.8	78.4	1.9	1.3	31.4	79.4	30.3	80.1	29.2	80.9	27.8	81.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	78.9	86.8	85.6	84.2	79.8	71.9	65.5	65.7	68.9	78.5	84.6	87.3	88.1	(6)
(7)		DBStd	9.78	4.48	4.32	4.09	4.84	5.65	6.02	5.50	5.85	6.26	5.07	4.37	4.58	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	161	0	0	0	0	11	64	59	26	1	0	0	0	(9)
(10)		CDD50	10532	1140	998	1059	893	679	464	487	585	856	1071	1118	1182	(10)
(11)		CDD65	5219	675	578	594	443	225	79	81	146	407	606	668	717	(11)
(12)		CDH74	71220	9133	7568	7634	5467	2488	993	1187	2206	5624	8736	9816	10368	(12)
(13)		CDH80	40675	5351	4304	4238	2992	1026	297	339	896	3192	5423	6173	6444	(13)
(14)	Wind	WSAvg	8.4	8.6	8.2	7.8	8.2	8.5	8.5	7.8	8.2	8.4	9.0	8.8	8.6	(14)
(15)	Precipitation	PrecAvg	26.9	7.4	7.2	3.9	0.9	0.3	0.2	0.0	0.2	0.9	1.4	4.1		(15)
(16)		PrecMax	59.1	23.7	22.2	17.2	6.5	3.6	1.9	0.6	0.6	1.3	3.7	4.6	9.1	(16)
(17)		PrecMin	7.6	1.4	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	(17)
(18)		PrecStd	11.8	5.2	5.7	4.6	1.7	0.8	0.5	0.2	0.1	0.3	1.1	1.1	2.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	107.7	106.1	104.8	100.4	94.6	91.1	89.5	94.3	101.0	105.3	107.1	109.5	(19)
MCWB			68.8	67.8	67.8	66.0	66.4	64.9	60.9	62.7	64.7	65.0	66.6	67.2	(20)	
2%		DB	104.5	103.5	101.1	98.0	91.0	87.0	86.5	90.9	98.7	103.3	105.1	106.6	(21)	
		MCWB	70.1	69.6	68.9	66.1	63.6	62.8	59.9	61.3	64.2	64.9	66.5	67.3	(22)	
5%		DB	101.9	100.8	98.6	96.1	88.8	83.3	83.9	88.3	96.7	101.5	103.3	104.0	(23)	
		MCWB	70.1	69.7	68.8	65.8	62.6	60.9	58.5	60.1	63.2	64.9	66.5	68.5	(24)	
10%		DB	98.9	97.9	96.3	93.8	86.2	79.9	81.1	85.4	94.5	99.4	101.0	100.9	(25)	
		MCWB	71.2	70.7	69.3	65.6	62.0	58.6	57.3	58.2	62.6	64.5	66.9	69.3	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.2	78.1	77.8	74.5	71.7	68.7	66.4	66.9	70.2	73.9	75.7	77.1	(27)
MCD B			88.6	86.9	86.5	85.7	82.8	80.5	83.2	85.4	87.9	88.0	89.1	85.5	(28)	
2%		WB	77.2	77.1	76.7	72.9	69.9	65.5	63.5	64.8	68.3	72.3	74.4	76.2	(29)	
		MCD B	86.9	86.2	85.0	84.6	83.1	83.7	80.6	84.1	90.1	86.1	87.9	85.8	(30)	
5%		WB	76.4	76.3	75.8	71.1	67.5	62.9	61.0	62.1	66.7	70.7	73.4	75.3	(31)	
		MCD B	86.1	85.6	84.5	84.4	81.8	79.8	78.1	83.5	89.7	86.6	87.0	86.1	(32)	
10%		WB	75.7	75.6	75.0	69.5	64.8	60.3	58.5	59.9	64.9	69.3	72.3	74.5	(33)	
		MCD B	85.5	84.9	84.1	85.5	80.9	76.5	77.6	82.5	89.6	87.9	87.4	86.3	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	20.6	20.8	21.4	26.0	26.4	27.1	28.9	30.5	29.5	27.3	24.5	22.4	(35)
MCDBR			25.9	26.5	25.9	28.4	29.0	29.0	31.5	32.1	29.8	29.9	28.8	27.8	(36)	
MCWBR			6.4	6.5	6.8	8.6	10.3	11.5	13.2	13.1	10.7	9.9	8.9	7.7	(37)	
5% WB		MCDBR	17.9	17.5	16.3	20.4	20.5	24.6	26.5	27.3	24.1	22.1	20.7	19.2	(38)	
		MCWBR	4.8	4.8	4.6	6.4	7.4	10.2	11.3	11.3	9.3	6.6	5.1	4.9	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.384	0.382	0.372	0.351	0.341	0.322	0.327	0.340	0.400	0.415	0.414	0.399	(40)	
taud		2.522	2.538	2.554	2.529	2.498	2.520	2.480	2.421	2.295	2.282	2.357	2.455	(41)		
Ebn at Noon		305	302	298	292	284	284	285	292	285	289	293	300	(42)		
Edh at Noon		36	35	33	32	30	29	30	35	42	44	42	38	(43)		
(44)	All-Sky Solar Radiation	RadAvg	2164	2118	1996	1900	1634	1529	1617	1896	2137	2260	2254	2155	(44)	
(45)		RadStd	128	176	198	115	124	75	82	64	106	140	135	124	(45)	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page