

LAJAMANU, Australia

WMO: 942310

Lat: 18.3325S

Lon: 130.6358E

Elev: 317

StdP: 97.58

Time Zone: 9.50 (AUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	6.7	8.3	-12.6	1.3	24.5	-10.1	1.6	23.2	12.9	20.4	9.3	18.8	2.0	120	0.455

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	12.4	41.2	19.7	40.2	19.8	39.3	19.8	25.1	30.2	24.7	29.9	24.4	29.7	4.5	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.1	19.7	26.4	23.6	19.2	26.5	23.2	18.6	26.5	78.9	30.2	77.3	29.7	75.8	29.6	27.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.5	8.3	7.4	DB	3.7	42.9	1.5	1.2	2.6	43.8	1.8	44.4	1.0	45.1	-0.1	45.9	(4)
(5)			WB	0.4	25.8	1.1	0.7	-0.3	26.3	-0.9	26.7	-1.5	27.1	-2.3	27.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.0	30.4	29.8	29.0	26.5	22.2	18.6	18.7	20.5	25.9	29.2	30.7	31.2	(6)	
	DBStd	5.43	2.49	2.40	2.27	2.69	3.14	3.35	3.05	3.25	3.48	2.82	2.43	2.55	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	89	0	0	0	0	6	36	33	14	1	0	0	0	(9)	
	CDD10.0	5851	633	554	588	496	377	258	271	325	476	595	621	657	(10)	
	CDD18.3	2899	375	321	330	246	125	44	45	81	226	337	371	398	(11)	
	CDH23.3	39567	5074	4204	4241	3037	1382	552	659	1226	3124	4853	5453	5760	(12)	
(13)	CDH26.7	22597	2973	2391	2354	1662	570	165	188	498	1773	3013	3429	3580	(13)	
(14)	Wind	WSAvg	3.7	3.8	3.7	3.5	3.7	3.8	3.5	3.7	3.8	4.0	3.9	3.8	(14)	
(15) Precipitation	PrecAvg	682	188	184	98	23	8	6	1	1	5	22	36	103	(15)	
	PrecMax	1501	601	563	436	164	92	47	16	14	32	93	116	230	(16)	
	PrecMin	193	36	10	1	0	0	0	0	0	0	0	0	2	(17)	
	PrecStd	300	131	145	118	42	20	13	4	3	8	28	28	62	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.0	41.2	40.4	38.0	34.8	32.8	32.0	34.6	38.4	40.7	41.7	43.0	(19)	
		MCWB	20.5	19.9	19.9	18.9	19.1	18.3	16.0	17.1	18.1	18.4	19.2	19.5	(20)	
	2%	DB	40.3	39.7	38.4	36.7	32.8	30.6	30.3	32.7	37.0	39.6	40.6	41.4	(21)	
		MCWB	21.2	20.9	20.5	18.9	17.6	17.1	15.5	16.3	17.9	18.3	19.1	19.6	(22)	
	5%	DB	38.8	38.2	37.0	35.6	31.5	28.5	28.8	31.3	35.9	38.6	39.6	40.0	(23)	
		MCWB	21.2	20.9	20.5	18.8	17.0	16.0	14.7	15.6	17.4	18.3	19.2	20.3	(24)	
	10%	DB	37.2	36.6	35.7	34.3	30.1	26.6	27.3	29.7	34.7	37.5	38.3	38.3	(25)	
		MCWB	21.8	21.5	20.7	18.7	16.7	14.8	14.1	14.5	17.0	18.1	19.4	20.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.6	25.6	25.5	23.6	22.1	20.4	19.1	19.4	21.2	23.3	24.3	25.1	(27)	
		MCDB	31.5	30.5	30.3	29.8	28.2	26.9	28.5	29.7	31.1	31.1	31.7	29.7	(28)	
	2%	WB	25.1	25.0	24.8	22.7	21.1	18.6	17.5	18.2	20.2	22.4	23.5	24.5	(29)	
		MCDB	30.5	30.1	29.4	29.2	28.4	28.7	27.0	29.0	32.3	30.1	31.1	29.9	(30)	
	5%	WB	24.7	24.6	24.3	21.7	19.7	17.1	16.1	16.7	19.3	21.5	23.0	24.1	(31)	
		MCDB	30.0	29.8	29.2	29.1	27.7	26.5	25.6	28.6	32.1	30.3	30.6	30.0	(32)	
	10%	WB	24.3	24.2	23.9	20.8	18.2	15.7	14.7	15.5	18.3	20.7	22.4	23.6	(33)	
		MCDB	29.7	29.4	28.9	29.7	27.1	24.7	25.3	28.1	32.0	31.1	30.8	30.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	11.4	11.6	11.9	14.4	14.6	15.0	16.0	17.0	16.4	15.2	13.6	12.4	(35)	
		MCDBR	14.4	14.7	14.4	15.8	16.1	16.1	17.5	17.8	16.6	16.6	16.0	15.4	(36)	
	5% WB	MCWBR	3.6	3.6	3.8	4.8	5.7	6.4	7.3	7.3	6.0	5.5	4.9	4.3	(37)	
		MCWBR	10.0	9.7	9.0	11.3	11.4	13.7	14.7	15.1	13.4	12.3	11.5	10.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.384	0.382	0.372	0.351	0.341	0.322	0.327	0.340	0.400	0.415	0.414	0.399	(40)	
		taud	2.522	2.538	2.554	2.529	2.498	2.520	2.480	2.421	2.295	2.282	2.357	2.455	(41)	
	Ebn at Noon		960	952	939	922	894	895	900	919	897	910	925	946	(42)	
		Edh at Noon	113	110	105	100	96	90	96	110	133	140	133	121	(43)	
(44) All-Sky Solar Radiation	RadAvg		6.82	6.68	6.29	5.99	5.15	4.82	5.10	5.98	6.74	7.12	7.11	6.79	(44)	
	RadStd		0.40	0.56	0.62	0.36	0.39	0.23	0.26	0.20	0.33	0.44	0.43	0.39	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page