

VICTORIA RIVER DOWNS, Australia

WMO: 942320

Lat: 16.403S

Lon: 131.014E

Elev: 295

StdP: 14.54

Time Zone: 9.50 (AUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	45.4	48.3	18.2	13.9	74.6	21.8	16.5	72.7	14.2	79.5	12.4	78.0	2.7	270	0.370

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	22.3	104.0	70.3	102.3	70.7	100.6	71.2	81.9	88.3	79.8	88.4	78.8	87.9	7.2	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.7	161.2	84.2	77.8	146.0	82.6	76.8	140.9	82.0	46.2	88.2	43.6	88.7	42.6	87.9	98.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.2	12.3	11.2	40.3	106.3	2.2	1.8	38.7	107.6	37.5	108.6	36.3	109.6	34.7	110.9		
(5)			35.2	88.7	1.9	7.8	33.8	94.3	32.7	98.8	31.6	103.2	30.2	108.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	80.2	86.0	85.2	84.2	81.1	74.5	68.9	68.8	71.6	80.5	86.0	88.2	87.6		
	DBStd	8.44	3.26	3.41	2.87	4.15	5.58	6.05	5.72	5.59	5.58	4.59	3.59	3.73		
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD65	68	0	0	0	0	4	29	27	8	0	0	0	0		
	CDD50	11010	1117	985	1059	932	759	567	582	668	916	1116	1145	1164		
	CDD65	5603	652	565	594	482	298	146	144	211	466	651	695	699		
	CDH74	74587	8381	6972	7162	5844	3520	1847	2028	3220	6488	9459	10096	9570		
	CDH80	40462	4387	3511	3587	3134	1625	664	748	1507	3776	5825	6198	5500		
(14) Wind	WSAvg	4.5	4.6	4.1	3.9	4.1	4.3	4.4	4.1	4.4	4.8	5.2	4.8	4.9		
(15) Precipitation	PrecAvg	29.3	6.3	8.1	5.2	0.9	0.4	0.0	0.2	0.0	0.2	0.8	2.5	4.6		
	PrecMax	44.3	14.5	22.8	15.7	10.0	2.1	0.7	3.0	1.1	1.1	3.9	8.7	11.6		
	PrecMin	12.3	0.5	0.2	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.5		
	PrecStd	8.4	3.6	5.3	4.1	2.0	0.6	0.1	0.6	0.2	0.3	0.9	1.8	2.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	103.3	102.8	100.4	99.4	95.6	92.5	91.9	96.5	100.6	104.8	105.7	106.2		
		MCWB	73.5	72.3	72.2	69.6	68.8	66.8	66.0	67.0	67.8	68.9	69.8	70.7		
	2%	DB	99.9	100.2	98.2	97.1	92.9	89.3	89.4	93.6	98.8	102.8	103.9	103.4		
		MCWB	74.6	73.0	72.9	69.7	67.3	66.0	64.2	65.1	67.4	68.6	70.0	71.8		
	5%	DB	97.7	97.8	96.0	95.4	91.0	86.9	87.1	90.8	97.2	101.1	102.2	100.7		
		MCWB	75.4	74.5	73.5	69.8	67.1	64.5	62.8	63.2	66.9	68.7	70.7	73.5		
	10%	DB	95.5	94.9	93.9	93.5	88.9	84.1	84.6	88.4	95.4	99.2	100.1	98.0		
		MCWB	76.1	75.6	73.8	70.4	66.2	62.2	61.9	62.1	66.1	69.3	71.6	74.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	83.3	81.8	80.1	84.9	78.0	72.6	70.8	70.2	74.5	91.0	85.3	86.7		
		MCDB	88.7	89.1	87.7	87.4	84.7	82.2	85.6	90.5	89.5	92.6	89.7	89.1		
	2%	WB	80.1	80.0	79.0	77.2	74.1	69.1	67.8	68.0	72.5	78.2	77.9	79.4		
		MCDB	89.6	88.6	87.2	86.1	84.6	84.5	84.7	87.8	89.3	89.1	89.9	88.2		
	5%	WB	79.2	79.1	78.2	75.7	71.8	66.9	65.6	66.2	71.1	74.9	76.6	78.2		
		MCDB	88.8	87.6	86.4	85.4	84.1	83.4	81.8	86.5	90.0	88.1	89.6	88.0		
	10%	WB	78.4	78.3	77.6	74.4	69.2	64.6	63.5	64.1	69.6	73.6	75.7	77.4		
		MCDB	87.9	86.5	85.6	85.0	83.4	81.1	81.1	84.5	90.0	88.1	88.9	87.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	17.3	17.0	18.5	24.3	27.8	28.8	30.8	32.5	29.2	25.3	22.3	19.2		
		MCDBR	21.4	22.7	23.0	26.5	28.7	29.4	31.4	32.7	28.8	28.0	26.1	23.6		
	5% WB	MCWBR	5.6	5.8	5.4	7.1	10.1	11.4	12.8	13.0	10.3	10.2	8.0	6.2		
		MCWBR	17.0	15.8	15.8	19.3	20.8	25.9	27.3	28.0	22.7	20.6	20.7	17.9		
(40) Clear-Sky Solar Irradiance	taub		0.412	0.410	0.395	0.374	0.360	0.341	0.344	0.357	0.428	0.443	0.458	0.431		
		taud	2.469	2.473	2.508	2.507	2.482	2.492	2.460	2.400	2.235	2.237	2.259	2.390		
	Ebn at Noon		296	294	292	286	279	279	282	287	277	281	281	290		
		Edh at Noon	38	37	35	33	31	30	32	36	45	47	46	41		
(44) All-Sky Solar Radiation	RadAvg		2036	1992	1951	1886	1680	1582	1680	1930	2138	2229	2196	2059		
	RadStd		149	232	203	115	103	77	65	65	103	126	88	131		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page