

DALY WATERS, Australia

WMO: 942340

Lat: 16.2636S

Lon: 133.3783E

Elev: 211

StdP: 98.81

Time Zone: 9.50 (AUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.4	9.1	-8.3	1.9	22.9	-6.7	2.2	21.8	7.1	20.0	6.4	21.9	1.2	170	0.383

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	14.2	40.0	20.4	39.0	20.6	38.1	20.8	25.9	31.4	25.5	30.9	25.1	30.5	3.6	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.7	20.3	27.5	24.2	19.6	27.3	23.8	19.2	27.2	81.6	31.4	79.8	31.0	78.2	30.6	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.9	6.5	5.8	4.5	41.6	1.2	1.3	3.7	42.5	3.0	43.3	2.3	44.0	1.4	45.0
			1.8	26.7	1.2	0.7	1.0	27.2	0.3	27.6	-0.4	28.0	-1.3	28.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	26.3	29.3	28.9	28.4	26.6	23.6	20.9	20.5	21.5	25.8	28.9	30.4	30.4
	DBStd	4.26	2.03	1.74	1.73	1.98	2.72	2.84	2.51	2.59	2.75	2.19	1.96	2.17
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	22	0	0	0	0	1	9	8	3	0	0	0	0
	CDD10.0	5932	597	528	569	499	422	328	326	357	473	586	612	633
	CDD18.3	2913	339	295	311	249	165	87	77	102	223	328	362	375
	CDH23.3	38018	4049	3426	3561	2899	1919	1018	1156	1686	3228	4792	5194	5089
CDH26.7	20733	2081	1734	1836	1543	896	372	436	787	1885	2973	3208	2982	
Wind	WSAvg	2.5	2.6	2.4	2.2	2.3	2.6	2.7	2.5	2.5	2.5	2.8	2.6	2.6
Precipitation	PrecAvg	792	178	204	115	22	2	6	3	1	7	24	64	130
	PrecMax	1264	325	526	368	151	19	128	43	12	66	129	155	266
	PrecMin	502	12	27	0	0	0	0	0	0	0	0	0	27
	PrecStd	198	95	123	113	32	4	24	10	2	14	31	38	74
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.9	38.9	38.6	36.4	35.1	33.1	33.1	35.2	38.1	40.2	40.9	41.6
		MCWB	22.1	20.8	22.1	20.9	19.8	19.2	19.0	18.7	19.3	19.6	20.3	20.4
	2%	DB	38.1	37.4	36.9	35.4	33.8	31.7	31.7	33.7	36.9	39.1	39.7	40.1
		MCWB	22.5	22.6	22.6	20.9	19.6	18.7	17.6	17.9	18.9	19.6	20.1	20.7
	5%	DB	36.5	36.1	35.6	34.6	32.8	30.5	30.6	32.4	36.0	38.1	38.9	38.6
		MCWB	23.1	23.2	22.7	20.8	19.2	17.9	16.9	17.0	18.7	19.5	20.2	21.5
	10%	DB	34.9	34.6	34.3	33.7	31.6	29.1	29.4	31.1	34.9	37.2	37.9	37.2
		MCWB	23.7	23.4	22.7	20.6	18.7	16.9	16.1	16.2	18.2	19.3	20.5	22.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.4	26.6	26.4	24.6	23.4	21.2	20.9	20.9	22.4	24.1	24.9	25.7
		MCDB	32.1	32.1	30.9	30.3	29.9	29.6	29.4	30.2	32.1	31.2	30.7	31.0
	2%	WB	25.8	25.9	25.7	23.9	22.4	20.1	19.5	19.7	21.6	23.1	24.1	25.1
		MCDB	31.2	31.4	31.1	29.8	29.1	29.1	28.9	30.4	31.5	31.6	31.2	30.7
	5%	WB	25.4	25.5	25.2	23.3	21.3	19.1	18.2	18.5	20.9	22.5	23.6	24.7
		MCDB	30.8	30.9	30.6	29.4	29.0	28.3	27.9	29.6	31.5	31.4	31.1	30.4
	10%	WB	25.0	25.0	24.7	22.8	20.2	18.0	17.1	17.3	20.1	21.9	23.2	24.3
		MCDB	30.3	30.4	30.0	29.0	29.0	26.6	27.4	29.0	30.5	31.3	30.8	30.1
Mean Daily Temperature Range	5% DB	MDBR	10.2	10.7	11.5	14.1	15.7	15.8	17.6	19.0	18.4	16.7	14.2	11.9
		MCDBR	13.2	13.9	14.1	15.6	17.1	17.4	19.2	20.6	19.1	18.2	16.8	15.1
		MCWBR	3.0	3.2	3.4	4.5	5.8	6.9	7.8	7.9	6.6	5.9	4.9	4.1
	5% WB	MCDBR	9.6	9.7	10.1	12.4	14.1	15.9	17.6	18.1	15.0	14.0	12.2	10.3
		MCWBR	2.8	3.0	3.0	3.8	5.0	6.1	7.3	7.2	5.6	4.5	3.1	2.7
Clear-Sky Solar Irradiance	taub	0.405	0.395	0.382	0.365	0.344	0.324	0.325	0.333	0.396	0.429	0.443	0.426	
	taud	2.492	2.522	2.553	2.550	2.542	2.555	2.533	2.487	2.336	2.277	2.301	2.405	
	Ebn at Noon	940	940	931	912	898	901	909	931	903	898	898	920	
	Edh at Noon	117	112	105	99	93	89	93	104	129	141	140	127	
All-Sky Solar Radiation	RadAvg	6.33	6.32	6.12	5.89	5.30	4.97	5.28	6.07	6.74	7.06	6.86	6.51	
	RadStd	0.54	0.67	0.60	0.41	0.30	0.27	0.20	0.20	0.35	0.41	0.28	0.47	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page