

CENTRE ISLAND, Australia

WMO: 942480

Lat: 15.742S

Lon: 136.819E

Elev: 42

StdP: 14.67

Time Zone: 9.50 (AUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	62.8	64.3	39.8	36.2	68.5	42.5	40.1	69.2	28.6	70.7	25.8	69.8	15.1	140	0.504

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	10.9	96.2	78.6	94.8	78.9	93.6	78.7	83.5	90.2	82.4	90.3	81.6	89.4	11.0	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.8	165.9	87.5	80.4	157.8	86.9	79.5	153.1	86.4	47.7	90.5	46.3	90.3	45.4	89.9	91.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.6	23.7	21.4	59.7	100.1	2.9	1.5	57.6	101.2	55.9	102.0	54.3	102.9	52.2	104.0		
(5)			49.3	84.5	1.8	2.3	48.0	86.1	47.0	87.5	46.0	88.7	44.7	90.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	81.4	86.2	85.8	85.2	83.6	78.6	73.6	72.6	74.3	79.2	83.8	86.8	87.5		
	DBStd	6.03	3.19	3.21	2.87	2.69	3.48	3.80	2.82	2.68	2.61	2.40	1.99	2.72		
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD50	11461	1122	1002	1092	1007	885	708	702	753	877	1049	1103	1161		
	CDD65	5986	657	582	627	557	420	258	237	288	427	584	653	696		
	CDH74	64750	8693	7572	7884	6427	3307	1046	711	1185	3293	6618	8541	9473		
(13)	CDH80	27974	4344	3661	3558	2440	725	119	52	160	930	2654	4274	5057		
(14)	Wind	WSAvg	11.3	10.6	10.7	10.5	12.1	12.9	12.5	12.0	11.6	10.7	10.6	10.5		
(15) Precipitation	PrecAvg	38.6	8.5	11.3	11.0	3.3	0.4	0.0	0.1	0.1	0.1	0.4	1.4	4.1		
	PrecMax	65.9	24.8	22.6	47.8	26.3	3.1	0.4	0.6	0.5	0.9	2.5	9.8	14.6		
	PrecMin	17.8	0.2	0.2	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
	PrecStd	13.7	5.9	6.3	11.7	5.1	0.7	0.1	0.1	0.1	0.2	0.7	2.1	3.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	98.0	96.8	96.3	93.5	89.4	85.2	83.6	85.2	90.6	95.0	97.1	98.1		
		MCWB	79.1	80.0	79.0	75.9	75.0	72.0	69.9	70.3	72.9	74.5	76.9	78.5		
	2%	DB	95.3	94.5	93.6	91.5	87.3	83.1	81.4	83.3	88.6	92.5	95.1	95.9		
		MCWB	80.0	79.7	78.5	76.3	74.1	71.3	68.6	69.2	73.0	75.5	77.1	79.3		
	5%	DB	93.4	92.9	91.9	90.0	85.6	81.2	79.7	81.9	86.9	91.1	93.5	94.4		
		MCWB	80.4	79.6	78.2	76.1	73.5	70.3	67.4	68.5	72.6	75.6	77.3	79.4		
	10%	DB	91.8	91.2	90.4	88.4	84.0	79.3	78.0	80.1	85.2	89.6	92.2	93.0		
		MCWB	80.1	79.5	78.2	75.8	72.7	69.1	66.4	67.5	72.1	75.8	77.5	79.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	86.3	84.5	83.3	81.4	79.3	75.5	73.8	74.7	78.0	80.8	82.2	83.6		
		MCDB	90.0	91.2	90.8	87.2	85.8	80.8	79.1	80.9	85.8	89.0	92.9	91.4		
	2%	WB	84.1	82.7	81.9	80.1	77.8	74.4	72.2	73.4	76.7	79.5	81.1	82.3		
		MCDB	89.2	90.1	89.6	85.7	83.3	79.2	77.0	78.9	83.8	87.7	90.5	91.2		
	5%	WB	82.5	81.8	81.0	79.4	76.8	73.3	71.0	72.4	75.7	78.7	80.3	81.5		
		MCDB	89.7	89.1	88.0	85.2	82.0	77.7	75.6	77.4	82.4	86.8	89.1	90.1		
	10%	WB	81.4	80.9	80.3	78.6	75.8	72.2	69.9	71.2	74.9	77.9	79.7	80.8		
		MCDB	88.8	88.2	86.9	84.7	81.1	76.9	74.5	76.0	81.3	85.5	88.0	89.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.2	9.8	9.7	10.0	10.6	11.1	11.8	12.9	13.0	12.6	12.2	10.9		
		MCDBR	12.1	11.5	11.7	11.5	11.4	11.7	12.7	13.9	13.9	13.7	13.3	12.5		
	5% WB	MCWBR	4.7	4.4	4.8	4.8	5.8	6.3	6.7	6.4	5.2	5.2	4.8	4.2		
		MCWBR	11.1	10.7	10.5	9.5	10.0	10.6	11.3	12.5	12.6	12.4	12.2	11.5		
(40) Clear-Sky Solar Irradiance	taub		0.412	0.403	0.387	0.378	0.357	0.341	0.326	0.332	0.381	0.408	0.426	0.425		
	taud		2.523	2.550	2.594	2.578	2.581	2.575	2.621	2.582	2.452	2.404	2.407	2.454		
	Ebn at Noon		296	296	294	286	282	281	289	296	292	291	290	292		
	Edh at Noon		36	35	32	31	29	28	27	30	36	40	40	38		
(44) All-Sky Solar Radiation	RadAvg		1832	1835	1789	1778	1630	1526	1630	1880	2136	2251	2201	2010		
	RadStd		206	264	207	155	90	89	45	49	75	113	111	203		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page