

CAMOOWEAL TOWNSHIP, Australia

WMO: 942550

Lat: 19.9223S

Lon: 138.1215E

Elev: 760

StdP: 14.30

Time Zone: 10.00 (E10)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	42.5	45.5	12.1	10.5	69.8	14.9	12.0	68.9	21.2	67.8	20.0	68.6	5.4	210	0.465

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	22.3	105.9	68.6	104.0	68.3	102.3	68.3	78.4	87.8	77.6	86.9	76.8	86.2	9.5	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.5	142.1	81.2	75.5	137.4	81.0	74.5	132.6	81.0	42.6	87.8	41.8	86.7	40.9	85.8	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.5	18.5	16.7	36.6	109.2	1.9	2.6	35.2	111.0	34.1	112.6	33.1	114.0	31.7	116.0		
(5)			30.8	79.6	1.8	1.2	29.5	80.5	28.4	81.3	27.4	81.9	26.0	82.8	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	78.0	87.0	86.0	84.0	79.3	71.0	64.5	64.5	67.7	76.4	82.4	86.2	88.2
	DBStd	10.19	4.70	4.29	4.20	4.92	6.19	6.18	5.77	6.06	6.23	5.75	4.87	4.95
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	232	0	0	0	1	19	86	83	40	3	0	0	0
	CDD50	10238	1147	1007	1054	879	652	434	449	549	793	1005	1085	1184
	CDD65	4996	682	587	589	430	206	70	67	124	346	541	635	719
	CDH74	69527	9433	7932	7734	5375	2380	915	1033	1984	4800	7872	9376	10693
	CDH80	39626	5562	4575	4334	2851	951	250	271	769	2619	4808	5867	6769
Wind	WSAvg	8.6	8.1	8.2	8.1	8.3	8.7	8.9	8.7	8.8	9.0	9.1	8.8	8.6
Precipitation	PrecAvg	15.4	4.3	3.8	2.2	0.6	0.5	0.2	0.2	0.1	0.3	0.6	1.0	2.4
	PrecMax	39.5	23.3	15.2	9.8	6.9	2.9	2.2	3.0	1.1	3.0	3.2	3.3	10.2
	PrecMin	5.9	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2
	PrecStd	7.5	4.6	3.4	2.2	1.2	0.8	0.4	0.6	0.2	0.6	0.7	0.9	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	108.0	106.4	103.8	98.9	93.8	88.8	88.7	94.1	100.4	104.9	106.7	109.1
		MCWB	70.3	69.7	69.9	67.5	66.0	64.0	63.4	63.2	64.5	65.9	66.8	68.9
	2%	DB	104.3	103.1	100.8	96.8	90.6	85.9	85.5	90.7	97.8	102.6	104.3	106.1
		MCWB	70.2	69.6	69.9	66.5	64.1	62.9	60.7	61.8	63.5	65.3	66.9	68.6
	5%	DB	102.0	100.7	98.5	94.8	88.4	83.0	83.2	87.7	95.4	100.3	102.2	104.0
		MCWB	70.8	70.1	69.9	66.3	63.3	60.7	58.9	59.9	62.6	65.1	66.9	68.3
	10%	DB	99.2	98.2	96.1	92.7	85.9	79.6	80.4	84.3	92.9	97.9	100.1	101.5
		MCWB	71.3	70.5	69.5	66.1	62.0	58.9	57.6	58.0	61.7	64.3	66.7	69.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.9	79.2	78.2	75.2	72.5	67.2	67.7	66.9	70.2	73.5	76.2	78.5
		MCDB	89.9	88.5	87.9	86.2	83.5	82.2	81.8	84.1	85.4	88.5	88.5	87.3
	2%	WB	78.7	78.3	77.0	73.4	69.0	65.3	64.2	64.5	67.9	71.4	74.8	77.2
		MCDB	88.1	87.7	86.8	83.9	82.4	80.4	79.9	84.5	85.7	87.1	87.8	86.6
	5%	WB	77.7	77.5	76.0	71.9	66.4	63.4	61.4	62.0	65.9	69.5	73.7	76.2
		MCDB	86.9	86.7	85.6	84.9	83.0	78.1	79.1	84.2	87.4	88.3	86.7	86.4
	10%	WB	76.7	76.7	74.9	70.1	64.3	61.1	59.0	59.5	63.9	67.8	72.6	75.3
		MCDB	86.0	85.9	84.5	85.1	82.0	76.4	77.3	82.4	87.8	88.8	86.8	86.2
Mean Daily Temperature Range	5% DB	MDBR	20.0	20.9	22.0	24.8	26.3	27.8	29.3	30.5	29.4	27.8	25.1	22.3
		MCDBR	25.1	25.7	25.9	27.6	27.5	29.5	31.1	32.2	30.4	30.0	27.9	26.8
		MCWBR	7.7	7.8	8.3	9.7	11.3	13.1	14.3	13.8	11.7	11.2	9.2	8.8
	5% WB	MCDBR	18.0	17.8	18.6	20.2	22.8	24.8	26.7	28.5	25.5	23.7	22.1	18.7
	MCWBR	5.2	5.1	5.6	7.1	9.9	10.9	12.1	12.5	10.6	9.5	6.2	5.7	
Clear-Sky Solar Irradiance	taub		0.397	0.399	0.376	0.357	0.343	0.322	0.325	0.339	0.379	0.397	0.416	0.415
	taud		2.451	2.435	2.479	2.472	2.452	2.481	2.444	2.384	2.303	2.280	2.300	2.353
	Ebn at Noon		301	296	296	289	281	282	284	290	290	293	293	296
	Edh at Noon		39	39	36	33	31	29	31	36	42	44	44	43
All-Sky Solar Radiation	RadAvg		2145	2162	2031	1847	1571	1447	1559	1839	2124	2306	2312	2237
	RadStd		198	164	164	137	94	86	70	67	118	160	114	184

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page