

CENTURY MINE, Australia

WMO: 942610

Lat: 18.7569S

Lon: 138.7056E

Elev: 417

StdP: 14.48

Time Zone: 10.00 (E10)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	49.5	52.0	13.3	11.0	72.1	16.3	12.7	73.4	15.3	74.3	14.2	73.8	4.4	180	0.398

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	21.4	105.4	69.0	103.6	69.1	102.0	69.2	78.3	86.8	77.7	86.4	77.1	86.0	8.2	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.5	140.3	81.3	75.8	136.8	80.9	75.1	133.6	80.6	42.2	86.7	41.6	86.3	41.0	85.5	81.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.8	14.2	13.1	44.0	108.8	2.3	2.2	42.4	110.4	41.0	111.7	39.7	113.0	38.1	114.6		
(5)			36.4	80.1	2.5	0.8	34.7	80.7	33.2	81.2	31.8	81.6	30.0	82.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	80.3	86.7	85.7	85.1	81.5	75.3	69.7	69.4	71.6	78.6	84.6	87.3	88.4		
	DBStd	8.09	4.38	3.87	3.51	4.05	5.04	5.05	4.84	4.54	4.09	4.18	3.57	4.07		
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD65	36	0	0	0	0	2	14	16	4	0	0	0	0		
	CDD50	11054	1137	999	1087	945	785	590	602	669	859	1071	1119	1191		
	CDD65	5615	672	579	622	495	322	154	153	208	409	606	669	726		
	CDH74	74107	9031	7608	7932	5894	3252	1462	1641	2688	5453	8730	9759	10657		
	CDH80	41516	5130	4224	4342	3127	1384	442	522	1143	3075	5415	6092	6620		
(14) Wind	WSAvg	6.5	6.3	6.1	6.1	6.4	6.5	6.5	6.4	6.5	6.6	6.9	6.9	6.8		
(15) Precipitation	PrecAvg	23.4	6.4	5.6	2.4	0.9	0.3	0.2	0.1	0.0	0.1	0.7	1.9	4.7		
	PrecMax	53.6	24.6	14.1	14.0	7.4	2.5	2.0	1.2	0.3	0.7	4.3	4.8	24.1		
	PrecMin	7.6	0.3	0.9	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.6	0.6		
	PrecStd	9.9	5.0	3.7	2.9	1.7	0.5	0.5	0.2	0.1	0.2	1.0	1.3	4.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	107.5	105.3	104.5	98.9	95.4	89.9	90.6	94.9	101.3	105.2	106.7	107.7		
		MCWB	69.6	69.5	69.3	68.2	66.8	65.0	64.9	64.4	65.5	67.1	68.1	69.0		
	2%	DB	103.7	102.4	101.1	97.0	92.0	87.3	87.8	92.1	98.5	102.8	104.2	105.2		
		MCWB	71.2	69.8	70.1	67.6	65.8	63.9	62.8	63.2	64.1	66.9	67.6	69.3		
	5%	DB	101.1	99.8	98.8	95.3	89.9	85.1	85.5	89.3	96.0	101.0	102.5	103.1		
		MCWB	72.1	70.8	70.5	67.6	65.2	62.5	61.0	61.2	63.9	66.9	67.9	70.3		
	10%	DB	98.3	97.3	96.2	93.3	87.6	82.4	83.2	86.7	93.8	98.8	100.5	100.7		
		MCWB	72.6	71.8	71.0	66.9	64.3	61.1	59.8	59.6	63.3	66.5	68.2	71.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.2	79.6	78.3	76.8	73.7	67.9	69.3	69.1	71.8	74.5	77.2	78.3		
		MCDB	87.4	88.0	86.8	85.2	85.8	83.2	84.9	85.9	87.1	87.5	89.3	88.4		
	2%	WB	78.3	78.3	77.3	75.4	71.0	66.0	66.9	66.4	70.2	73.2	75.8	77.4		
		MCDB	86.4	86.6	85.9	84.5	83.6	83.4	79.5	83.5	86.2	88.9	88.1	87.5		
	5%	WB	77.7	77.6	76.5	73.9	69.2	64.6	64.2	64.1	68.6	72.0	74.8	76.6		
		MCDB	86.0	85.9	85.2	83.3	82.2	81.3	79.8	84.3	85.4	88.7	87.6	87.0		
	10%	WB	77.1	76.8	75.8	72.1	66.9	63.0	61.9	61.9	66.8	70.7	73.9	76.0		
		MCDB	85.6	85.4	84.6	83.5	82.9	79.4	79.6	82.6	86.7	88.5	87.5	86.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	18.8	19.5	19.8	22.2	22.9	23.8	25.4	28.4	28.9	27.3	24.6	21.4		
		MCDBR	24.9	25.1	24.7	25.7	24.8	26.3	28.4	32.5	32.9	30.0	28.2	26.0		
	5% WB	MCWBR	5.9	6.5	6.8	7.8	9.2	10.6	12.0	12.2	10.8	8.5	7.8	7.2		
		MCWBR	17.1	16.8	17.3	17.4	19.7	23.3	24.2	29.0	26.8	26.2	22.3	19.3		
(40) Clear-Sky Solar Irradiance	taub		0.414	0.411	0.384	0.362	0.349	0.331	0.331	0.348	0.391	0.409	0.429	0.426		
	taud		2.432	2.434	2.500	2.505	2.474	2.487	2.463	2.392	2.301	2.287	2.299	2.358		
	Ebn at Noon		296	293	294	288	280	280	283	288	287	290	289	292		
	Edh at Noon		39	39	35	32	31	30	31	36	42	44	44	42		
(44) All-Sky Solar Radiation	RadAvg		2005	2056	1992	1849	1601	1484	1588	1860	2147	2301	2272	2156		
	RadStd		215	193	178	140	86	91	58	60	95	140	117	202		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	+1.82	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page