

CENTURY MINE, Australia

WMO: 942610

Lat: 18.7569S

Lon: 138.7056E

Elev: 127

StdP: 99.81

Time Zone: 10.00 (E10)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	9.7	11.1	-10.4	1.6	22.3	-8.7	1.8	23.0	6.9	23.5	6.4	23.2	2.0	180	0.398

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	11.9	40.8	20.6	39.8	20.6	38.9	20.7	25.7	30.4	25.4	30.2	25.1	30.0	3.7	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.7	20.0	27.4	24.3	19.5	27.2	23.9	19.1	27.0	80.3	30.4	78.8	30.2	77.4	29.7	27.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.1	6.3	5.8	DB	6.7	42.7	1.3	1.2	5.8	43.6	5.0	44.3	4.3	45.0	3.4	45.9	(4)
(5)			WB	2.5	26.7	1.4	0.5	1.5	27.0	0.7	27.3	-0.1	27.6	-1.1	27.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.8	30.4	29.8	29.5	27.5	24.1	20.9	20.8	22.0	25.9	29.2	30.7	31.4	(6)	
	DBStd	4.50	2.44	2.15	1.95	2.25	2.80	2.80	2.69	2.52	2.27	2.32	1.99	2.26	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	20	0	0	0	0	1	8	9	2	0	0	0	0	(9)	
	CDD10.0	6141	632	555	604	525	436	328	334	372	477	595	622	662	(10)	
	CDD18.3	3119	373	322	346	275	179	86	85	116	227	337	372	403	(11)	
	CDH23.3	41171	5017	4227	4407	3274	1807	812	912	1493	3029	4850	5422	5921	(12)	
(13)	CDH26.7	23064	2850	2347	2412	1737	769	246	290	635	1708	3008	3384	3678	(13)	
(14)	Wind	WSAvg	2.9	2.8	2.7	2.7	2.9	2.9	2.8	2.9	3.0	3.1	3.1	3.0	(14)	
(15) Precipitation	PrecAvg	595	163	143	62	23	7	6	2	1	2	18	49	119	(15)	
	PrecMax	1361	626	359	356	187	63	50	31	7	17	108	123	613	(16)	
	PrecMin	193	8	24	5	0	0	0	0	0	0	0	14	16	(17)	
	PrecStd	251	128	95	73	44	13	12	6	2	5	25	32	118	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.9	40.7	40.3	37.2	35.2	32.2	32.6	34.9	38.5	40.7	41.5	42.1	(19)	
		MCWB	20.9	20.8	20.7	20.1	19.3	18.3	18.3	18.0	18.6	19.5	20.1	20.5	(20)	
	2%	DB	39.8	39.1	38.4	36.1	33.3	30.7	31.0	33.4	36.9	39.4	40.1	40.7	(21)	
		MCWB	21.8	21.0	21.1	19.8	18.8	17.7	17.1	17.3	17.9	19.4	19.8	20.7	(22)	
	5%	DB	38.4	37.7	37.1	35.2	32.2	29.5	29.7	31.8	35.6	38.3	39.2	39.5	(23)	
		MCWB	22.3	21.6	21.4	19.8	18.5	17.0	16.1	16.2	17.7	19.4	19.9	21.3	(24)	
	10%	DB	36.8	36.3	35.7	34.1	30.9	28.0	28.4	30.4	34.4	37.1	38.1	38.2	(25)	
		MCWB	22.6	22.1	21.6	19.4	17.9	16.2	15.4	15.4	17.4	19.2	20.1	21.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.2	26.4	25.7	24.9	23.2	19.9	20.7	20.6	22.1	23.6	25.1	25.7	(27)	
		MCDB	30.8	31.1	30.4	29.5	29.9	28.4	29.4	29.9	30.6	30.8	31.8	31.4	(28)	
	2%	WB	25.7	25.7	25.1	24.1	21.7	18.9	19.4	19.1	21.2	22.9	24.3	25.2	(29)	
		MCDB	30.2	30.3	29.9	29.2	28.7	28.6	26.4	28.6	30.1	31.6	31.2	30.8	(30)	
	5%	WB	25.4	25.3	24.7	23.3	20.7	18.1	17.9	17.8	20.3	22.2	23.8	24.8	(31)	
		MCDB	30.0	30.0	29.6	28.5	27.9	27.4	26.6	29.1	29.7	31.5	30.9	30.6	(32)	
	10%	WB	25.1	24.9	24.3	22.3	19.4	17.2	16.6	16.6	19.3	21.5	23.3	24.4	(33)	
		MCDB	29.8	29.7	29.2	28.6	28.3	26.3	26.4	28.1	30.4	31.4	30.9	30.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.4	10.8	11.0	12.3	12.7	13.2	14.1	15.8	16.1	15.2	13.7	11.9	(35)	
		MCDBR	13.8	14.0	13.7	14.3	13.8	14.6	15.8	18.0	18.3	16.7	15.7	14.5	(36)	
	5% WB	MCWBR	3.3	3.6	3.8	4.4	5.1	5.9	6.7	6.8	6.0	4.7	4.3	4.0	(37)	
		MCWBR	9.5	9.3	9.6	9.7	11.0	13.0	13.5	16.1	14.9	14.6	12.4	10.7	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.414	0.411	0.384	0.362	0.349	0.331	0.331	0.348	0.391	0.409	0.429	0.426	(40)	
		taud	2.432	2.434	2.500	2.505	2.474	2.487	2.463	2.392	2.301	2.287	2.299	2.358	(41)	
	Ebn at Noon	Ebn at Noon	932	924	927	909	884	882	893	908	904	915	912	921	(42)	
		Edh at Noon	124	122	110	102	98	93	98	112	132	140	140	133	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	6.32	6.48	6.28	5.83	5.05	4.68	5.01	5.86	6.77	7.25	7.16	6.80	(44)	
	RadStd	RadStd	0.68	0.61	0.56	0.44	0.27	0.29	0.18	0.19	0.30	0.44	0.37	0.64	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	N/A	N/A	N/A	+1.01	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page