

GEORGETOWN AP, Australia

WMO: 942740

Lat: 18.3039S

Lon: 143.5306E

Elev: 992

StdP: 14.18

Time Zone: 10.00 (E10)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	48.3	51.9	18.5	14.4	74.4	23.2	18.1	72.7	17.9	69.8	16.2	70.4	3.3	190	0.374

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	20.4	100.3	68.4	98.5	68.3	96.9	68.6	78.4	87.0	77.5	86.2	76.8	85.5	8.3	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.4	142.9	81.9	75.4	138.3	81.1	74.5	134.1	80.5	42.9	87.4	41.9	86.3	41.1	85.4	82.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.4	14.8	13.7	DB	41.7	103.9	4.6	2.3	38.4	105.6	35.7	107.0	33.1	108.3	29.7	110.0	(4)
(5)			WB	36.5	80.4	3.9	1.3	33.7	81.4	31.5	82.1	29.3	82.9	26.5	83.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	78.3	82.8	82.0	81.3	78.3	74.2	70.2	69.7	71.6	77.0	82.0	84.8	85.5	(6)	
	DBStd	6.55	3.16	2.62	2.51	3.17	4.37	4.59	4.50	4.34	3.84	3.52	3.06	3.28	(7)	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD65	31	0	0	0	0	2	13	11	5	0	0	0	0	(9)	
	CDD50	10315	1016	895	970	850	751	606	611	669	811	991	1045	1100	(10)	
	CDD65	4872	551	475	505	400	288	169	158	209	361	526	595	635	(11)	
	CDH74	55977	6225	5116	5321	4034	2456	1360	1409	2274	4463	6914	7994	8411	(12)	
	CDH80	26550	2885	2286	2335	1658	782	286	306	761	2190	3849	4536	4676	(13)	
(14) Wind	WSAvg	6.8	6.3	5.9	6.2	6.7	6.9	6.6	6.6	6.6	7.1	8.1	7.5	7.1	(14)	
(15) Precipitation	PrecAvg	32.0	9.0	8.3	4.7	1.1	0.4	0.2	0.2	0.1	0.2	0.7	2.2	4.5	(15)	
	PrecMax	80.6	30.7	20.7	17.9	8.6	2.3	3.0	1.5	2.0	1.6	5.5	12.4	12.0	(16)	
	PrecMin	14.5	1.6	0.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3	(17)	
	PrecStd	11.7	6.8	4.8	4.3	1.6	0.6	0.6	0.4	0.3	0.4	1.0	2.4	2.9	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	100.2	97.1	96.5	93.5	91.5	87.6	88.1	92.7	97.0	100.8	102.0	103.1	(19)	
		MCWB	72.5	72.3	71.6	70.2	67.7	67.0	65.4	65.4	64.0	66.0	68.3	68.4	(20)	
	2%	DB	96.7	94.7	93.8	91.3	88.6	85.1	85.3	89.4	94.6	98.6	99.7	100.6	(21)	
		MCWB	72.0	73.1	72.3	70.2	67.2	65.4	64.5	63.7	63.9	65.9	67.8	68.8	(22)	
	5%	DB	94.2	92.8	92.0	89.7	86.6	83.3	83.4	86.7	92.6	96.7	97.8	98.4	(23)	
		MCWB	72.7	73.7	72.7	69.5	66.8	64.5	63.4	62.4	63.9	65.9	67.8	69.8	(24)	
	10%	DB	91.6	90.9	90.1	88.0	84.5	81.4	81.4	84.3	90.5	94.6	96.1	96.2	(25)	
		MCWB	74.0	74.0	72.8	69.1	65.9	63.6	62.2	61.4	63.3	65.8	68.0	70.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.1	79.4	78.2	76.4	72.3	69.5	70.3	69.2	71.8	72.7	75.8	78.7	(27)	
		MCDB	88.5	87.3	87.2	85.0	84.0	83.0	79.2	85.0	87.0	87.0	87.4	88.1	(28)	
	2%	WB	78.7	78.2	77.0	75.0	70.9	68.1	67.5	67.3	69.9	71.1	74.5	76.9	(29)	
		MCDB	87.3	86.5	85.8	83.5	83.1	81.4	80.1	82.9	84.8	86.0	86.5	87.5	(30)	
	5%	WB	77.7	77.4	76.2	73.5	69.6	66.8	66.1	65.6	68.2	70.0	73.5	75.9	(31)	
		MCDB	86.0	85.9	84.8	83.7	81.3	79.7	79.2	81.5	83.7	86.5	86.1	86.6	(32)	
	10%	WB	76.8	76.5	75.4	72.0	68.2	65.5	64.7	63.9	66.5	68.9	72.5	74.9	(33)	
		MCDB	84.9	85.0	83.8	83.3	80.2	78.0	77.7	80.1	84.1	86.6	86.0	85.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	16.5	17.0	17.6	20.6	21.5	23.0	24.2	26.3	27.2	25.4	22.4	20.4	(35)	
		MCDBR	21.6	20.7	21.3	22.5	22.8	24.3	25.5	28.5	29.4	27.9	24.7	24.2	(36)	
	5% WB	MCWBR	5.7	6.2	6.3	7.1	7.9	9.3	9.2	10.5	9.7	8.4	7.2	6.6	(37)	
		MCWBR	15.2	15.7	15.9	16.7	18.2	20.3	20.8	23.3	22.6	22.6	19.3	17.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.385	0.384	0.360	0.341	0.322	0.312	0.303	0.318	0.356	0.388	0.408	0.411	(40)	
		taud	2.536	2.541	2.605	2.624	2.622	2.617	2.633	2.554	2.440	2.375	2.364	2.404	(41)	
	Ebn at Noon		304	301	302	296	291	288	294	299	298	297	295	297	(42)	
		Edh at Noon	36	35	31	29	27	26	26	30	36	41	42	40	(43)	
(44) All-Sky Solar Radiation	RadAvg		2041	2033	1961	1828	1588	1459	1589	1860	2158	2315	2345	2211	(44)	
	RadStd		154	175	159	125	82	109	63	79	81	129	147	193	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page