

GEORGETOWN, Australia

WMO: 942750

Lat: 18.300S

Lon: 143.550E

Elev: 295

StdP: 97.83

Time Zone: 10.00 (E10)

Period: 94-05

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.0	10.3	-2.3	3.2	19.0	-0.4	3.8	18.2	11.7	15.8	9.1	19.7	1.1	200	0.324

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	13.7	38.5	22.0	37.5	22.0	36.5	22.1	26.2	32.1	25.8	31.6	25.5	31.1	2.6	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.0	20.8	28.2	24.5	20.2	27.9	24.1	19.7	27.5	83.7	32.0	81.9	31.6	80.2	31.3	29.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
8.9	7.3	6.6	DB	4.5	40.6	2.3	1.3	2.8	41.5	1.5	42.3	0.2	43.0	-1.4	44.0
			WB	2.0	27.8	1.9	0.8	0.7	28.3	-0.4	28.7	-1.5	29.2	-2.9	29.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	25.9	28.9	28.5	27.6	26.3	23.6	21.2	20.4	21.6	25.4	28.4	29.6	29.6	(6)
	DBStd	3.87	1.83	1.43	1.39	1.70	2.37	2.55	2.42	2.51	2.21	1.89	1.74	2.01	(7)
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD18.3	24	0	0	0	0	1	9	11	4	0	0	0	0	(9)
	CDD10.0	5807	586	518	544	490	422	337	321	361	462	569	589	608	(10)
	CDD18.3	2789	327	285	286	240	164	95	73	107	212	311	339	350	(11)
	CDH23.3	32152	3809	3208	3109	2519	1447	741	703	1098	2560	3957	4577	4424	(12)
	CDH26.7	15615	1891	1468	1395	1112	481	158	136	327	1318	2236	2687	2408	(13)
(14) Wind	WSAvg	2.1	1.8	1.7	2.0	2.2	2.0	2.1	2.0	2.2	2.4	2.3	2.1	2.0	(14)
(15) Precipitation	PrecAvg	812	229	210	120	28	10	6	4	3	4	17	56	115	(15)
	PrecMax	2046	779	527	455	219	59	76	38	50	41	140	314	306	(16)
	PrecMin	368	41	21	0	0	0	0	0	0	0	0	0	8	(17)
	PrecStd	297	173	121	109	41	15	14	10	8	9	26	61	74	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.3	36.5	35.3	35.1	32.6	31.0	30.8	33.0	36.7	39.2	39.9	39.2	(19)
		MCWB	23.2	24.1	23.8	22.7	21.6	19.6	19.0	19.3	19.5	20.8	21.5	22.9	(20)
	2%	DB	37.1	35.5	34.1	33.9	31.5	29.6	29.3	31.1	35.3	37.8	38.4	38.1	(21)
		MCWB	23.4	24.3	23.6	22.2	20.9	19.5	18.2	19.2	19.3	21.1	21.6	22.7	(22)
	5%	DB	35.4	34.6	33.3	32.8	30.5	28.5	28.1	29.9	34.1	36.6	37.4	36.9	(23)
		MCWB	23.9	24.3	23.3	21.6	20.3	18.9	17.5	18.4	19.3	21.1	21.5	23.1	(24)
	10%	DB	34.1	33.4	32.5	31.9	29.5	27.4	27.1	28.8	33.0	35.4	36.2	35.6	(25)
		MCWB	24.1	24.4	22.9	21.2	19.8	18.3	17.0	17.6	19.3	20.8	21.6	23.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.7	26.9	26.7	25.1	23.8	21.7	20.5	21.2	23.4	25.8	25.9	26.1	(27)
		MCDB	33.2	32.5	32.0	30.3	30.8	28.5	28.7	29.5	31.8	34.3	33.9	33.0	(28)
	2%	WB	26.1	26.2	25.7	24.2	22.5	20.6	19.5	20.2	22.0	23.7	24.9	25.6	(29)
		MCDB	32.3	31.4	30.8	30.0	28.9	27.4	27.5	29.1	31.6	32.3	32.3	32.4	(30)
	5%	WB	25.7	25.8	25.2	23.7	21.7	19.8	18.6	19.4	21.2	23.0	24.2	25.1	(31)
		MCDB	31.5	30.9	30.0	29.7	28.2	26.6	26.4	28.2	30.5	31.4	32.0	31.8	(32)
	10%	WB	25.2	25.5	24.6	22.9	21.0	19.1	17.9	18.7	20.4	22.3	23.7	24.7	(33)
		MCDB	30.8	30.4	29.3	29.1	27.6	25.8	25.4	27.1	29.7	31.3	31.7	31.1	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	10.1	9.4	10.4	11.4	12.2	12.3	14.2	14.6	15.8	14.4	13.7	11.2	(35)
		MCDBR	12.4	11.6	11.7	12.8	13.2	13.5	15.2	15.7	17.0	16.3	15.5	13.5	(36)
	5% WB	MCWBR	3.3	3.4	3.6	3.9	4.9	5.5	6.4	6.3	5.9	5.5	4.7	3.6	(37)
		MCDWR	9.7	9.1	9.3	10.3	10.3	11.6	13.4	12.7	13.7	12.9	12.0	10.3	(38)
(40) Clear-Sky Solar Irradiance	taub		0.385	0.384	0.360	0.342	0.322	0.312	0.303	0.319	0.356	0.388	0.409	0.411	(40)
		taud	2.535	2.540	2.604	2.623	2.622	2.616	2.632	2.554	2.439	2.374	2.364	2.402	(41)
	Ebn at Noon		959	950	950	932	916	908	928	941	939	935	930	934	(42)
		Edh at Noon	112	110	99	91	85	82	83	96	115	128	132	127	(43)
(44) All-Sky Solar Radiation	RadAvg		6.43	6.41	6.18	5.76	5.00	4.59	5.00	5.86	6.80	7.29	7.39	6.97	(44)
	RadStd		0.48	0.55	0.50	0.39	0.26	0.35	0.20	0.25	0.26	0.41	0.47	0.61	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page