

PALMERVILLE, Australia

WMO: 942760

Lat: 16.001S

Lon: 144.076E

Elev: 672

StdP: 14.34

Time Zone: 10.00 (E10)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	52.6	55.5	37.1	33.3	80.8	41.4	39.3	77.5	13.9	82.0	12.3	80.8	2.0	100	0.315

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	20.9	98.8	70.5	97.0	70.6	95.3	70.6	79.2	85.7	78.4	85.0	77.8	84.2	7.7	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.1	149.4	80.3	77.1	144.8	79.7	76.4	141.1	79.4	43.4	85.9	42.6	85.3	41.9	84.3	85.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation	n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Max
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(p)
(4) 13.6	12.0	11.0		47.2	102.2	3.7	1.7	44.5	103.5	42.3	104.4	40.2	105.4	37.5	106.6	
(5)			DB	45.2	80.9	4.0	1.6	42.3	82.0	40.0	83.0	37.8	83.8	34.9	85.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	78.2	82.1	81.6	80.3	77.8	75.1	72.9	71.6	72.8	76.5	80.8	83.0	84.3	(6)
	DBStd	5.10	2.40	2.02	1.97	2.24	3.02	3.51	3.50	3.42	3.35	3.12	2.52	2.70	(7)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD65	3	0	0	0	0	0	2	1	0	0	0	0	0	(9)
	CDD50	10296	996	885	938	833	778	686	671	705	796	954	990	1064	(10)
	CDD65	4825	531	465	473	383	313	238	207	241	346	489	540	599	(11)
	CDH74	51300	5421	4421	4255	3414	2695	2017	2051	2759	4239	5988	6658	7382	(12)
	CDH80	22856	2257	1681	1567	1258	919	610	607	1051	2110	3268	3656	3872	(13)
(14) Wind	WSAvg	4.9	4.8	4.3	4.0	4.1	4.1	4.3	4.6	4.9	5.6	6.1	6.0	5.5	(14)
(15) Precipitation	PrecAvg	41.3	9.9	10.6	7.0	1.6	0.6	0.4	0.1	0.1	0.2	0.7	2.7	6.2	(15)
	PrecMax	62.8	32.0	21.4	24.1	4.9	2.3	3.7	1.0	0.6	2.8	3.0	12.5	13.0	(16)
	PrecMin	17.6	1.2	0.4	0.7	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.7	0.7	(17)
	PrecStd	12.3	6.3	5.3	4.7	1.3	0.7	0.7	0.3	0.2	0.5	0.7	2.7	3.0	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	97.6	94.5	92.6	91.4	91.2	89.5	89.4	92.2	96.7	100.3	100.5	101.3	(19)
		MCWB	73.7	74.6	75.9	72.8	69.9	69.7	68.1	67.4	65.9	67.5	69.3	72.3	(20)
	2%	DB	94.3	92.0	90.8	89.6	88.9	87.3	87.3	89.8	94.3	97.4	98.1	98.8	(21)
		MCWB	74.2	76.1	75.6	72.6	70.1	69.1	67.7	66.6	66.5	68.6	69.8	72.2	(22)
	5%	DB	92.0	90.5	89.3	88.2	87.1	85.7	85.6	87.8	92.3	95.4	96.3	96.9	(23)
		MCWB	74.8	76.1	75.5	72.7	70.3	68.6	66.8	65.8	66.6	68.9	70.3	72.2	(24)
	10%	DB	89.9	88.8	87.7	86.7	85.3	83.9	83.6	85.8	90.3	93.5	94.5	94.8	(25)
		MCWB	75.4	76.1	75.3	72.5	69.9	67.8	65.9	65.0	66.4	69.0	70.3	72.5	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.6	80.2	81.3	78.4	75.5	73.7	72.5	71.9	73.5	74.6	76.8	79.0	(27)
		MCDB	86.1	86.0	85.6	84.3	83.1	81.6	82.9	84.3	85.8	86.5	85.6	90.5	(28)
	2%	WB	78.6	79.0	79.3	76.8	74.2	71.9	70.5	70.1	71.8	73.2	75.6	77.4	(29)
		MCDB	85.4	85.6	84.9	83.4	82.4	81.6	82.0	83.6	85.0	85.6	85.0	86.7	(30)
	5%	WB	77.9	78.2	78.3	75.8	73.0	70.7	69.0	68.6	70.2	72.4	74.7	76.8	(31)
		MCDB	84.4	84.7	83.9	82.4	81.8	81.1	81.1	82.0	84.8	85.6	85.0	85.3	(32)
	10%	WB	77.3	77.6	77.4	74.9	71.8	69.5	67.6	67.1	68.7	71.5	73.7	76.0	(33)
		MCDB	83.4	83.7	82.9	81.6	81.0	80.4	79.9	81.1	84.2	85.6	85.5	84.7	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	15.8	14.8	15.8	19.8	22.2	23.4	25.9	28.0	29.5	26.9	24.7	20.9	(35)
		MCDBR	19.8	17.8	18.7	22.0	24.1	24.7	26.9	29.8	31.7	29.7	27.4	25.0	(36)
	5% WB	MCWBR	4.7	5.0	5.7	7.3	7.9	8.2	8.9	9.2	8.3	6.6	5.5	5.0	(37)
		MCWBR	14.6	14.3	14.4	16.8	19.2	20.7	23.4	24.4	25.1	23.4	20.2	17.0	(38)
(40) Clear-Sky Solar Irradiance	taub		0.394	0.386	0.370	0.358	0.342	0.335	0.323	0.334	0.366	0.390	0.404	0.408	(40)
		taud	2.527	2.560	2.606	2.606	2.612	2.615	2.635	2.578	2.463	2.420	2.413	2.440	(41)
	Ebn at Noon		302	301	299	292	286	283	290	295	296	296	296	297	(42)
		Edh at Noon	36	34	32	30	28	27	27	30	36	39	40	39	(43)
(44) All-Sky Solar Radiation	RadAvg		1893	1854	1809	1748	1559	1433	1546	1801	2097	2247	2259	2092	(44)
	RadStd		145	198	123	127	83	92	69	84	73	129	145	209	(45)

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page