

PALMERVILLE, Australia

WMO: 942760

Lat: 16.001S

Lon: 144.076E

Elev: 205

StdP: 98.89

Time Zone: 10.00 (E10)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.5	13.1	2.8	4.8	27.1	5.2	5.6	25.3	6.2	27.8	5.5	27.1	0.9	100	0.315

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	11.6	37.1	21.4	36.1	21.5	35.2	21.4	26.2	29.9	25.8	29.4	25.4	29.0	3.4	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.6	21.3	26.8	25.1	20.7	26.5	24.6	20.2	26.3	83.2	30.0	81.2	29.6	79.5	29.1	29.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.1	5.4	4.9	DB	8.4	39.0	2.1	0.9	7.0	39.7	5.7	40.2	4.6	40.8	3.1	41.4	(4)
(5)			WB	7.3	27.2	2.2	0.9	5.7	27.8	4.4	28.3	3.2	28.8	1.6	29.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.7	27.9	27.6	26.8	25.4	23.9	22.7	22.0	22.6	24.7	27.1	28.3	29.1
	DBStd	2.83	1.33	1.12	1.10	1.24	1.68	1.95	1.94	1.90	1.86	1.73	1.40	1.50
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	2	0	0	0	0	0	1	1	0	0	0	0	0
	CDD10.0	5720	553	492	521	463	432	381	373	392	442	530	550	591
	CDD18.3	2681	295	258	263	213	174	132	115	134	192	272	300	333
	CDH23.3	28500	3012	2456	2364	1897	1497	1121	1139	1533	2355	3327	3699	4101
CDH26.7	12698	1254	934	871	699	511	339	337	584	1172	1816	2031	2151	
Wind	WSAvg	2.2	2.1	1.9	1.8	1.9	1.8	1.9	2.1	2.2	2.5	2.7	2.7	2.5
Precipitation	PrecAvg	1048	252	270	177	41	15	11	3	2	5	17	69	157
	PrecMax	1595	813	543	612	125	59	94	26	15	71	76	317	329
	PrecMin	448	31	10	17	0	0	0	0	0	0	0	2	18
	PrecStd	312	161	134	119	32	18	19	7	4	13	18	68	75
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.4	34.7	33.7	33.0	32.9	32.0	31.9	33.5	35.9	38.0	38.0	38.5
		MCWB	23.1	23.7	24.4	22.7	21.1	20.9	20.0	19.7	18.9	19.7	20.7	22.4
	2%	DB	34.6	33.4	32.7	32.0	31.6	30.7	30.7	32.1	34.6	36.4	36.7	37.1
		MCWB	23.4	24.5	24.2	22.5	21.2	20.6	19.8	19.2	19.2	20.3	21.0	22.3
	5%	DB	33.3	32.5	31.8	31.2	30.6	29.8	29.8	31.0	33.5	35.2	35.7	36.1
		MCWB	23.8	24.5	24.2	22.6	21.3	20.3	19.3	18.8	19.2	20.5	21.3	22.3
	10%	DB	32.2	31.5	31.0	30.4	29.6	28.8	28.7	29.9	32.4	34.1	34.7	34.9
		MCWB	24.1	24.5	24.0	22.5	21.1	19.9	18.9	18.3	19.1	20.5	21.3	22.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.4	26.8	27.4	25.8	24.2	23.2	22.5	22.2	23.1	23.7	24.9	26.1
		MCDB	30.1	30.0	29.8	29.1	28.4	27.6	28.3	29.0	29.9	30.3	29.8	32.5
	2%	WB	25.9	26.1	26.3	24.9	23.4	22.2	21.4	21.2	22.1	22.9	24.2	25.2
		MCDB	29.6	29.8	29.4	28.6	28.0	27.5	27.8	28.7	29.4	29.8	29.4	30.4
	5%	WB	25.5	25.7	25.7	24.4	22.8	21.5	20.5	20.3	21.2	22.4	23.7	24.9
		MCDB	29.1	29.3	28.8	28.0	27.7	27.3	27.3	27.8	29.3	29.8	29.4	29.6
	10%	WB	25.1	25.3	25.2	23.8	22.1	20.8	19.8	19.5	20.4	22.0	23.2	24.5
		MCDB	28.6	28.7	28.3	27.5	27.2	26.9	26.6	27.3	29.0	29.8	29.7	29.3
Mean Daily Temperature Range	5% DB	MDBR	8.8	8.2	8.8	11.0	12.3	13.0	14.4	15.6	16.4	15.0	13.7	11.6
		MCDBR	11.0	9.9	10.4	12.2	13.4	13.7	14.9	16.5	17.6	16.5	15.2	13.9
		MCWBR	2.6	2.8	3.2	4.0	4.4	4.6	4.9	5.1	4.6	3.7	3.1	2.8
	5% WB	MCDBR	8.1	8.0	8.0	9.3	10.7	11.5	13.0	13.5	13.9	13.0	11.2	9.4
		MCWBR	2.6	2.8	3.1	3.6	4.2	4.6	4.9	4.5	3.8	3.3	2.6	2.5
Clear-Sky Solar Irradiance	taub	0.394	0.386	0.370	0.358	0.342	0.335	0.323	0.334	0.366	0.390	0.404	0.408	
	taud	2.527	2.560	2.606	2.606	2.612	2.615	2.635	2.578	2.463	2.420	2.413	2.440	
	Ebn at Noon	951	949	944	920	902	892	914	931	932	934	934	936	
	Edh at Noon	113	108	100	94	88	84	84	95	113	123	125	122	
All-Sky Solar Radiation	RadAvg	5.97	5.85	5.70	5.51	4.91	4.52	4.88	5.68	6.61	7.08	7.12	6.59	
	RadStd	0.46	0.62	0.39	0.40	0.26	0.29	0.22	0.26	0.23	0.41	0.46	0.66	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page