

LIHOU REEF, Australia

WMO: 942960

Lat: 17.117S

Lon: 152.000E

Elev: 30

StdP: 14.68

Time Zone: 10.00 (E10)

Period: 94-12

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	69.6	70.8	N/A	N/A	N/A	N/A	N/A	N/A	33.0	71.8	31.3	73.0	17.7	150	0.626

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	3.5	86.0	N/A	85.1	N/A	84.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	8.1	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 30.9	29.0	27.3	DB	67.1	87.5	1.8	1.1	65.7	88.3	64.7	89.0	63.6	89.6	62.3	90.5	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	77.8	81.3	81.9	81.0	79.3	77.3	75.3	73.6	73.5	74.7	76.7	78.6	80.8	(6)	
	DBStd	3.38	1.82	1.48	1.80	1.46	1.47	1.77	1.58	1.40	1.40	1.76	1.74	1.98	(7)	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD50	10151	970	894	961	879	847	759	732	729	742	826	859	953	(10)	
	CDD65	4676	505	474	496	429	382	309	267	264	292	361	409	488	(11)	
	CDH74	36478	5586	5531	5415	4022	2618	1268	423	306	766	2052	3424	5067	(12)	
	CDH80	5563	1322	1567	1188	297	26	1	0	0	1	22	173	966	(13)	
(14) Wind	WSAvg	16.1	12.9	13.0	16.1	18.7	17.5	19.1	18.2	17.6	16.3	15.6	15.2	12.6	(14)	
(15) Precipitation	PrecAvg	45.1	7.2	8.0	8.6	5.3	2.9	2.2	1.4	1.3	0.9	1.4	1.9	4.1	(15)	
	PrecMax	75.1	19.6	18.5	28.6	16.8	13.5	6.8	4.3	4.2	2.3	9.6	12.8	12.5	(16)	
	PrecMin	19.6	0.4	1.8	1.4	0.6	0.2	0.1	0.2	0.2	0.1	0.1	0.0	0.6	(17)	
	PrecStd	13.4	5.0	4.9	6.1	4.4	2.7	1.4	1.1	1.0	0.7	2.0	2.5	3.1	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	87.1	87.4	86.2	83.6	81.8	79.6	78.4	77.4	79.9	81.8	84.1	86.5	(19)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(20)	
	2%	DB	85.5	86.1	85.0	82.6	80.8	78.6	77.4	76.8	78.6	80.6	82.7	85.0	(21)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(22)	
	5%	DB	84.7	85.1	84.3	81.9	80.1	78.1	76.7	76.1	77.4	79.8	81.8	84.0	(23)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(24)	
	10%	DB	83.9	84.3	83.6	81.5	79.5	77.6	76.1	75.5	76.7	79.1	80.9	83.3	(25)	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(27)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(28)	
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(29)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(30)	
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(31)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(32)	
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(33)	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	3.3	3.5	3.2	2.5	2.1	2.5	2.3	2.3	2.2	2.6	2.9	3.2	(35)	
		MCDBR	4.1	4.4	4.0	3.0	2.6	2.8	2.8	2.6	2.8	3.5	3.7	3.9	(36)	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(37)	
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(38)	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.387	0.387	0.394	0.383	0.369	0.372	0.357	0.352	0.367	0.382	0.384	0.385	(40)	
	taud		2.611	2.624	2.593	2.602	2.601	2.591	2.599	2.614	2.544	2.521	2.554	2.585	(41)	
	Ebn at Noon		304	300	292	284	277	270	278	289	295	298	303	304	(42)	
	Edh at Noon		33	32	32	30	28	27	28	29	33	35	35	34	(43)	
(44) All-Sky Solar Radiation	RadAvg		2139	2048	1824	1661	1454	1293	1406	1682	2019	2217	2286	2305	(44)	
	RadStd		186	194	143	120	95	89	69	100	72	117	182	156	(45)	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page