

LIHOU REEF, Australia

WMO: 942960

Lat: 17.117S

Lon: 152.000E

Elev: 9

StdP: 101.22

Time Zone: 10.00 (E10)

Period: 94-12

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	20.9	21.5	N/A	N/A	N/A	N/A	N/A	N/A	14.7	22.1	14.0	22.8	7.9	150	0.626

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	1.9	30.0	N/A	29.5	N/A	29.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	3.6	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.8	13.0	12.2	DB	19.5	30.8	1.0	0.6	18.7	31.3	18.1	31.7	17.6	32.0	16.8	32.5	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.5	27.4	27.7	27.2	26.3	25.2	24.1	23.1	23.1	23.7	24.8	25.9	27.1
	DBStd	1.88	1.01	0.82	1.00	0.81	0.82	0.98	0.88	0.78	0.78	0.98	0.97	1.10
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	5639	539	497	534	488	471	422	407	405	412	459	477	529
	CDD18.3	2598	281	263	276	238	212	172	148	147	162	201	227	271
	CDH23.3	20266	3103	3073	3008	2234	1454	704	235	170	426	1140	1902	2815
	CDH26.7	3091	734	871	660	165	14	0	0	0	1	12	96	537
Wind	WSAvg	7.2	5.8	5.8	7.2	8.4	7.8	8.5	8.2	7.9	7.3	7.0	6.8	5.6
Precipitation	PrecAvg	1146	184	202	219	135	73	56	36	32	22	35	49	105
	PrecMax	1907	499	469	726	426	343	173	110	106	58	245	325	318
	PrecMin	498	10	46	35	14	4	2	4	4	2	3	1	14
	PrecStd	341	128	125	155	111	68	36	28	26	17	51	63	79
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.6	30.8	30.1	28.7	27.6	26.4	25.8	25.2	26.6	27.7	28.9	30.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	29.7	30.1	29.4	28.1	27.1	25.9	25.2	24.9	25.9	27.0	28.2	29.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	29.3	29.5	29.0	27.7	26.7	25.6	24.8	24.5	25.2	26.6	27.7	28.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	28.8	29.1	28.7	27.5	26.4	25.3	24.5	24.2	24.8	26.2	27.2	28.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	1.8	1.9	1.8	1.4	1.2	1.4	1.3	1.3	1.2	1.5	1.6	1.8
		MCDBR	2.3	2.4	2.2	1.7	1.5	1.5	1.6	1.5	1.6	2.0	2.1	2.2
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.387	0.387	0.394	0.383	0.369	0.372	0.357	0.352	0.367	0.382	0.384	0.385
	taud		2.611	2.624	2.593	2.602	2.601	2.591	2.599	2.614	2.544	2.521	2.554	2.585
	Ebn at Noon		957	947	920	894	872	851	875	911	931	941	954	958
	Edh at Noon		104	101	101	94	88	86	87	91	104	111	109	106
All-Sky Solar Radiation	RadAvg		6.74	6.46	5.75	5.24	4.58	4.08	4.43	5.30	6.37	6.99	7.21	7.27
	RadStd		0.59	0.61	0.45	0.38	0.30	0.28	0.22	0.31	0.23	0.37	0.57	0.49

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page