

THEVENARD ISLAND, Australia

WMO: 943030

Lat: 21.461S

Lon: 115.020E

Elev: 20

StdP: 14.69

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	61.6	63.0	39.9	36.3	70.0	42.3	39.8	70.1	39.0	68.7	32.1	69.0	13.3	170	0.554

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	11.3	96.1	76.0	93.8	76.2	91.9	76.4	82.8	86.1	81.8	85.9	80.9	86.0	11.2	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
82.1	167.4	84.2	80.9	160.6	84.0	79.7	154.2	83.8	46.9	86.1	45.7	85.7	44.7	85.8	90.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 36.3	28.7	24.8	57.2	104.1	2.4	2.5	55.5	105.9	54.1	107.3	52.7	108.7	50.9	110.5		
(5)			49.4	84.5	1.3	2.5	48.5	86.3	47.7	87.8	47.0	89.1	46.1	91.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	78.0	84.2	85.2	85.6	82.6	76.5	71.5	69.8	70.9	73.1	76.8	79.0	81.5
	DBStd	6.32	3.37	3.26	2.92	3.08	3.20	2.89	2.40	2.45	2.66	3.33	3.16	3.57
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDD50	10225	1060	985	1103	977	821	646	615	648	692	829	871	978
	CDD65	4752	595	565	638	527	356	196	152	183	242	364	421	513
	CDH74	43229	7093	7057	8078	5764	2221	440	184	442	952	2395	3439	5164
	CDH80	16081	3035	3234	3777	2108	394	10	3	28	123	570	958	1841
Wind	WSAvg	13.9	15.1	14.6	13.0	12.4	12.8	13.2	12.5	12.5	14.6	15.5	15.4	15.1
Precipitation	PrecAvg	11.6	1.7	3.0	2.3	0.8	1.1	1.3	0.6	0.2	0.0	0.0	0.1	0.5
	PrecMax	21.9	5.6	14.5	10.9	3.6	7.2	4.8	3.9	1.3	0.4	0.5	0.6	2.7
	PrecMin	3.9	0.0	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	5.4	1.8	3.7	2.9	1.0	1.6	1.5	1.0	0.3	0.1	0.1	0.1	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	98.9	98.7	99.1	95.4	88.6	81.4	79.8	83.3	87.3	92.1	93.7	96.6
		MCWB	76.7	77.1	75.2	73.0	69.3	67.6	65.2	63.9	66.4	68.9	69.7	75.4
	2%	DB	94.7	95.2	95.0	92.1	85.8	79.5	77.4	79.9	83.1	87.7	89.6	92.5
		MCWB	77.2	77.9	76.6	73.0	69.2	66.5	65.4	64.8	66.2	69.3	71.4	74.6
	5%	DB	91.9	92.7	92.7	90.1	83.9	78.1	76.0	78.0	80.7	85.2	87.1	90.1
		MCWB	77.6	78.1	77.1	73.3	69.5	66.1	64.6	64.4	66.2	69.7	72.3	75.4
	10%	DB	89.9	90.7	90.7	88.2	82.1	76.6	74.6	76.5	78.9	83.1	85.0	87.7
		MCWB	77.9	78.3	77.1	73.6	69.0	65.8	63.7	64.0	65.9	69.6	72.1	75.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	83.4	84.1	84.3	82.6	78.6	75.8	73.8	72.5	73.6	76.0	78.8	82.5
		MCDB	87.1	87.0	86.3	84.9	81.1	77.5	75.7	74.7	76.8	79.9	81.7	86.1
	2%	WB	81.9	82.7	82.6	80.3	75.5	73.6	70.5	70.2	71.2	74.2	77.1	80.1
		MCDB	85.8	86.8	85.4	84.1	79.5	75.8	73.3	73.5	76.2	79.6	81.5	85.3
	5%	WB	80.9	81.8	81.3	78.4	74.2	71.8	68.6	68.7	69.9	73.0	75.9	78.8
		MCDB	85.9	86.5	85.9	83.6	79.0	74.5	72.2	73.0	75.4	79.7	81.4	84.1
	10%	WB	80.0	80.9	80.1	77.0	72.8	69.8	67.0	67.4	68.7	71.8	74.6	77.6
		MCDB	85.8	86.2	86.2	83.3	78.4	74.0	71.4	72.5	74.9	79.6	81.1	83.8
Mean Daily Temperature Range	5% DB	MDBR	11.2	10.9	11.3	11.6	10.8	9.8	10.5	12.6	13.2	13.4	12.8	12.0
		MCDBR	13.8	13.4	13.3	13.6	12.7	10.9	11.7	14.3	15.2	15.4	14.8	14.7
		MCWBR	6.1	6.4	6.6	7.8	7.7	7.2	7.1	7.5	8.1	7.7	7.2	6.9
	5% WB	MCDBR	11.3	11.1	11.3	11.5	10.8	8.3	9.7	12.7	13.4	13.5	12.1	12.1
		MCWBR	5.3	5.9	6.4	7.6	7.6	7.2	7.3	8.0	7.6	7.3	6.5	6.3
Clear-Sky Solar Irradiance	taub	0.396	0.395	0.374	0.353	0.331	0.322	0.315	0.316	0.330	0.346	0.352	0.369	
	taud	2.527	2.549	2.596	2.618	2.624	2.631	2.629	2.590	2.543	2.519	2.535	2.552	
	Ebn at Noon	301	298	296	290	285	281	287	297	305	309	312	310	
	Edh at Noon	36	34	31	29	26	25	26	29	33	35	35	35	
All-Sky Solar Radiation	RadAvg	2443	2316	2046	1722	1439	1291	1393	1738	2079	2371	2553	2585	
	RadStd	117	132	126	101	106	91	104	57	70	62	67	101	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	+0.56	N/A	-1.84	N/A	N/A	N/A	N/A	N/A	+275	+288

Nomenclature: See separate page