

LEGENDRE ISLAND, Australia

WMO: 943070

Lat: 20.358S

Lon: 116.843E

Elev: 30

StdP: 100.97

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.0	17.8	4.8	5.4	21.5	6.4	6.0	21.8	15.5	19.2	14.8	19.2	6.0	150	0.559

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	5.1	34.7	26.2	33.6	26.5	32.8	26.5	30.2	31.2	29.6	30.8	29.2	30.4	4.6	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
30.0	27.4	30.8	29.4	26.4	30.2	28.9	25.6	29.8	101.3	31.3	98.5	30.9	96.0	30.4	32.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
14.3	12.7	11.5	DB	15.5	37.5	0.8	1.0	14.9	38.2	14.4	38.8	14.0	39.4	13.4	40.2
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.0	29.1	29.5	30.0	28.4	25.0	22.1	21.2	21.9	23.7	26.0	27.2	28.2
	DBStd	3.42	1.33	1.40	1.54	1.29	1.87	1.70	1.47	1.32	1.36	1.77	1.70	1.64
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDD10.0	5840	592	547	619	553	465	363	347	368	409	496	517	563
	CDD18.3	2799	334	313	361	303	207	113	89	109	159	237	267	305
	CDH23.3	27344	4094	3997	4755	3604	1557	329	143	249	706	1901	2614	3394
	CDH26.7	10058	1702	1798	2309	1359	273	8	2	8	75	480	811	1232
(14) Wind	WSAvg	6.1	6.6	6.3	5.6	4.9	6.0	6.7	6.0	5.6	5.9	6.3	7.0	6.8
(15) Precipitation	PrecAvg	297	51	86	45	20	29	37	10	3	1	1	1	13
	PrecMax	715	231	349	202	113	133	158	70	24	18	13	33	103
	PrecMin	77	1	1	0	0	3	1	0	0	0	0	0	0
	PrecStd	165	62	100	61	29	35	45	17	6	4	3	6	23
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.3	35.7	36.4	34.1	31.2	27.7	26.7	27.6	30.2	33.5	34.2	34.9
		MCWB	25.6	26.4	25.1	25.4	22.9	22.1	18.8	20.4	20.3	22.2	24.4	25.8
	2%	DB	33.2	33.9	34.8	32.8	30.0	26.7	25.6	26.3	28.4	31.5	32.6	33.0
		MCWB	27.9	27.5	26.6	25.0	22.1	20.8	19.1	19.3	20.5	22.2	24.2	26.1
	5%	DB	32.4	32.9	33.7	31.9	29.1	25.9	24.8	25.4	27.4	30.2	31.3	31.9
		MCWB	27.5	27.6	26.9	24.7	22.0	20.2	18.9	18.8	20.3	22.6	24.4	26.6
	10%	DB	31.6	32.1	32.7	31.1	28.2	25.1	24.1	24.7	26.5	29.1	30.2	31.0
		MCWB	27.1	27.4	27.2	24.6	21.8	19.5	18.2	18.5	19.9	22.7	24.5	26.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	30.2	30.9	30.5	30.9	26.5	26.2	24.8	23.9	24.9	26.8	29.0	31.7
		MCDB	31.4	31.7	31.4	32.2	27.7	26.5	25.0	25.0	26.3	28.3	29.9	32.4
	2%	WB	29.6	29.7	29.8	29.9	25.6	24.9	22.9	22.7	23.7	26.0	27.9	29.7
		MCDB	30.8	30.9	30.8	31.0	26.8	25.5	23.5	24.0	25.3	27.9	29.2	30.9
	5%	WB	29.1	29.2	29.3	28.7	25.0	23.2	21.7	21.9	23.0	25.4	27.0	28.6
		MCDB	30.1	30.5	30.6	30.1	26.9	24.5	23.1	23.5	24.7	27.5	28.7	30.2
	10%	WB	28.6	28.9	28.9	27.8	24.4	22.1	20.6	21.1	22.3	24.7	26.2	27.8
		MCDB	29.8	30.3	30.4	29.5	26.7	24.1	22.6	23.0	24.5	27.1	28.3	29.8
(35) Mean Daily Temperature Range	5% DB	MDBR	4.7	4.7	5.1	5.3	5.0	4.7	5.2	5.7	5.8	5.8	5.5	4.9
		MCDBR	5.5	5.7	6.4	6.4	5.9	5.4	6.1	6.6	6.8	7.1	6.7	5.9
	5% WB	MCWBR	2.7	3.2	3.8	4.0	3.9	3.6	4.5	4.0	3.8	3.5	3.2	3.4
		MCWBR	4.5	5.3	5.6	5.7	5.1	4.3	5.2	5.9	6.0	5.9	5.1	4.7
(40) Clear-Sky Solar Irradiance	taub		0.403	0.395	0.377	0.352	0.336	0.324	0.314	0.313	0.334	0.357	0.361	0.377
		taud	2.527	2.566	2.609	2.637	2.619	2.639	2.648	2.606	2.549	2.507	2.535	2.559
	Ebn at Noon		942	938	932	917	895	888	910	943	959	963	976	967
		Edh at Noon	113	107	98	89	84	79	81	90	103	112	111	109
(44) All-Sky Solar Radiation	RadAvg		7.45	7.14	6.39	5.59	4.65	4.22	4.59	5.66	6.66	7.54	8.03	8.00
	RadStd		0.46	0.50	0.47	0.31	0.36	0.30	0.29	0.15	0.25	0.14	0.17	0.31

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)		+0.46	N/A	N/A	N/A	+0.48	+0.56	N/A	N/A	N/A	+158

Nomenclature: See separate page