

PARABURDOO, Australia

WMO: 943160

Lat: 23.1725S

Lon: 117.7494E

Elev: 424

StdP: 96.33

Time Zone: 8.00 (E08)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.6	9.0	-12.6	1.3	25.6	-10.6	1.6	24.9	8.7	18.7	8.1	18.9	2.8	60	0.455

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.7	42.9	19.0	41.7	18.8	40.5	18.7	24.7	28.2	24.1	28.7	23.6	29.1	4.9	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.2	20.1	25.6	23.2	18.9	25.7	22.2	17.8	26.1	78.1	27.9	75.5	28.2	73.2	29.1	28.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.3	8.3	7.5	4.8	44.7	1.6	1.0	3.6	45.4	2.7	46.0	1.8	46.6	0.7	47.3		
			0.9	25.7	1.1	1.1	0.1	26.5	-0.6	27.2	-1.2	27.8	-2.1	28.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.6	32.7	31.3	29.8	26.5	21.7	18.0	17.4	19.1	22.4	26.9	29.9	32.3
	DBStd	6.09	3.00	2.89	2.81	2.62	2.78	2.54	2.36	2.40	2.55	2.70	2.65	2.54
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	108	0	0	0	0	4	36	47	18	2	0	0	0
	CDD10.0	5711	704	596	613	496	363	241	228	283	372	524	598	692
	CDD18.3	2778	446	363	355	246	109	27	17	43	124	266	348	434
	CDH23.3	39974	6980	5346	4931	2910	1068	228	239	641	1664	3785	5218	6964
	CDH26.7	24085	4692	3368	2923	1491	379	29	32	177	760	2210	3313	4709
Wind	WSAvg	3.8	4.1	3.9	3.8	3.5	3.6	3.6	3.6	3.7	3.8	3.9	4.1	4.1
Precipitation	PrecAvg	267	50	62	33	24	25	23	12	7	3	3	7	25
	PrecMax	457	201	301	135	152	119	107	88	47	45	20	30	181
	PrecMin	57	0	3	0	0	0	0	0	0	0	0	0	0
	PrecStd	102	54	63	39	32	32	27	18	13	8	6	8	35
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.3	43.8	41.2	38.5	33.9	29.1	29.2	32.1	35.6	39.9	41.5	44.2
		MCWB	19.0	18.7	19.3	18.0	16.3	15.4	14.4	14.7	15.4	17.0	17.7	18.8
	2%	DB	43.1	42.1	39.5	36.2	32.2	27.4	27.5	30.3	34.1	38.2	40.2	42.5
		MCWB	19.1	19.0	19.2	17.7	15.8	14.6	13.8	13.8	14.8	16.5	17.4	18.7
	5%	DB	41.9	40.5	38.2	34.8	30.5	25.9	25.9	28.7	32.8	36.9	39.1	41.2
		MCWB	19.0	19.1	19.1	17.2	15.5	13.9	13.0	13.4	14.5	16.2	17.2	18.5
	10%	DB	40.4	38.6	36.7	33.5	28.9	24.4	24.4	27.1	31.2	35.5	37.9	39.8
		MCWB	19.3	19.5	19.4	17.1	15.2	13.1	12.6	13.0	14.3	16.0	17.1	18.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.9	26.0	24.9	22.9	21.5	19.9	18.3	17.9	18.2	20.1	21.2	24.1
		MCDB	27.2	27.2	26.8	26.2	24.1	21.5	21.6	22.1	26.5	29.5	28.7	27.7
	2%	WB	24.7	24.9	23.9	21.8	18.9	18.1	16.7	16.3	16.7	18.9	20.0	23.1
		MCDB	28.4	28.4	27.8	26.7	23.2	22.3	21.5	24.3	28.8	29.6	31.9	29.4
	5%	WB	24.1	24.3	23.1	21.0	17.8	16.9	15.4	15.1	15.7	18.1	19.1	22.3
		MCDB	29.5	28.5	28.5	26.9	24.7	22.0	21.5	25.4	29.0	30.7	32.8	30.2
	10%	WB	23.5	23.7	22.5	20.1	16.9	15.6	14.2	14.1	15.0	17.2	18.4	21.5
		MCDB	30.0	28.8	28.8	27.1	25.3	21.4	21.3	24.9	29.2	32.2	32.9	31.2
Mean Daily Temperature Range	5% DB	MDBR	12.7	12.0	11.9	12.5	12.9	12.4	13.6	15.1	16.2	15.8	14.5	13.7
		MCDBR	15.0	15.1	14.0	14.3	14.8	14.1	16.2	17.7	18.8	17.6	15.8	15.3
		MCWBR	4.1	3.9	3.7	4.5	5.4	5.9	7.0	7.4	7.2	6.2	4.9	4.7
	5% WB	MCDBR	11.3	10.5	10.3	10.3	10.8	9.6	11.7	14.4	16.2	14.3	13.8	12.3
MCWBR		3.1	2.8	3.3	3.4	4.7	4.9	5.9	6.8	6.6	4.7	4.2	3.4	
Clear-Sky Solar Irradiance	taub	0.367	0.366	0.356	0.340	0.315	0.301	0.303	0.308	0.324	0.345	0.344	0.351	
	taud	2.554	2.572	2.574	2.569	2.568	2.593	2.561	2.512	2.467	2.445	2.482	2.545	
	Ebn at Noon	976	964	947	920	906	901	910	940	963	973	992	994	
	Edh at Noon	110	106	101	93	86	80	85	97	110	118	117	111	
All-Sky Solar Radiation	RadAvg	7.48	7.08	6.28	5.42	4.63	4.12	4.43	5.62	6.77	7.51	8.05	8.06	
	RadStd	0.47	0.44	0.44	0.28	0.34	0.32	0.37	0.21	0.23	0.36	0.35	0.48	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.98	+0.92	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page