

TELFER, Australia

WMO: 943190

Lat: 21.7125S

Lon: 122.2281E

Elev: 960

StdP: 14.19

Time Zone: 8.00 (E08)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	46.4	49.0	6.4	7.9	80.6	13.6	11.3	76.2	24.8	62.3	23.0	63.4	9.6	140	0.528

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	23.7	109.8	68.2	108.0	68.2	106.1	68.2	77.1	87.9	76.3	87.8	75.5	87.7	11.0	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.2	137.0	79.1	73.8	130.4	79.8	72.7	125.7	80.5	41.4	87.5	40.6	87.4	39.8	87.4	86.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.9	21.5	19.5	DB	41.8	113.6	2.3	1.7	40.1	114.8	38.8	115.8	37.5	116.8	35.8	118.0	(4)
(5)			WB	34.7	79.3	1.5	1.8	33.6	80.6	32.7	81.6	31.9	82.7	30.8	84.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	80.2	91.3	89.3	87.3	81.7	72.2	65.3	65.0	68.9	77.0	85.3	88.9	91.4	(6)
(7)		DBStd	11.15	5.31	5.73	5.53	5.38	5.66	5.37	5.06	5.24	5.76	5.48	4.85	4.92	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	157	0	0	0	0	8	61	65	21	2	0	0	0	(9)
(10)		CDD50	11040	1280	1102	1155	950	689	458	464	585	810	1096	1168	1283	(10)
(11)		CDD65	5724	815	682	690	500	232	70	64	142	362	631	718	818	(11)
(12)		CDH74	83370	12753	10188	9904	6310	2412	666	777	1805	4749	9400	11278	13128	(12)
(13)		CDH80	51604	8583	6564	6105	3464	1008	144	176	649	2525	5919	7508	8959	(13)
(14)	Wind	WSAvg	10.5	10.5	10.4	10.3	9.9	10.1	10.5	10.3	10.3	10.6	10.7	11.0	11.0	(14)
(15)	Precipitation	PrecAvg	11.9	1.7	3.7	1.7	0.6	0.7	0.5	0.4	0.2	0.1	0.1	0.3	1.7	(15)
(16)		PrecMax	26.8	5.1	13.5	5.0	3.5	5.6	1.9	3.1	2.2	0.9	0.5	1.0	8.2	(16)
(17)		PrecMin	4.5	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	5.9	1.3	4.1	1.5	0.9	1.4	0.6	0.7	0.6	0.3	0.2	0.3	2.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	112.6	111.3	107.9	102.4	95.0	87.9	87.6	92.4	100.2	106.5	109.6	112.6	(19)
(20)			MCWB	69.8	68.4	69.8	67.2	63.1	62.2	59.9	59.8	62.6	65.0	66.4	69.3	(20)
(21)		2%	DB	109.6	109.1	104.5	100.0	92.1	84.0	84.4	89.4	97.3	104.3	107.5	109.4	(21)
(22)			MCWB	68.4	68.6	69.1	66.2	62.1	60.8	58.9	58.8	61.6	64.7	66.2	68.4	(22)
(23)		5%	DB	107.6	106.1	102.4	97.1	89.2	80.9	81.7	86.6	95.1	102.3	105.4	107.2	(23)
(24)			MCWB	68.7	69.5	68.6	66.0	61.2	58.7	57.7	58.0	60.8	64.1	66.0	68.5	(24)
(25)		10%	DB	105.1	102.6	100.2	94.6	86.0	78.1	78.6	83.9	92.7	100.2	102.6	104.6	(25)
(26)			MCWB	69.7	69.9	68.8	64.9	59.6	57.5	55.7	57.2	60.0	63.8	65.8	68.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.3	79.0	77.2	74.4	71.2	68.8	66.2	65.4	66.1	70.6	73.6	76.5	(27)
(28)			MCD B	88.7	87.5	86.6	82.8	77.1	75.1	77.6	77.8	88.3	90.0	90.5	89.5	(28)
(29)		2%	WB	77.1	77.3	76.0	72.6	66.8	65.9	63.0	62.5	64.4	68.9	72.0	75.3	(29)
(30)			MCD B	88.5	87.4	86.2	83.9	81.2	76.7	77.1	81.4	87.9	91.3	91.2	88.9	(30)
(31)		5%	WB	76.3	76.3	75.1	70.8	64.6	63.0	60.4	60.7	62.9	67.6	70.7	74.4	(31)
(32)			MCD B	88.6	87.3	85.9	85.9	81.1	74.5	76.2	80.8	88.2	91.1	91.7	89.7	(32)
(33)		10%	WB	75.5	75.5	74.1	69.1	62.6	60.8	58.2	58.8	61.7	66.4	69.5	73.4	(33)
(34)			MCD B	88.8	87.1	86.4	87.2	79.6	72.6	74.6	80.1	87.5	91.0	91.9	90.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	23.0	21.6	21.7	23.2	24.1	23.2	25.1	27.3	27.6	26.5	25.9	23.7	(35)
(36)			MCDBR	26.7	26.4	24.8	25.0	26.9	25.3	28.1	30.1	29.6	27.4	27.0	26.1	(36)
(37)			MCWBR	8.1	7.7	7.3	8.2	9.8	10.2	12.3	12.2	10.3	8.6	8.0	7.3	(37)
(38)		5% WB	MCDBR	21.4	19.6	18.9	19.5	20.6	18.4	22.7	24.8	26.6	24.9	25.0	22.3	(38)
(39)			MCWBR	6.3	6.5	6.1	7.0	8.4	8.2	10.9	11.1	9.7	7.9	7.3	6.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.378	0.377	0.372	0.360	0.337	0.321	0.325	0.327	0.345	0.375	0.377	0.374	(40)	
(41)		taud	2.490	2.506	2.495	2.466	2.454	2.488	2.450	2.402	2.380	2.335	2.379	2.470	(41)	
(42)		Ebn at Noon	306	303	296	286	280	280	282	292	299	300	305	308	(42)	
(43)		Edh at Noon	37	36	35	33	31	29	30	35	38	42	41	38	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2360	2245	2021	1807	1524	1377	1497	1847	2165	2394	2516	2472	(44)	
(45)		RadStd	141	176	151	89	116	113	93	63	84	81	98	141	(45)	

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page