

JERVOIS, Australia

WMO: 943270

Lat: 22.9494S

Lon: 136.1442E

Elev: 329

StdP: 97.43

Time Zone: 9.50 (AUC)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.5	4.8	-17.3	0.9	27.7	-14.4	1.1	25.6	7.5	17.7	7.2	17.5	2.0	190	0.453

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.2	41.6	19.0	40.3	19.0	39.2	18.8	24.5	29.6	23.9	29.6	23.2	29.6	4.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.4	19.0	26.2	22.5	17.9	26.3	21.5	16.8	26.6	76.4	29.3	73.7	29.6	71.1	29.2	36.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.2	7.4	6.9	0.8	43.3	1.2	1.5	-0.1	44.4	-0.8	45.2	-1.4	46.1	-2.3	47.1		
			-1.1	27.9	1.6	3.7	-2.2	30.6	-3.2	32.8	-4.0	34.9	-5.2	37.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.1	31.0	29.8	27.7	23.3	18.0	14.3	14.1	16.1	20.7	24.7	27.8	29.8
	DBStd	6.93	2.95	2.75	3.22	3.33	3.32	3.19	2.98	3.66	4.28	3.97	3.39	3.52
	HDD10.0	2	0	0	0	0	0	1	1	0	0	0	0	0
	HDD18.3	433	0	0	1	4	47	128	136	92	22	3	1	0
	CDD10.0	4773	650	554	550	398	248	131	128	189	322	454	534	613
	CDD18.3	2161	392	321	292	153	37	8	4	22	94	199	285	355
	CDH23.3	31298	6006	4756	4036	1861	456	107	118	411	1447	2812	4006	5284
CDH26.7	18376	3877	2928	2333	867	129	24	19	143	711	1584	2411	3349	
Wind	WSAvg	3.6	3.9	3.9	3.9	3.5	3.2	3.2	3.1	3.4	3.6	3.8	3.8	3.9
Precipitation	PrecAvg	285	47	60	30	18	20	11	14	8	6	16	24	33
	PrecMax	776	241	285	188	191	158	91	147	118	39	49	80	195
	PrecMin	107	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	150	65	76	46	37	35	19	30	20	9	15	23	37
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.2	41.7	40.2	36.6	31.7	29.8	29.0	33.3	37.9	40.2	41.6	43.6
		MCWB	20.0	18.9	19.1	18.4	15.9	15.8	14.0	15.2	16.2	17.3	17.8	18.8
	2%	DB	41.6	40.1	38.5	34.7	29.9	26.2	26.4	30.5	35.3	38.0	39.7	41.3
		MCWB	19.8	19.2	18.9	17.6	15.4	14.4	12.5	14.2	15.7	16.6	17.8	18.6
	5%	DB	40.2	38.8	37.1	33.3	28.1	23.7	24.3	27.7	33.3	36.4	38.1	39.8
		MCWB	19.7	19.1	18.5	16.9	14.7	13.2	12.0	12.7	15.1	16.3	17.5	18.8
	10%	DB	38.8	37.4	35.6	31.5	26.0	21.4	22.2	25.2	31.0	34.5	36.5	38.3
		MCWB	19.4	19.1	18.3	16.3	13.9	12.1	11.4	11.7	14.1	15.9	17.2	18.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.5	25.5	24.6	22.6	19.7	17.7	17.3	17.5	20.5	21.2	23.0	24.8
		MCDB	31.0	30.1	28.4	29.1	23.5	25.1	22.8	27.4	24.7	27.7	28.3	29.2
	2%	WB	24.5	24.4	23.1	20.8	17.7	16.2	15.0	15.4	18.1	20.1	21.7	23.6
		MCDB	30.0	29.6	29.2	27.7	25.4	22.4	21.4	27.2	27.7	27.3	29.9	29.1
	5%	WB	23.9	23.8	22.0	19.1	16.1	14.7	13.3	13.7	16.6	19.0	20.9	22.7
		MCDB	29.8	29.8	29.7	28.1	25.0	21.0	21.9	26.5	29.2	29.7	29.4	29.2
	10%	WB	23.2	23.2	20.9	17.6	14.9	13.2	12.0	12.2	15.2	17.8	20.1	22.0
		MCDB	29.9	29.9	30.2	27.9	24.0	19.5	20.7	23.7	29.6	30.1	28.8	30.1
Mean Daily Temperature Range	5% DB	MDBR	13.2	13.2	13.3	14.3	13.8	13.3	15.1	16.1	16.5	15.9	14.6	13.5
		MCDBR	15.1	15.7	15.6	16.4	16.7	16.2	18.6	19.5	19.2	18.5	17.3	16.2
		MCWBR	4.5	4.8	5.4	5.8	6.8	7.0	8.4	8.6	7.4	6.6	5.7	5.4
	5% WB	MCDBR	10.7	10.1	11.0	12.0	13.1	12.5	14.9	16.2	14.0	13.8	12.7	11.0
		MCWBR	3.5	3.3	4.2	4.6	5.9	5.7	7.2	7.6	6.6	5.4	4.0	3.5
Clear-Sky Solar Irradiance	taub	0.381	0.371	0.354	0.330	0.311	0.296	0.296	0.309	0.360	0.367	0.378	0.383	
	taud	2.440	2.475	2.494	2.515	2.530	2.552	2.533	2.465	2.348	2.350	2.383	2.412	
	Ebn at Noon	963	960	949	930	910	906	918	938	927	952	960	962	
	Edh at Noon	123	116	109	98	89	83	87	102	124	130	129	127	
All-Sky Solar Radiation	RadAvg	7.52	7.40	6.69	5.84	4.73	4.25	4.58	5.56	6.46	7.29	7.57	7.49	
	RadStd	0.48	0.44	0.46	0.42	0.34	0.25	0.33	0.24	0.43	0.49	0.43	0.56	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page