

CLONCURRY, Australia

WMO: 943350

Lat: 20.6664S

Lon: 140.5050E

Elev: 613

StdP: 14.37

Time Zone: 10.00 (E10)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	46.7	49.2	12.5	10.6	70.5	15.2	12.1	70.1	21.5	64.6	20.2	66.0	7.6	190	0.482

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	21.9	105.9	68.1	104.0	68.3	102.2	68.1	77.7	88.2	76.8	87.4	76.0	86.6	10.2	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.2	135.1	81.9	74.2	130.8	81.5	73.3	126.5	81.2	41.7	88.2	40.8	87.2	40.0	86.4	81.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.9	18.9	17.3	42.4	109.2	1.8	2.6	41.1	111.0	40.0	112.6	39.0	114.0	37.7	115.9
			34.4	79.1	2.1	1.1	32.9	79.9	31.7	80.5	30.5	81.1	29.0	81.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	79.0	87.8	86.3	85.1	80.8	72.6	66.8	65.6	68.5	76.3	83.0	86.7	89.0
	DBStd	9.71	4.82	4.45	4.17	4.42	5.85	5.45	5.31	5.16	5.31	5.14	4.21	4.70
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	140	0	0	0	1	10	45	60	23	1	0	0	0
	CDD50	10586	1172	1017	1089	925	701	504	483	573	788	1024	1101	1209
	CDD65	5252	707	597	624	475	247	99	78	132	339	559	651	744
	CDH74	71299	10250	8251	8444	5711	2337	794	811	1673	4247	7881	9566	11334
	CDH80	40483	6242	4779	4775	2891	827	161	159	569	2180	4683	5923	7294
Wind	WSAvg	9.4	9.1	9.1	9.2	9.6	9.7	9.7	9.4	9.3	9.4	9.7	9.5	9.4
Precipitation	PrecAvg	18.8	5.3	4.3	2.7	0.7	0.4	0.3	0.2	0.2	0.2	0.9	1.1	2.7
	PrecMax	49.9	30.3	13.3	20.2	7.5	4.0	3.1	3.0	1.8	2.5	4.2	5.2	12.7
	PrecMin	8.3	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2
	PrecStd	9.7	6.3	3.8	3.7	1.5	0.7	0.6	0.6	0.3	0.5	1.2	1.2	2.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	107.9	106.7	103.4	98.1	93.3	87.2	87.0	93.0	99.7	105.2	106.3	109.2
		MCWB	69.5	68.3	69.6	67.3	64.9	63.3	62.9	63.3	64.7	65.7	67.0	68.0
	2%	DB	104.8	103.0	100.8	96.1	89.6	84.1	83.9	89.4	96.9	102.1	103.7	106.2
		MCWB	69.8	69.3	68.9	66.1	63.4	62.7	60.3	61.2	63.2	65.0	66.9	68.0
	5%	DB	102.1	100.2	98.8	94.2	87.4	81.7	81.5	86.1	94.1	99.7	101.7	104.1
		MCWB	70.0	69.7	69.0	65.5	62.6	61.3	58.8	59.4	62.4	64.4	66.6	68.5
	10%	DB	99.4	97.7	96.5	92.2	84.9	78.9	79.0	82.9	91.3	97.2	99.6	101.7
		MCWB	70.4	70.1	69.0	65.0	61.8	59.3	57.4	57.4	61.2	63.9	66.4	68.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.2	78.5	78.2	75.0	70.4	66.4	67.4	66.6	70.5	72.0	75.4	77.5
		MCDB	88.5	90.0	89.0	84.8	82.2	81.3	79.1	85.6	84.5	86.8	88.0	88.2
	2%	WB	77.8	77.5	76.4	72.7	68.3	64.7	64.5	63.9	67.7	70.1	73.9	76.1
		MCDB	87.8	88.7	85.9	83.8	81.9	79.6	76.4	84.2	86.6	87.8	87.8	87.4
	5%	WB	76.9	76.7	75.2	70.3	65.8	63.3	61.8	61.2	65.7	68.6	72.7	75.1
		MCDB	87.1	87.7	84.1	85.2	81.6	77.0	76.4	81.5	85.5	88.6	87.7	87.2
	10%	WB	76.0	75.9	74.0	68.4	63.9	61.7	59.3	59.1	63.6	67.1	71.6	74.2
		MCDB	86.5	86.5	84.4	85.8	81.5	75.5	76.7	81.0	87.2	89.4	87.5	87.6
Mean Daily Temperature Range	5% DB	MDBR	19.3	19.4	20.0	21.3	22.3	22.6	24.7	26.6	26.7	25.8	23.8	21.9
		MCDBR	23.6	23.8	23.3	23.8	23.6	23.9	26.8	30.5	30.5	28.8	27.3	25.7
		MCWBR	7.7	7.1	8.1	8.7	9.7	10.1	12.5	13.7	12.8	11.3	10.0	9.0
	5% WB	MCDBR	16.7	17.0	16.1	17.3	18.8	20.1	22.4	26.3	23.7	23.2	21.4	18.6
	MCWBR	5.3	5.5	5.7	6.3	8.5	8.3	10.7	12.2	10.5	10.0	7.1	5.9	
Clear-Sky Solar Irradiance	taub	0.394	0.394	0.365	0.349	0.338	0.320	0.318	0.335	0.371	0.388	0.407	0.410	
	taud	2.477	2.465	2.531	2.521	2.488	2.515	2.494	2.420	2.347	2.327	2.336	2.380	
	Ebn at Noon	302	298	299	291	282	282	286	291	292	296	296	297	
	Edh at Noon	37	37	34	31	30	28	30	34	40	43	43	42	
All-Sky Solar Radiation	RadAvg	2170	2200	2068	1879	1573	1429	1549	1844	2147	2356	2364	2286	
	RadStd	230	154	167	144	87	98	78	66	122	142	119	183	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page