

CLONCURRY, Australia

WMO: 943350

Lat: 20.6664S

Lon: 140.5050E

Elev: 187

StdP: 99.10

Time Zone: 10.00 (E10)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.2	9.6	-10.8	1.5	21.4	-9.3	1.7	21.2	9.6	18.1	9.0	18.9	3.4	190	0.482

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	12.1	41.1	20.1	40.0	20.2	39.0	20.1	25.4	31.2	24.9	30.8	24.5	30.3	4.6	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.0	19.3	27.7	23.5	18.7	27.5	22.9	18.1	27.3	79.2	31.2	77.1	30.6	75.2	30.2	27.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.4	8.4	7.7	5.8	42.9	1.0	1.4	5.1	43.9	4.5	44.8	3.9	45.6	3.2	46.6		
(5)			1.3	26.2	1.1	0.6	0.5	26.6	-0.2	27.0	-0.8	27.3	-1.6	27.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	26.1	31.0	30.2	29.5	27.1	22.6	19.3	18.7	20.3	24.6	28.4	30.4	31.7	
	DBStd	5.40	2.68	2.47	2.32	2.46	3.25	3.03	2.95	2.86	2.95	2.85	2.34	2.61	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD18.3	78	0	0	0	1	6	25	33	13	1	0	0	0	
	CDD10.0	5881	651	565	605	514	389	280	268	318	438	569	612	672	
	CDD18.3	2918	393	332	347	264	137	55	43	73	188	311	362	413	
	CDH23.3	39611	5694	4584	4691	3173	1298	441	451	929	2359	4378	5314	6297	
	CDH26.7	22491	3468	2655	2653	1606	459	89	88	316	1211	2602	3291	4052	
Wind	WSAvg	4.2	4.1	4.1	4.1	4.3	4.3	4.3	4.2	4.2	4.2	4.4	4.2	4.2	
Precipitation	PrecAvg	477	134	110	68	17	11	7	5	4	5	22	29	69	
	PrecMax	1267	770	338	512	191	101	79	77	45	63	106	131	322	
	PrecMin	211	0	2	0	0	0	0	0	0	0	0	0	5	
	PrecStd	247	159	97	95	37	19	16	15	8	12	31	30	68	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.1	41.5	39.7	36.7	34.1	30.7	30.6	33.9	37.6	40.7	41.3	42.9	
		MCWB	20.8	20.2	20.9	19.6	18.3	17.4	17.2	17.4	18.2	18.7	19.4	20.0	
	2%	DB	40.4	39.5	38.2	35.6	32.0	29.0	28.8	31.9	36.0	39.0	39.9	41.2	
		MCWB	21.0	20.7	20.5	19.0	17.4	17.0	15.7	16.2	17.3	18.4	19.4	20.0	
	5%	DB	38.9	37.9	37.1	34.6	30.8	27.6	27.5	30.1	34.5	37.6	38.7	40.0	
		MCWB	21.1	20.9	20.5	18.6	17.0	16.3	14.9	15.2	16.9	18.0	19.2	20.3	
	10%	DB	37.5	36.5	35.8	33.4	29.4	26.1	26.1	28.3	32.9	36.2	37.6	38.7	
		MCWB	21.3	21.2	20.6	18.3	16.6	15.1	14.1	14.1	16.2	17.7	19.1	20.3	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.2	25.8	25.7	23.9	21.4	19.1	19.6	19.2	21.4	22.2	24.1	25.3
			MCDB	31.4	32.2	31.7	29.3	27.9	27.4	26.2	29.8	29.2	30.5	31.1	31.2
2%		WB	25.5	25.3	24.7	22.6	20.2	18.2	18.1	17.7	19.8	21.2	23.3	24.5	
		MCDB	31.0	31.5	30.0	28.8	27.7	26.4	24.7	29.0	30.3	31.0	31.0	30.8	
5%		WB	24.9	24.8	24.0	21.3	18.8	17.4	16.6	16.2	18.7	20.4	22.6	24.0	
		MCDB	30.6	31.0	29.0	29.6	27.6	25.0	24.7	27.5	29.7	31.4	30.9	30.6	
10%		WB	24.5	24.4	23.3	20.2	17.7	16.5	15.2	15.1	17.5	19.5	22.0	23.4	
		MCDB	30.3	30.3	29.1	29.9	27.5	24.2	24.9	27.2	30.7	31.9	30.8	30.9	
Mean Daily Temperature Range	5% DB	MDBR	10.7	10.8	11.1	11.8	12.4	12.5	13.7	14.8	14.8	14.3	13.2	12.1	
		MCDBR	13.1	13.2	12.9	13.2	13.1	13.3	14.9	16.9	17.0	16.0	15.2	14.3	
		MCWBR	4.3	4.0	4.5	4.8	5.4	5.6	7.0	7.6	7.1	6.3	5.5	5.0	
	5% WB	MCDBR	9.3	9.4	8.9	9.6	10.5	11.2	12.4	14.6	13.1	12.9	11.9	10.4	
		MCWBR	2.9	3.1	3.2	3.5	4.7	4.6	5.9	6.8	5.8	5.5	3.9	3.3	
Clear-Sky Solar Irradiance	taub	0.394	0.394	0.365	0.349	0.338	0.320	0.318	0.335	0.371	0.388	0.407	0.410		
	taud	2.477	2.465	2.531	2.521	2.488	2.515	2.494	2.420	2.347	2.327	2.336	2.380		
	Ebn at Noon	951	939	942	918	888	888	901	917	921	933	933	936		
	Edh at Noon	118	118	106	99	95	89	93	108	125	134	135	131		
All-Sky Solar Radiation	RadAvg	6.84	6.93	6.52	5.92	4.96	4.51	4.88	5.81	6.77	7.43	7.45	7.21		
	RadStd	0.73	0.49	0.53	0.45	0.27	0.31	0.24	0.21	0.39	0.45	0.38	0.58		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page