

THE MONUMENT, Australia

WMO: 943360

Lat: 21.8125S

Lon: 139.9267E

Elev: 289

StdP: 97.90

Time Zone: 10.00 (E10)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.2	6.5	-11.5	1.4	18.1	-10.1	1.6	18.2	8.6	19.2	8.0	19.1	1.9	180	0.469

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.3	41.0	19.9	40.0	19.8	38.9	19.6	24.4	30.7	23.9	30.1	23.5	29.8	4.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.9	18.3	26.3	22.4	17.7	26.4	21.8	17.1	26.6	75.5	31.0	73.4	29.8	71.7	29.4	31.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.1	8.1	7.4	DB	2.1	42.8	1.0	1.4	1.4	43.9	0.8	44.7	0.2	45.5	-0.5	46.6	(4)
(5)			WB	-0.9	25.7	1.1	1.7	-1.6	26.9	-2.3	27.9	-2.9	28.8	-3.7	30.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	24.5	31.0	29.8	28.5	25.0	20.2	16.3	16.1	18.0	22.6	26.7	29.1	30.8	(6)	
	DBStd	6.36	2.86	2.83	2.75	2.94	3.33	3.39	3.24	3.62	4.06	3.65	3.20	3.04	(7)	
	HDD10.0	1	0	0	0	0	0	0	1	0	0	0	0	0	(8)	
	HDD18.3	247	0	0	0	1	19	81	86	51	8	1	0	0	(9)	
	CDD10.0	5288	652	555	575	450	316	189	188	249	378	517	572	646	(10)	
	CDD18.3	2492	394	322	317	201	77	19	16	41	137	259	322	388	(11)	
	CDH23.3	34937	5803	4534	4203	2405	840	222	243	651	1897	3641	4701	5798	(12)	
(13)	CDH26.7	20072	3612	2702	2362	1168	264	38	40	225	954	2119	2893	3696	(13)	
(14)	Wind	WSAvg	3.9	4.3	4.2	4.1	3.7	3.6	3.5	3.7	4.0	4.2	4.2	4.2	(14)	
(15) Precipitation	PrecAvg	332	76	76	28	11	15	10	7	6	10	11	29	51	(15)	
	PrecMax	695	325	193	200	107	91	72	37	43	116	65	72	104	(16)	
	PrecMin	100	3	3	0	0	0	0	0	0	0	0	0	7	(17)	
	PrecStd	152	76	56	43	24	24	19	12	10	24	16	23	31	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.3	41.1	39.9	36.4	33.4	29.6	29.8	33.7	37.7	40.1	41.6	42.8	(19)	
		MCWB	20.6	20.2	20.2	19.0	17.7	16.1	15.8	16.4	17.6	18.6	19.2	20.8	(20)	
	2%	DB	40.6	39.4	38.1	35.0	30.9	27.7	27.6	31.4	35.7	38.5	40.0	41.0	(21)	
		MCWB	20.5	20.5	20.2	18.7	16.8	15.8	14.7	15.2	16.8	18.0	18.9	19.7	(22)	
	5%	DB	39.3	38.1	36.8	33.8	29.5	26.1	26.1	29.2	34.0	37.2	38.7	39.8	(23)	
		MCWB	20.3	20.2	19.7	17.8	16.2	15.0	13.9	14.3	16.1	17.5	18.6	19.7	(24)	
	10%	DB	37.9	36.9	35.4	32.5	28.0	24.0	24.3	27.1	32.1	35.5	37.2	38.5	(25)	
		MCWB	20.5	20.0	19.5	17.4	15.3	13.8	13.2	13.1	15.3	17.0	18.4	19.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.1	24.7	24.6	22.6	20.6	18.3	19.0	18.5	20.1	21.3	22.8	24.5	(27)	
		MCDB	31.9	31.8	29.8	29.6	28.0	25.6	25.3	28.8	28.4	31.4	32.2	32.0	(28)	
	2%	WB	24.5	24.0	23.7	21.6	18.7	17.2	17.1	16.8	18.8	20.1	21.9	23.6	(29)	
		MCDB	30.9	30.8	28.6	28.1	27.2	24.3	23.5	27.4	28.8	30.8	31.9	30.8	(30)	
	5%	WB	24.1	23.5	23.2	20.3	17.6	16.1	15.3	15.2	17.5	19.2	21.2	23.1	(31)	
		MCDB	30.1	30.4	28.2	27.9	26.5	23.3	23.4	27.6	30.1	31.3	30.8	30.6	(32)	
	10%	WB	23.6	23.1	22.5	19.2	16.5	15.0	13.9	14.0	16.3	18.3	20.5	22.5	(33)	
		MCDB	29.7	29.9	28.7	28.9	26.1	22.7	23.2	25.4	30.2	32.3	30.6	30.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	11.3	11.7	11.8	13.3	13.8	13.7	14.8	15.8	15.8	15.3	14.4	12.9	(35)	
		MCDBR	13.6	13.5	13.5	14.3	14.8	15.4	16.7	17.5	16.8	16.6	15.9	14.6	(36)	
	5% WB	MCWBR	4.4	4.1	4.7	5.2	6.4	7.1	7.9	7.8	7.3	6.7	5.9	5.1	(37)	
		MCWBR	9.6	9.7	9.1	10.5	12.2	12.2	13.3	15.0	13.3	13.2	12.7	10.8	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.384	0.376	0.356	0.340	0.327	0.310	0.310	0.322	0.364	0.373	0.391	0.395	(40)	
		taud	2.462	2.481	2.514	2.512	2.493	2.516	2.489	2.432	2.343	2.340	2.350	2.385	(41)	
	Ebn at Noon		960	955	949	924	896	894	905	928	926	946	947	950	(42)	
		Edh at Noon	120	116	107	100	93	87	92	106	125	132	134	130	(43)	
(44) All-Sky Solar Radiation	RadAvg		7.10	7.13	6.54	5.82	4.82	4.34	4.72	5.69	6.61	7.37	7.51	7.36	(44)	
	RadStd		0.67	0.47	0.49	0.44	0.29	0.28	0.26	0.23	0.43	0.49	0.38	0.57	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page