

JULIA CREEK, Australia

WMO: 943370

Lat: 20.6672S

Lon: 141.7214E

Elev: 405

StdP: 14.48

Time Zone: 10.00 (E10)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	41.8	44.6	9.8	9.2	68.3	13.0	10.8	66.7	23.5	67.1	22.2	68.7	8.7	160	0.512

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	25.3	106.5	69.0	104.6	69.0	102.8	69.1	78.7	90.6	77.7	89.1	76.8	87.9	10.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.1	138.4	82.6	75.0	133.5	81.8	74.0	128.7	81.6	42.6	90.7	41.5	88.7	40.6	87.8	95.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
22.8	20.6	18.7	DB	36.1	109.5	2.6	2.2	34.2	111.1	32.7	112.4	31.2	113.7	29.3	115.3
			WB	30.4	81.4	2.8	3.8	28.4	84.2	26.8	86.4	25.2	88.6	23.2	91.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	77.8	86.5	85.1	83.4	78.7	71.6	65.1	64.9	67.3	75.1	81.8	85.9	88.4
	DBStd	9.86	4.61	4.31	4.23	4.53	5.92	6.15	5.80	5.71	5.83	5.63	4.58	4.52
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	211	0	0	0	1	15	76	75	41	3	0	0	0
	CDD50	10137	1132	982	1035	862	671	453	462	535	752	986	1077	1190
	CDD65	4873	667	562	570	413	221	79	72	111	305	521	627	725
	CDH74	67503	9213	7503	7454	5141	2495	911	1041	1875	4250	7532	9218	10870
	CDH80	39063	5518	4358	4278	2803	1014	229	265	712	2314	4647	5881	7044
(14) Wind	WSAvg	10.2	9.4	9.4	9.4	10.2	10.4	10.7	10.7	10.5	10.7	10.7	9.9	10.2
(15) Precipitation	PrecAvg	19.6	5.1	4.6	2.3	0.8	0.5	0.3	0.2	0.2	0.2	0.7	1.3	2.8
	PrecMax	42.7	29.1	14.3	10.3	10.2	5.3	3.7	2.8	2.0	2.9	3.4	4.8	8.0
	PrecMin	8.6	0.2	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1
	PrecStd	7.6	5.5	3.1	2.3	1.9	1.0	0.7	0.6	0.4	0.6	0.9	1.2	2.1
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	108.3	107.9	104.0	98.7	94.2	87.8	89.0	93.8	100.5	105.5	107.1	109.3
		MCWB	71.4	69.0	69.8	68.7	66.6	64.3	64.5	63.9	65.4	66.3	68.2	69.1
	2%	DB	105.0	103.3	101.3	96.7	90.8	85.2	85.4	90.6	97.6	102.8	104.6	106.7
		MCWB	71.0	70.7	70.2	67.4	64.6	63.5	62.3	62.3	64.2	66.1	67.9	68.6
	5%	DB	102.2	100.6	99.0	94.8	88.6	82.8	83.0	87.2	94.9	100.5	102.8	104.7
		MCWB	72.2	71.0	70.0	66.6	64.1	62.2	60.5	60.4	63.0	65.4	67.5	68.9
	10%	DB	99.2	97.8	96.5	92.8	86.1	79.8	80.4	84.0	92.2	98.0	100.8	102.4
		MCWB	72.1	71.6	70.3	66.2	63.1	60.0	58.9	58.6	61.8	64.8	67.3	69.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	86.7	80.6	79.1	74.6	71.3	67.5	68.7	67.5	71.1	72.9	76.3	78.1
		MCDB	97.7	91.8	89.8	90.0	86.6	82.1	77.8	86.3	88.9	90.1	93.3	90.7
	2%	WB	79.0	78.5	77.2	72.4	68.8	65.6	65.6	65.2	68.7	71.0	74.4	76.7
		MCDB	91.1	90.1	87.1	88.1	82.6	80.1	80.8	84.8	87.9	90.0	90.9	90.0
	5%	WB	77.9	77.5	76.0	70.9	66.7	64.1	63.0	62.7	66.6	69.2	73.0	75.6
		MCDB	89.3	88.7	86.4	87.2	82.9	78.6	79.4	82.7	86.7	90.2	90.0	89.9
	10%	WB	76.9	76.6	74.8	69.3	65.1	62.2	60.5	60.3	64.2	67.6	71.7	74.7
		MCDB	87.7	87.5	85.9	86.1	82.9	77.0	77.6	81.3	86.1	91.2	89.9	89.7
(35) Mean Daily Temperature Range	5% DB	MDBR	21.7	22.6	24.1	27.7	27.8	27.9	29.9	32.2	31.8	30.8	27.9	25.3
		MCDBR	27.1	27.7	28.0	29.7	28.9	29.3	31.3	34.8	33.8	32.5	30.9	29.3
		MCWBR	9.7	9.3	9.9	11.8	12.9	13.7	15.8	16.8	15.2	13.7	12.0	11.7
	5% WB	MCDBR	19.2	19.4	19.3	23.1	24.0	24.5	26.3	29.5	27.6	26.6	24.4	21.8
		MCWBR	6.7	6.5	7.1	8.8	11.0	11.6	13.4	14.7	12.7	11.6	8.2	8.0
(40) Clear-Sky Solar Irradiance	taub		0.396	0.392	0.369	0.351	0.340	0.323	0.320	0.334	0.371	0.393	0.402	0.414
	taud		2.459	2.464	2.506	2.502	2.468	2.495	2.482	2.417	2.338	2.300	2.335	2.353
	Ebn at Noon		301	298	298	290	281	280	285	291	292	295	297	296
	Edh at Noon		38	37	35	32	31	29	30	34	40	44	43	43
(44) All-Sky Solar Radiation	RadAvg		2213	2224	2081	1884	1565	1422	1543	1841	2150	2355	2384	2324
	RadStd		217	134	158	136	81	95	76	72	119	129	123	166

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page