

JULIA CREEK, Australia

WMO: 943370

Lat: 20.6672S

Lon: 141.7214E

Elev: 123

StdP: 99.85

Time Zone: 10.00 (E10)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.4	7.0	-12.3	1.3	20.2	-10.5	1.5	19.3	10.5	19.5	9.9	20.4	3.9	160	0.512

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	14.1	41.4	20.6	40.3	20.5	39.3	20.6	26.0	32.5	25.4	31.7	24.9	31.1	4.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.5	19.8	28.1	23.9	19.1	27.7	23.3	18.4	27.5	81.2	32.6	78.7	31.5	76.7	31.0	35.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.2	9.2	8.4	DB	2.3	43.0	1.4	1.2	1.2	43.9	0.4	44.7	-0.4	45.4	-1.5	46.3	(4)
(5)			WB	-0.9	27.5	1.6	2.1	-2.0	29.0	-2.9	30.2	-3.8	31.4	-4.9	33.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	25.4	30.3	29.5	28.5	26.0	22.0	18.4	18.3	19.6	23.9	27.7	29.9	31.3	(6)	
	DBStd	5.48	2.56	2.40	2.35	2.52	3.29	3.42	3.22	3.17	3.24	3.13	2.54	2.51	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	117	0	0	0	1	8	42	42	23	2	0	0	0	(9)	
	CDD10.0	5632	629	546	575	479	373	252	257	297	418	548	598	661	(10)	
	CDD18.3	2707	371	312	317	229	123	44	40	62	169	289	348	403	(11)	
	CDH23.3	37502	5118	4168	4141	2856	1386	506	578	1042	2361	4184	5121	6039	(12)	
(13)	CDH26.7	21702	3066	2421	2377	1557	563	127	147	396	1286	2582	3267	3913	(13)	
(14)	Wind	WSAvg	4.6	4.2	4.2	4.2	4.6	4.7	4.8	4.7	4.8	4.8	4.4	4.5	(14)	
(15) Precipitation	PrecAvg	498	129	117	58	21	13	7	6	4	6	17	32	71	(15)	
	PrecMax	1084	739	363	262	260	135	94	71	50	74	87	123	202	(16)	
	PrecMin	219	6	5	0	0	0	0	0	0	0	0	0	3	(17)	
	PrecStd	193	140	80	59	49	26	18	14	10	15	24	30	53	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.4	42.1	40.0	37.1	34.6	31.0	31.7	34.4	38.0	40.9	41.7	42.9	(19)	
		MCWB	21.9	20.6	21.0	20.4	19.2	17.9	18.1	17.7	18.6	19.1	20.1	20.6	(20)	
	2%	DB	40.6	39.6	38.5	36.0	32.7	29.5	29.7	32.6	36.5	39.4	40.4	41.5	(21)	
		MCWB	21.6	21.5	21.2	19.7	18.1	17.5	16.8	16.9	17.9	19.0	20.0	20.3	(22)	
	5%	DB	39.0	38.1	37.2	34.9	31.4	28.2	28.3	30.7	35.0	38.1	39.4	40.4	(23)	
		MCWB	22.3	21.6	21.1	19.2	17.8	16.8	15.8	15.8	17.2	18.5	19.7	20.5	(24)	
	10%	DB	37.3	36.6	35.8	33.8	30.1	26.6	26.9	28.9	33.4	36.7	38.2	39.1	(25)	
		MCWB	22.3	22.0	21.3	19.0	17.3	15.6	15.0	14.8	16.5	18.2	19.6	21.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	30.4	27.0	26.2	23.7	21.8	19.7	20.4	19.7	21.7	22.7	24.6	25.6	(27)	
		MCDB	36.5	33.2	32.1	32.2	30.3	27.8	25.5	30.2	31.6	32.3	34.0	32.6	(28)	
	2%	WB	26.1	25.8	25.1	22.5	20.4	18.6	18.7	18.5	20.4	21.7	23.5	24.8	(29)	
		MCDB	32.8	32.3	30.6	31.2	28.1	26.7	27.1	29.4	31.1	32.2	32.7	32.2	(30)	
	5%	WB	25.5	25.3	24.5	21.6	19.3	17.8	17.2	17.0	19.2	20.7	22.8	24.2	(31)	
		MCDB	31.9	31.5	30.2	30.7	28.3	25.9	26.4	28.2	30.4	32.4	32.2	32.2	(32)	
	10%	WB	25.0	24.8	23.8	20.7	18.4	16.8	15.9	15.7	17.9	19.8	22.1	23.7	(33)	
		MCDB	30.9	30.8	30.0	30.0	28.3	25.0	25.3	27.4	30.1	32.9	32.2	32.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	12.0	12.5	13.4	15.4	15.4	15.5	16.6	17.9	17.7	17.1	15.5	14.1	(35)	
		MCDBR	15.0	15.4	15.6	16.5	16.1	16.3	17.4	19.3	18.8	18.1	17.2	16.3	(36)	
	5% WB	MCWBR	5.4	5.1	5.5	6.5	7.2	7.6	8.8	9.3	8.5	7.6	6.7	6.5	(37)	
		MCWBR	10.7	10.8	10.7	12.9	13.3	13.6	14.6	16.4	15.3	14.8	13.6	12.1	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.396	0.392	0.369	0.351	0.340	0.323	0.320	0.334	0.371	0.393	0.402	0.414	(40)	
		taud	2.459	2.464	2.506	2.502	2.468	2.495	2.482	2.417	2.338	2.300	2.335	2.353	(41)	
	Ebn at Noon	Ebn at Noon	949	941	938	915	886	884	899	918	921	929	937	933	(42)	
		Edh at Noon	121	118	109	101	97	90	94	108	127	138	136	134	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	6.98	7.01	6.56	5.94	4.93	4.48	4.87	5.80	6.78	7.42	7.51	7.33	(44)	
	RadStd	RadStd	0.68	0.42	0.50	0.43	0.26	0.30	0.24	0.23	0.38	0.41	0.39	0.52	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page