

TREPELL, Australia

WMO: 943380

Lat: 21.8400S

Lon: 140.8925E

Elev: 267

StdP: 98.16

Time Zone: 10.00 (E10)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.7	6.9	-12.0	1.4	16.8	-10.6	1.6	18.1	8.9	21.5	8.1	20.4	2.9	220	0.475

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	12.9	40.9	19.8	39.9	19.8	38.8	19.7	24.4	30.0	24.0	29.6	23.5	29.7	5.0	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.1	18.5	26.4	22.6	17.9	26.3	21.9	17.1	26.3	75.5	30.0	73.6	29.5	71.8	29.2	26.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.4	8.4	7.6	DB	3.4	42.8	1.3	1.5	2.5	43.9	1.8	44.8	1.0	45.6	0.1	46.7	(4)
(5)			WB	-0.1	25.3	1.2	0.6	-0.9	25.8	-1.6	26.2	-2.3	26.5	-3.2	27.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	24.7	30.5	29.7	28.5	25.3	20.8	16.8	16.6	18.5	22.9	27.0	29.1	30.9	(6)	
	DBStd	6.06	2.97	2.79	2.73	2.80	3.33	3.32	3.21	3.41	3.77	3.39	2.94	2.86	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	202	0	0	0	1	16	68	72	39	6	1	0	0	(9)	
	CDD10.0	5367	636	552	573	458	334	206	206	264	388	526	573	649	(10)	
	CDD18.3	2527	378	319	314	208	92	23	20	46	144	268	323	391	(11)	
	CDH23.3	34385	5408	4400	4109	2425	911	229	258	671	1882	3684	4584	5824	(12)	
(13)	CDH26.7	19565	3303	2602	2309	1185	286	34	38	224	928	2149	2805	3703	(13)	
(14)	Wind	WSAvg	4.1	4.5	4.5	4.3	3.8	3.7	3.7	3.9	4.1	4.5	4.4	4.5	(14)	
(15) Precipitation	PrecAvg	391	92	84	45	15	14	12	5	4	8	15	34	63	(15)	
	PrecMax	857	436	195	376	146	78	112	37	30	88	70	108	290	(16)	
	PrecMin	123	8	2	2	0	0	0	0	0	0	0	1	11	(17)	
	PrecStd	182	96	64	73	31	20	23	9	7	18	18	28	54	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.9	41.6	40.0	36.4	33.5	29.4	29.5	34.1	37.5	40.1	41.3	42.6	(19)	
		MCWB	21.2	20.0	20.8	19.4	17.7	16.4	16.2	16.9	17.7	18.4	19.4	20.3	(20)	
	2%	DB	40.4	39.3	38.2	34.9	31.0	27.7	27.6	31.3	35.4	38.4	39.7	41.0	(21)	
		MCWB	20.5	20.5	20.2	18.8	17.2	16.0	14.9	15.4	16.9	18.0	19.0	19.7	(22)	
	5%	DB	39.1	38.0	36.8	33.7	29.7	26.1	26.2	29.1	33.8	37.1	38.5	39.7	(23)	
		MCWB	20.5	20.3	19.9	17.9	16.5	15.2	14.3	14.3	16.3	17.7	18.7	19.7	(24)	
	10%	DB	37.6	36.7	35.4	32.6	28.2	24.4	24.6	27.2	32.0	35.4	37.1	38.5	(25)	
		MCWB	20.5	20.3	19.7	17.6	15.9	14.1	13.5	13.4	15.5	17.1	18.6	19.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.2	24.6	24.5	22.2	20.8	18.2	19.3	18.5	20.6	21.3	22.9	24.2	(27)	
		MCDB	30.6	30.9	29.8	30.2	27.9	26.1	24.8	29.4	30.0	30.8	31.2	30.4	(28)	
	2%	WB	24.7	24.0	23.7	21.1	19.1	17.3	17.6	16.8	19.1	20.3	22.2	23.6	(29)	
		MCDB	30.0	30.3	29.0	28.4	27.2	24.8	24.0	27.8	29.0	30.9	30.7	30.4	(30)	
	5%	WB	24.2	23.5	23.1	20.2	18.0	16.4	15.8	15.4	17.8	19.5	21.6	23.1	(31)	
		MCDB	29.6	30.0	28.7	28.5	26.9	23.5	23.5	26.4	30.0	31.2	30.7	30.8	(32)	
	10%	WB	23.7	23.0	22.5	19.3	17.0	15.3	14.4	14.2	16.6	18.6	20.9	22.5	(33)	
		MCDB	29.4	29.8	29.0	29.0	26.5	22.7	23.2	26.1	29.3	31.9	30.8	30.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	11.2	12.0	12.0	13.5	13.6	13.6	14.6	15.7	15.6	15.2	14.2	12.9	(35)	
		MCDBR	13.9	13.6	13.6	14.1	14.1	14.6	15.8	17.2	16.4	16.6	15.7	14.7	(36)	
		MCWBR	4.7	4.1	4.8	5.5	6.1	7.0	7.9	8.1	7.4	6.8	5.9	5.3	(37)	
	5% WB	MCDBR	9.3	10.0	9.2	11.6	12.0	12.0	13.1	15.0	13.6	13.1	12.9	11.0	(38)	
		MCWBR	2.7	3.0	2.9	4.3	5.5	5.8	6.8	7.2	6.4	5.5	4.2	3.4	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.383	0.377	0.357	0.341	0.330	0.312	0.311	0.323	0.365	0.374	0.389	0.395	(40)	
	taud		2.481	2.495	2.529	2.528	2.502	2.533	2.506	2.448	2.354	2.353	2.368	2.403	(41)	
	Ebn at Noon		961	954	948	923	893	893	905	927	925	946	949	951	(42)	
	Edh at Noon		118	114	106	98	93	86	91	104	124	130	131	128	(43)	
(44) All-Sky Solar Radiation	RadAvg		7.09	7.10	6.51	5.77	4.77	4.29	4.68	5.66	6.59	7.38	7.51	7.35	(44)	
	RadStd		0.67	0.44	0.48	0.44	0.27	0.28	0.25	0.22	0.43	0.46	0.39	0.53	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page