

URANDANGI, Australia

WMO: 943440

Lat: 21.598S

Lon: 138.366E

Elev: 587

StdP: 14.39

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	39.7	42.6	7.9	8.4	68.9	11.7	10.2	68.6	20.4	72.4	18.6	68.0	2.7	150	0.413

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.5	107.5	68.9	105.5	69.0	103.5	68.8	78.9	89.8	77.9	88.3	76.9	87.2	8.9	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.6	141.8	82.2	75.6	136.8	81.9	74.4	131.4	82.0	43.0	89.6	41.9	88.2	40.9	86.7	94.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max				
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
19.6	17.7	15.9	DB	34.7	110.6	2.0	2.1	33.3	112.2	32.1	113.4	31.0	114.6	29.6	116.2	
			WB	30.4	82.9	2.4	4.5	28.8	86.2	27.4	88.8	26.1	91.4	24.3	94.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	76.8	88.5	87.8	84.6	77.9	68.6	63.2	61.4	64.3	73.2	80.3	84.8	88.0
	DBStd	11.54	4.90	4.53	4.69	5.49	6.04	6.43	5.80	6.45	7.03	6.69	5.93	5.88
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	397	0	0	0	2	34	111	144	94	11	1	0	0
	CDD50	9785	1192	1057	1073	836	576	396	352	443	696	941	1045	1178
	CDD65	4705	727	637	608	388	145	57	31	71	257	476	595	713
	CDH74	65103	10772	9233	8066	4442	1472	597	506	1071	3375	6400	8480	10689
(13)	CDH80	38164	6807	5724	4632	2266	520	154	117	368	1700	3750	5260	6866
(14)	Wind	WSAvg	6.4	5.8	6.0	6.3	6.3	6.4	6.0	6.5	7.0	7.0	6.8	6.6
(15) Precipitation	PrecAvg	12.4	2.6	2.6	1.4	0.5	0.5	0.3	0.4	0.2	0.3	0.6	1.0	1.8
	PrecMax	32.3	17.3	10.7	6.9	5.3	5.4	3.9	4.8	1.4	1.8	3.6	3.8	14.3
	PrecMin	3.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	6.5	3.1	2.7	1.8	1.1	1.0	0.6	1.0	0.4	0.4	0.9	1.1	2.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	109.0	108.4	105.5	99.9	92.0	88.1	87.3	92.0	100.6	105.5	108.1	110.5
		MCWB	70.0	70.5	68.2	67.8	64.8	63.8	61.8	63.0	65.5	66.0	67.3	69.7
	2%	DB	106.3	105.3	102.5	97.0	88.7	84.4	83.2	88.5	96.9	102.5	105.4	107.5
		MCWB	70.3	70.2	69.2	66.1	63.0	62.6	58.8	61.6	64.3	65.0	67.0	68.3
	5%	DB	104.1	103.0	99.7	94.4	85.8	80.8	79.8	84.7	93.9	99.3	102.9	105.0
		MCWB	70.7	70.2	69.1	65.6	62.2	60.8	57.2	59.2	62.8	64.3	66.4	68.8
	10%	DB	101.3	100.4	97.1	91.4	82.4	76.8	75.9	80.6	90.5	96.2	100.0	102.2
		MCWB	70.7	70.2	68.9	64.7	60.8	58.7	55.5	57.6	61.2	63.4	66.2	69.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.0	80.4	78.1	74.9	71.3	66.5	64.6	66.6	70.9	74.3	76.4	79.2
		MCDB	95.6	92.4	87.2	86.7	83.6	83.0	79.4	83.8	83.9	87.5	90.4	88.7
	2%	WB	78.9	78.9	76.9	72.0	67.2	64.5	61.7	64.2	67.9	71.3	74.3	77.4
		MCDB	90.8	89.2	85.8	86.4	81.1	79.7	77.9	82.4	88.0	85.4	87.9	87.8
	5%	WB	77.8	77.9	75.7	69.4	64.9	62.6	59.1	61.5	65.9	69.5	72.8	76.3
		MCDB	88.8	88.0	85.5	85.8	79.6	77.7	76.3	81.2	87.4	86.6	87.1	87.6
	10%	WB	76.7	77.0	74.2	67.2	62.7	60.2	56.4	58.8	63.8	67.4	71.7	75.1
		MCDB	87.7	87.1	86.2	85.9	78.8	73.7	73.3	78.9	85.2	87.9	87.0	87.7
(35) Mean Daily Temperature Range	5% DB	MDBR	22.5	22.8	23.6	26.1	25.9	26.4	28.9	30.3	30.4	27.9	26.2	23.1
		MCDBR	27.0	27.0	27.7	29.6	29.5	30.0	33.3	34.0	33.5	31.8	30.8	27.8
		MCWBR	8.8	8.6	9.4	11.1	13.2	14.1	16.1	15.6	14.3	12.9	11.5	10.5
	5% WB	MCDBR	19.4	19.1	18.1	21.8	22.9	24.6	27.7	28.4	25.4	24.3	21.9	18.2
		MCWBR	6.5	5.6	6.6	8.9	10.8	12.4	13.9	13.8	11.4	10.4	7.8	6.1
(40) Clear-Sky Solar Irradiance	taub		0.391	0.388	0.369	0.346	0.331	0.314	0.315	0.327	0.369	0.383	0.397	0.404
	taud		2.437	2.440	2.465	2.482	2.470	2.492	2.464	2.404	2.323	2.306	2.331	2.355
	Ebn at Noon		303	299	297	291	283	282	285	292	292	298	299	299
	Edh at Noon		39	38	36	33	30	29	30	35	41	43	43	43
(44) All-Sky Solar Radiation	RadAvg		2276	2273	2069	1843	1530	1387	1497	1795	2087	2315	2376	2334
(45)	RadStd		190	151	147	128	89	78	82	75	125	155	108	187

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page