

PROSERPINE WHITSUNDAY COAST, Australia

WMO: 943650

Lat: 20.4925S

Lon: 148.5550E

Elev: 67

StdP: 14.66

Time Zone: 10.00 (E10)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	42.5	46.0	35.3	30.3	60.3	38.9	34.9	56.0	22.7	71.9	20.7	72.0	2.5	210	0.387

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.4	93.0	75.4	90.9	75.1	89.1	74.8	80.0	86.3	79.0	84.9	78.1	83.9	11.9	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.5	148.4	82.7	77.4	142.9	81.7	76.6	139.0	81.1	43.7	86.7	42.6	85.0	41.7	84.0	85.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.7	19.8	18.1	36.8	98.0	3.1	2.4	34.6	99.7	32.8	101.2	31.1	102.5	28.8	104.3
			35.8	81.8	3.2	1.6	33.5	82.9	31.6	83.9	29.9	84.7	27.6	85.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	73.1	80.3	79.9	78.4	74.7	69.6	65.4	63.7	64.9	69.9	74.3	77.4	79.9	(6)
	DBStd	6.95	2.48	2.51	2.31	2.51	4.10	4.88	4.95	4.24	3.63	3.32	2.86	2.87	(7)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD65	210	0	0	0	0	13	56	83	52	6	0	0	0	(9)
	CDD50	8450	938	837	880	741	608	461	425	463	596	753	822	926	(10)
	CDD65	3185	473	417	415	291	156	67	43	50	152	288	372	461	(11)
	CDH74	25404	4371	3671	3231	1678	721	225	175	418	1177	2242	3123	4372	(12)
	CDH80	7808	1501	1171	899	299	65	14	9	46	263	679	1129	1733	(13)
(14) Wind	WSAvg	8.3	8.6	8.7	9.2	9.4	8.1	7.6	7.4	7.3	7.8	8.7	8.4	8.7	(14)
(15) Precipitation	PrecAvg	57.3	11.0	13.5	6.4	5.4	3.4	1.4	0.8	0.9	0.9	1.2	3.7	7.6	(15)
	PrecMax	97.5	32.2	36.5	17.4	17.8	10.7	4.8	2.9	4.3	3.6	5.8	10.6	42.4	(16)
	PrecMin	33.7	0.6	1.0	0.9	1.0	0.2	0.0	0.0	0.0	0.0	0.0	0.0	1.8	(17)
	PrecStd	20.0	8.6	9.5	4.8	4.9	2.8	1.2	0.8	1.1	1.1	1.5	3.5	9.0	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	94.4	94.6	91.3	87.4	84.5	82.1	81.1	84.2	89.6	92.8	94.1	96.3	(19)
		MCWB	77.1	78.2	76.9	73.6	70.5	68.7	66.9	66.8	67.1	70.6	73.1	75.8	(20)
	2%	DB	91.3	90.7	88.1	84.7	81.7	78.5	77.9	80.9	85.9	88.7	90.7	92.9	(21)
		MCWB	77.3	77.7	76.4	72.9	69.6	67.6	65.6	65.1	67.8	71.6	73.3	75.2	(22)
	5%	DB	89.1	88.1	86.3	82.9	79.8	76.5	75.6	78.4	82.8	86.1	88.2	90.3	(23)
		MCWB	76.7	77.2	75.6	72.5	69.1	66.7	64.6	64.5	67.6	70.9	72.6	74.6	(24)
	10%	DB	86.9	86.3	84.6	81.6	78.1	74.7	73.8	76.0	80.4	83.8	86.1	88.1	(25)
		MCWB	75.9	76.6	74.9	72.0	68.4	65.7	63.8	64.1	67.2	70.2	72.0	74.2	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.1	81.9	80.2	78.2	75.5	72.8	71.6	71.6	74.0	77.6	78.3	80.2	(27)
		MCDB	88.2	88.9	85.6	82.4	79.8	77.3	75.3	77.3	81.5	83.2	85.7	87.8	(28)
	2%	WB	79.8	80.0	78.7	76.2	72.9	70.5	69.3	69.6	72.1	74.7	76.4	78.5	(29)
		MCDB	86.2	86.3	84.5	80.4	77.7	75.4	74.2	75.8	79.7	81.9	84.1	85.7	(30)
	5%	WB	78.8	79.0	77.6	74.6	71.3	69.1	67.5	67.9	70.8	73.1	75.2	77.3	(31)
		MCDB	84.7	84.3	83.2	79.8	77.1	73.9	72.6	74.3	78.0	81.6	83.5	84.6	(32)
	10%	WB	77.8	78.0	76.6	73.5	70.0	67.5	66.1	66.3	69.4	71.9	74.0	76.3	(33)
		MCDB	83.7	83.2	81.9	79.0	75.8	72.4	71.0	72.7	76.3	80.5	82.2	83.6	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	13.4	12.5	12.9	14.4	17.7	18.7	21.3	23.3	22.2	19.8	17.7	16.3	(35)
		MCDBR	17.3	16.2	15.8	16.8	19.0	19.3	22.6	27.5	27.5	23.9	21.7	20.6	(36)
		MCWBR	5.9	6.3	6.4	7.4	9.3	10.2	12.0	13.6	12.1	9.3	7.5	6.3	(37)
		MCDBR	14.0	13.6	12.9	13.1	15.4	15.2	16.8	20.3	19.6	19.7	17.9	16.0	(38)
	5% WB	MCWBR	5.6	6.3	6.0	6.4	8.3	8.6	9.6	11.1	8.9	8.1	6.7	6.0	(39)
(40) Clear-Sky Solar Irradiance	taub		0.405	0.399	0.386	0.362	0.347	0.331	0.319	0.328	0.360	0.386	0.394	0.404	(40)
	taud		2.499	2.518	2.540	2.592	2.587	2.623	2.640	2.596	2.499	2.450	2.469	2.471	(41)
	Ebn at Noon		298	296	292	287	280	279	287	294	296	297	299	299	(42)
	Edh at Noon		37	36	33	30	28	25	26	29	34	37	38	38	(43)
(44) All-Sky Solar Radiation	RadAvg		1963	1882	1745	1557	1352	1214	1372	1631	1971	2179	2201	2189	(44)
	RadStd		178	217	182	157	89	120	101	112	139	130	278	235	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page