

MIDDLE PERCY ISLAND, Australia

WMO: 943720

Lat: 21.663S

Lon: 150.271E

Elev: 209

StdP: 98.83

Time Zone: 10.00 (E10)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.3	15.0	3.7	5.1	16.3	5.4	5.7	16.5	13.5	16.5	12.3	17.0	7.1	170	0.495

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.7	28.9	24.4	28.4	24.1	27.9	23.9	26.2	27.2	25.7	26.9	25.2	26.5	5.3	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.9	21.8	26.7	25.3	21.0	26.3	24.8	20.4	26.0	83.0	27.1	80.6	27.0	78.7	26.5	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.0	11.9	11.0	DB	12.7	30.7	1.6	0.9	11.6	31.4	10.6	31.9	9.8	32.5	8.6	33.2	(4)
(5)			WB	8.2	26.8	1.1	0.8	7.4	27.4	6.8	27.8	6.2	28.3	5.4	28.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	22.5	25.8	25.7	25.0	23.3	21.2	19.0	18.6	19.0	20.7	22.5	24.0	25.3	(6)
(7)		DBStd	2.94	1.05	1.05	1.18	1.09	1.54	1.80	1.69	1.51	1.26	1.08	1.10	1.09	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	43	0	0	0	0	1	14	17	11	1	0	0	0	(9)
(10)		CDD10.0	4562	490	441	467	399	347	269	267	279	322	386	420	475	(10)
(11)		CDD18.3	1565	232	207	208	149	89	34	26	32	73	128	170	217	(11)
(12)		CDH23.3	6926	1688	1476	1197	311	46	2	1	3	35	204	625	1338	(12)
(13)	CDH26.7	563	185	148	77	1	0	0	0	0	0	2	19	131	(13)	
(14)	Wind	WSAvg	6.0	6.2	6.4	6.9	7.2	6.2	6.0	5.8	5.4	5.2	5.7	5.5	5.9	(14)
(15)	Precipitation	PrecAvg	840	126	148	134	72	53	50	34	32	20	30	43	99	(15)
(16)		PrecMax	1503	331	520	521	218	236	147	178	167	111	103	231	347	(16)
(17)		PrecMin	375	28	20	12	8	11	10	3	1	1	2	6	17	(17)
(18)		PrecStd	250	74	101	124	54	41	34	38	39	23	25	54	75	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.7	29.5	28.9	26.7	25.4	23.4	23.0	23.8	25.1	26.6	28.1	29.2	(19)
(20)			MCWB	25.2	24.6	25.0	22.4	21.7	20.3	19.3	19.8	20.1	21.2	23.0	23.7	(20)
(21)		2%	DB	28.8	28.8	28.2	26.0	24.4	22.5	22.0	22.6	24.2	25.7	27.2	28.5	(21)
(22)			MCWB	24.6	24.4	24.4	22.0	20.8	19.8	18.7	18.8	19.9	21.3	22.6	23.6	(22)
(23)		5%	DB	28.3	28.2	27.6	25.4	23.8	21.9	21.3	21.9	23.6	25.1	26.6	28.0	(23)
(24)			MCWB	24.3	24.4	24.0	21.8	20.3	19.4	18.6	18.3	19.6	20.9	22.2	23.4	(24)
(25)		10%	DB	27.7	27.6	26.9	24.9	23.1	21.2	20.7	21.2	22.9	24.5	26.1	27.4	(25)
(26)			MCWB	23.9	24.3	23.6	21.5	19.9	18.9	18.4	18.0	19.2	20.5	21.8	23.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.7	26.7	26.6	24.1	22.9	21.6	21.2	21.4	22.7	23.7	25.0	26.5	(27)
(28)			MADB	27.9	27.8	27.4	25.1	24.2	22.2	21.7	22.1	23.6	24.6	26.2	27.1	(28)
(29)		2%	WB	26.1	26.1	25.8	23.5	21.9	20.6	20.3	20.3	21.7	22.8	24.3	25.5	(29)
(30)			MADB	27.5	27.2	26.7	24.6	23.5	21.7	20.9	21.4	22.7	24.1	25.9	26.6	(30)
(31)		5%	WB	25.5	25.6	25.2	23.0	21.2	20.0	19.8	19.7	21.0	22.2	23.5	24.9	(31)
(32)			MADB	27.0	26.8	26.2	24.3	22.8	21.2	20.4	20.9	22.3	23.7	25.4	26.3	(32)
(33)		10%	WB	25.0	25.1	24.6	22.5	20.6	19.4	19.2	19.0	20.3	21.7	22.8	24.3	(33)
(34)			MADB	26.5	26.5	25.8	24.0	22.4	20.7	20.0	20.3	21.8	23.3	24.9	26.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	3.7	3.5	3.2	3.1	3.1	2.9	3.0	3.7	4.1	4.1	4.1	4.0	(35)
(36)			MCDBR	4.2	4.1	3.9	3.5	3.4	3.3	3.3	4.3	4.6	4.5	4.5	4.5	(36)
(37)			MCWBR	2.0	2.1	1.9	2.1	2.4	2.3	2.3	2.6	2.4	2.3	2.1	2.1	(37)
(38)		5% WB	MCDDBR	3.8	3.8	3.3	3.2	3.2	3.0	2.8	3.7	4.0	4.0	4.2	3.8	(38)
(39)			MCWBR	2.2	2.3	2.1	2.1	2.7	2.5	2.6	2.8	2.4	2.4	2.3	2.3	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.389	0.384	0.373	0.347	0.328	0.321	0.309	0.314	0.339	0.364	0.367	0.379	(40)
(41)		taud		2.567	2.588	2.605	2.666	2.671	2.684	2.700	2.673	2.581	2.535	2.567	2.568	(41)
(42)		Ebn at Noon		956	948	933	920	900	888	913	940	951	955	970	966	(42)
(43)		Edh at Noon		108	104	98	86	79	75	76	84	99	109	108	108	(43)
(44)	All-Sky Solar Radiation	RadAvg		6.63	6.16	5.62	4.94	4.22	3.72	4.20	5.09	6.18	6.84	7.10	7.07	(44)
(45)		RadStd		0.41	0.68	0.49	0.42	0.23	0.35	0.29	0.32	0.38	0.36	0.70	0.69	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page