

YEPPOON THE ESPLANADE, Australia

WMO: 943730

Lat: 23.1364S

Lon: 150.7506E

Elev: 19

StdP: 14.69

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	46.0	48.5	32.3	26.7	60.7	36.3	31.4	57.0	18.1	66.7	16.4	67.0	7.5	270	0.433

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.9	86.9	77.5	85.5	77.1	84.5	76.4	80.4	84.5	79.2	83.5	78.3	82.7	12.6	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.3	152.1	82.9	78.0	145.5	82.3	76.9	140.3	81.6	44.2	84.7	42.9	83.5	41.8	82.8	92.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
25.2	21.2	18.8	DB	41.0	93.5	1.5	3.7	39.8	96.2	38.9	98.4	38.1	100.5	37.0	103.2
			WB	38.4	84.0	2.0	3.1	37.0	86.2	35.8	88.0	34.7	89.7	33.3	92.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	71.7	79.6	79.4	77.6	73.5	67.8	63.6	61.9	63.1	67.7	72.3	75.8	78.3
	DBStd	7.15	2.28	2.49	2.55	2.86	3.96	4.33	4.02	3.82	3.52	3.12	2.48	2.50
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	302	0	0	0	1	22	74	111	79	14	1	0	0
	CDD50	7911	918	823	856	705	552	409	368	407	531	691	775	876
	CDD65	2736	453	403	391	256	108	33	13	21	95	227	325	411
	CDH74	19691	4428	3896	3281	1342	206	16	11	27	214	820	1943	3507
	CDH80	3131	911	859	475	57	2	1	1	2	22	45	170	586
Wind	WSAvg	10.3	12.9	11.9	11.3	10.1	8.5	7.8	7.6	8.2	9.5	11.7	12.4	12.4
Precipitation	PrecAvg	48.0	6.6	7.9	6.9	4.4	4.3	2.1	1.7	1.4	1.0	2.1	3.0	6.4
	PrecMax	95.1	37.0	24.0	38.2	17.6	17.2	11.7	7.4	7.6	6.2	9.0	8.2	24.1
	PrecMin	27.1	0.4	0.7	0.3	0.9	0.2	0.0	0.0	0.0	0.0	0.0	0.0	1.1
	PrecStd	14.5	6.1	6.1	7.4	3.6	3.8	2.4	1.9	1.6	1.2	2.0	2.1	5.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	88.3	88.6	86.3	83.5	79.3	75.7	75.1	77.2	83.7	85.6	87.9	89.4
		MCWB	79.7	78.9	77.6	74.3	69.8	66.7	63.2	65.6	68.7	71.0	70.8	76.6
	2%	DB	86.2	86.5	84.7	81.5	77.4	73.6	72.0	73.8	78.0	80.6	83.0	85.5
		MCWB	78.7	78.0	76.4	72.8	69.2	66.9	64.6	66.0	68.4	72.4	73.9	76.7
	5%	DB	85.1	85.4	83.7	80.3	76.2	72.3	70.7	72.3	76.0	79.1	81.7	84.1
		MCWB	77.7	77.2	75.7	72.2	68.6	66.0	64.0	65.4	68.2	71.8	73.6	76.2
	10%	DB	83.9	84.2	82.6	79.2	75.0	71.1	69.6	71.0	74.7	77.8	80.5	82.9
		MCWB	76.7	76.3	75.0	71.5	67.8	65.0	63.2	64.4	67.5	70.7	72.7	75.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	83.6	81.4	80.4	77.7	74.6	71.2	69.2	70.5	73.5	76.5	79.1	81.2
		MCDB	84.6	85.8	83.9	81.3	76.7	73.2	71.5	73.8	77.4	79.8	81.6	84.7
	2%	WB	80.7	79.8	78.6	75.7	72.4	69.4	67.8	68.7	71.9	74.9	76.8	79.2
		MCDB	84.4	84.7	82.7	79.1	75.4	71.8	70.3	72.1	75.5	78.7	80.7	83.7
	5%	WB	79.2	78.8	77.5	74.1	70.7	67.9	66.4	67.3	70.6	73.5	75.5	77.9
		MCDB	83.3	83.7	81.8	78.3	74.8	71.1	69.1	70.9	74.3	77.6	80.0	82.4
	10%	WB	78.1	77.8	76.5	72.9	69.4	66.6	65.0	65.9	69.2	72.2	74.3	76.7
		MCDB	82.5	82.7	81.1	77.8	73.7	69.9	68.3	69.7	73.3	76.6	79.2	81.4
Mean Daily Temperature Range	5% DB	MDBR	7.9	8.2	8.9	10.7	13.4	13.7	15.4	15.5	13.8	10.5	8.9	8.5
		MCDBR	9.2	9.7	9.8	11.7	13.7	13.5	15.7	16.4	15.6	12.2	10.9	10.2
		MCWBR	5.2	4.7	5.2	6.0	7.7	8.1	9.7	10.3	9.2	6.9	6.1	5.5
	5% WB	MCDBR	9.4	9.4	8.9	10.1	11.4	11.0	11.9	13.7	13.4	11.2	10.1	9.9
		MCWBR	6.3	5.2	5.5	6.2	7.5	7.5	8.3	9.6	9.2	7.6	6.7	6.4
Clear-Sky Solar Irradiance	taub	0.398	0.392	0.376	0.354	0.332	0.321	0.312	0.321	0.355	0.380	0.396	0.396	
	taud	2.507	2.529	2.562	2.601	2.615	2.644	2.647	2.606	2.502	2.465	2.448	2.486	
	Ebn at Noon	300	298	294	288	282	279	286	294	296	298	299	301	
	Edh at Noon	36	35	32	29	26	24	25	28	34	37	38	37	
All-Sky Solar Radiation	RadAvg	2094	1945	1758	1531	1311	1138	1286	1557	1897	2100	2200	2188	
	RadStd	141	209	145	134	70	95	97	105	138	134	219	214	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page