

YEPPON THE ESPLANADE, Australia

WMO: 943730

Lat: 23.1364S

Lon: 150.7506E

Elev: 6

StdP: 101.26

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.8	9.2	0.1	3.8	16.0	2.4	4.5	13.9	8.1	19.3	7.3	19.4	3.3	270	0.433

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.4	30.5	25.3	29.7	25.1	29.2	24.7	26.9	29.1	26.2	28.6	25.7	28.2	5.6	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.3	21.7	28.3	25.6	20.8	27.9	25.0	20.0	27.6	84.9	29.3	81.9	28.6	79.5	28.2	33.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.3	9.5	8.4	5.0	34.2	0.9	2.1	4.4	35.7	3.9	36.9	3.4	38.0	2.8	39.6		
(5)			3.6	28.9	1.1	1.7	2.8	30.1	2.1	31.1	1.5	32.1	0.7	33.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	22.0	26.5	26.3	25.3	23.1	19.9	17.6	16.6	17.3	19.8	22.4	24.3	25.7		
	DBStd	3.97	1.27	1.38	1.41	1.59	2.20	2.40	2.23	2.12	1.95	1.74	1.38	1.39		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	168	0	0	0	1	12	41	62	44	8	1	0	0		
	CDD10.0	4395	510	457	476	392	307	227	204	226	295	384	431	487		
	CDD18.3	1520	252	224	217	142	60	18	7	12	53	126	181	228		
	CDH23.3	10939	2460	2164	1823	746	114	9	6	15	119	456	1079	1948		
	CDH26.7	1739	506	477	264	32	1	1	1	1	12	25	94	326		
(14) Wind	WSAvg	4.6	5.8	5.3	5.1	4.5	3.8	3.5	3.4	3.7	4.2	5.2	5.5	5.5		
(15) Precipitation	PrecAvg	1220	167	201	174	111	108	53	43	35	26	54	77	163		
	PrecMax	2415	941	609	970	448	437	298	187	194	158	228	208	611		
	PrecMin	689	9	18	7	22	4	0	0	0	0	0	0	29		
	PrecStd	368	154	156	188	92	96	62	48	41	31	50	54	137		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.3	31.4	30.2	28.6	26.3	24.3	24.0	25.1	28.7	29.8	31.1	31.9		
		MCWB	26.5	26.0	25.3	23.5	21.0	19.3	17.3	18.7	20.4	21.7	21.6	24.8		
	2%	DB	30.1	30.3	29.3	27.5	25.2	23.1	22.2	23.2	25.5	27.0	28.3	29.7		
		MCWB	25.9	25.6	24.6	22.7	20.7	19.4	18.1	18.9	20.2	22.4	23.3	24.8		
	5%	DB	29.5	29.7	28.7	26.8	24.6	22.4	21.5	22.4	24.4	26.2	27.6	28.9		
		MCWB	25.4	25.1	24.3	22.3	20.3	18.9	17.8	18.5	20.1	22.1	23.1	24.6		
	10%	DB	28.9	29.0	28.1	26.2	23.9	21.7	20.9	21.7	23.7	25.5	27.0	28.3		
		MCWB	24.8	24.6	23.9	21.9	19.9	18.4	17.3	18.0	19.7	21.5	22.6	24.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.7	27.5	26.9	25.4	23.7	21.8	20.7	21.4	23.0	24.7	26.2	27.4		
		MCDB	29.2	29.9	28.8	27.4	24.8	22.9	21.9	23.2	25.2	26.6	27.6	29.3		
	2%	WB	27.1	26.6	25.9	24.3	22.5	20.8	19.9	20.4	22.2	23.8	24.9	26.2		
		MCDB	29.1	29.3	28.2	26.2	24.1	22.1	21.3	22.3	24.1	26.0	27.1	28.7		
	5%	WB	26.2	26.0	25.3	23.4	21.5	20.0	19.1	19.6	21.4	23.0	24.2	25.5		
		MCDB	28.5	28.7	27.7	25.7	23.8	21.7	20.6	21.6	23.5	25.3	26.7	28.0		
	10%	WB	25.6	25.5	24.7	22.7	20.8	19.2	18.3	18.8	20.7	22.3	23.5	24.8		
		MCDB	28.0	28.2	27.3	25.4	23.2	21.1	20.2	20.9	22.9	24.8	26.2	27.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.4	4.6	5.0	6.0	7.4	7.6	8.5	8.6	7.7	5.8	5.0	4.7		
		MCDBR	5.1	5.4	5.5	6.5	7.6	7.5	8.7	9.1	8.7	6.8	6.1	5.6		
		MCWBR	2.9	2.6	2.9	3.3	4.3	4.5	5.4	5.7	5.1	3.8	3.4	3.1		
	5% WB	MCDBR	5.2	5.2	5.0	5.6	6.4	6.1	6.6	7.6	7.4	6.2	5.6	5.5		
		MCWBR	3.5	2.9	3.1	3.4	4.2	4.2	4.6	5.3	5.1	4.2	3.7	3.6		
(40) Clear-Sky Solar Irradiance	taub		0.398	0.392	0.376	0.354	0.332	0.321	0.312	0.321	0.355	0.380	0.396	0.396		
	taud		2.507	2.529	2.562	2.601	2.615	2.644	2.647	2.606	2.502	2.465	2.448	2.486		
	Ebn at Noon		947	939	928	907	890	881	903	928	933	939	942	949		
	Edh at Noon		115	110	102	91	82	77	78	89	106	116	121	117		
(44) All-Sky Solar Radiation	RadAvg		6.60	6.13	5.54	4.83	4.13	3.59	4.05	4.91	5.98	6.62	6.93	6.90		
	RadStd		0.44	0.66	0.46	0.42	0.22	0.30	0.31	0.33	0.43	0.42	0.69	0.68		

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (11 neighbors)		(m)								
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page