

ROCKHAMPTON, Australia

WMO: 943740

Lat: 23.3753S

Lon: 150.4775E

Elev: 50

StdP: 14.67

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	43.4	46.2	21.0	15.8	71.2	26.4	20.4	68.6	18.6	67.2	16.8	68.0	1.7	190	0.368

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.9	96.2	72.9	93.4	72.6	91.2	72.1	78.3	86.4	77.4	84.9	76.4	83.8	9.8	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.5	138.6	80.8	75.4	133.4	80.3	74.5	129.4	79.9	41.9	86.4	40.9	85.1	40.0	83.8	91.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
17.5	16.0	14.4	DB	39.0	102.3	1.7	2.7	37.8	104.3	36.8	105.9	35.8	107.4	34.5	109.4
			WB	36.5	81.0	2.1	2.4	35.0	82.7	33.7	84.1	32.6	85.4	31.0	87.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	73.1	81.1	80.5	78.7	74.6	68.8	64.2	62.7	64.7	70.2	74.6	77.7	80.3	(6)
	DBStd	7.57	3.32	3.28	3.00	3.10	4.14	4.58	4.35	4.22	4.00	3.95	3.67	3.71	(7)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD65	241	0	0	0	0	15	69	97	55	5	0	0	0	(9)
	CDD50	8443	965	853	891	737	583	427	393	457	606	762	830	939	(10)
	CDD65	3210	500	433	426	288	133	46	25	47	161	297	380	474	(11)
	CDH74	27269	4943	4068	3527	1845	739	203	152	420	1339	2268	3234	4531	(12)
	CDH80	9698	1959	1526	1205	455	90	12	6	65	383	815	1283	1899	(13)
(14) Wind	WSAvg	7.3	8.4	8.4	8.1	7.5	6.5	6.1	5.9	6.2	6.7	7.6	7.9	8.2	(14)
(15) Precipitation	PrecAvg	31.9	4.4	5.2	4.0	1.7	1.9	1.4	1.1	1.0	1.1	1.9	2.8	4.5	(15)
	PrecMax	64.2	26.0	19.8	17.6	7.8	12.0	7.3	5.4	4.2	5.7	7.8	11.8	21.0	(16)
	PrecMin	15.5	0.1	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	(17)
	PrecStd	11.0	4.3	4.6	4.1	1.7	2.2	1.6	1.4	1.0	1.3	1.7	2.0	4.3	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	100.0	97.4	95.1	90.0	85.6	81.6	80.6	85.8	91.9	95.3	97.4	100.1	(19)
		MCWB	74.8	75.5	73.1	69.5	66.3	64.7	62.8	62.7	65.0	67.9	69.4	72.3	(20)
	2%	DB	95.0	93.4	91.1	86.4	82.4	78.6	77.6	81.2	87.7	91.0	93.1	95.1	(21)
		MCWB	75.3	74.7	73.5	69.0	65.3	63.4	61.3	62.1	64.7	68.2	70.3	73.2	(22)
	5%	DB	91.4	90.6	88.2	84.4	80.3	76.3	75.4	78.5	84.3	87.8	89.9	91.9	(23)
		MCWB	74.3	74.1	72.6	68.3	64.6	62.6	60.4	60.9	63.8	68.3	69.9	72.7	(24)
	10%	DB	88.6	87.9	86.1	82.6	78.5	74.0	73.4	75.6	81.2	84.4	87.1	89.2	(25)
		MCWB	73.6	73.7	72.0	68.2	63.8	61.6	59.6	59.8	63.1	67.3	69.4	72.0	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.6	79.6	79.2	75.7	72.7	70.2	69.1	69.1	71.7	74.4	76.3	78.5	(27)
		MCDB	89.2	87.6	86.2	81.8	78.3	74.7	74.3	77.8	80.2	85.4	85.0	87.6	(28)
	2%	WB	78.2	78.2	77.3	74.0	70.4	67.6	66.8	66.9	69.8	72.6	74.5	77.1	(29)
		MCDB	86.7	85.7	83.8	79.8	76.5	72.9	72.3	75.2	77.8	82.1	84.5	86.4	(30)
	5%	WB	77.2	77.2	76.1	72.3	68.7	66.0	64.8	64.9	68.2	71.3	73.3	76.0	(31)
		MCDB	84.7	84.2	82.4	78.9	75.3	72.3	70.3	72.9	77.2	80.5	83.3	84.7	(32)
	10%	WB	76.2	76.2	75.0	71.0	67.1	64.5	62.9	63.2	66.8	70.1	72.2	74.8	(33)
		MCDB	83.6	83.0	81.2	78.1	74.1	70.8	69.2	71.3	75.9	79.1	81.7	83.1	(34)
(35) Mean Daily Temperature Range	MDBR		15.9	15.1	15.9	17.3	19.8	20.2	22.5	23.7	23.5	20.4	18.8	17.6	(35)
	5% DB	MCDBR	20.4	19.0	19.0	19.6	21.8	21.9	24.1	27.5	28.1	25.2	23.5	22.3	(36)
		MCWBR	5.8	5.5	5.9	6.5	8.2	9.3	10.7	11.1	10.0	8.1	6.8	6.4	(37)
	5% WB	MCDBR	16.9	15.9	15.2	15.7	16.4	16.3	17.5	22.2	22.3	20.9	19.7	18.4	(38)
		MCWBR	5.7	5.6	5.7	6.2	6.8	7.7	8.9	9.9	8.8	7.4	6.3	6.4	(39)
(40) Clear-Sky Solar Irradiance	taub		0.395	0.387	0.371	0.351	0.327	0.318	0.308	0.320	0.354	0.380	0.395	0.398	(40)
	taud		2.495	2.524	2.558	2.588	2.605	2.631	2.632	2.585	2.484	2.444	2.434	2.461	(41)
	Ebn at Noon		301	299	296	288	284	280	287	294	296	298	299	301	(42)
	Edh at Noon		37	35	32	29	26	24	25	29	34	38	39	38	(43)
(44) All-Sky Solar Radiation	RadAvg		2086	1952	1760	1543	1323	1145	1289	1556	1892	2095	2189	2178	(44)
	RadStd		150	206	143	142	71	92	101	108	149	142	234	227	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	+1.39	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (11 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page