

RUNDLE ISLAND, Australia

WMO: 943780

Lat: 23.532S

Lon: 151.277E

Elev: 67

StdP: 14.66

Time Zone: 10.00 (E10)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 57.3	(c) 59.2	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 34.5	(k) 64.9	(l) 32.0	(m) 65.4	(n) 16.4	(o) 200	(p) 0.621

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 2	(b) 4.3	(c) 84.5	(d) N/A	(e) 83.5	(f) N/A	(g) 82.7	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 12.2	(p) 0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 35.5	(b) 32.2	(c) 29.6	(e) 53.7	(f) 87.4	(g) 2.2	(h) 2.2	(i) 52.1	(j) 88.9	(k) 50.8	(l) 90.2	(m) 49.5	(n) 91.4	(o) 47.9	(p) 93.0		
			DB		WB											
			53.7		87.4		2.2		2.2		52.1		88.9		50.8	
			N/A		N/A		N/A		N/A		N/A		N/A		N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	72.9	79.3	79.4	78.0	74.6	70.5	66.5	64.8	65.9	69.7	72.9	75.5	78.3
	DBStd	5.66	2.15	2.21	2.21	2.08	2.64	3.01	2.40	2.41	2.41	2.11	2.19	2.18
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	70	0	0	0	0	2	19	31	17	1	0	0	0
	CDD50	8367	908	824	868	739	636	495	460	493	591	710	766	877
	CDD65	2963	443	404	403	289	173	64	26	45	143	245	316	412
	CDH74	17075	4022	3746	3149	1080	126	3	1	1	36	341	1337	3233
	CDH80	1518	497	517	218	14	0	0	0	0	0	2	27	243
(14) Wind	WSAvg	16.7	19.6	19.1	19.4	18.6	16.4	15.9	14.4	14.1	14.2	15.7	16.2	16.8
(15) Precipitation	PrecAvg	33.4	5.5	6.2	4.0	2.0	1.5	1.6	1.2	1.2	1.1	1.7	2.7	4.6
	PrecMax	62.6	20.9	22.4	15.0	9.4	5.1	6.1	6.4	5.2	4.7	7.4	6.9	16.7
	PrecMin	21.3	0.1	1.5	0.3	0.1	0.2	0.3	0.1	0.0	0.0	0.0	0.1	0.2
	PrecStd	8.6	4.3	5.0	3.9	2.3	1.3	1.5	1.6	1.2	1.4	1.6	2.0	3.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	85.6	86.5	84.5	81.8	77.9	74.2	71.9	73.3	76.9	79.4	82.8	84.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	84.2	84.8	83.0	79.7	76.4	72.7	70.1	71.8	74.9	77.7	80.4	83.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	83.2	83.7	82.0	78.7	75.4	71.9	69.2	70.7	73.8	76.7	79.4	82.1
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	82.5	82.7	81.2	77.8	74.5	70.9	68.6	69.6	72.9	75.9	78.5	81.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	5% DB	MDBR	4.2	4.3	4.2	4.7	5.5	5.9	6.1	5.5	4.6	4.3	4.3	4.1
		MCDBR	4.9	5.2	4.7	5.0	5.8	5.7	6.3	6.3	5.8	5.1	5.4	4.8
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.395	0.390	0.377	0.349	0.328	0.321	0.310	0.319	0.353	0.376	0.388	0.392
	taud		2.537	2.558	2.580	2.646	2.650	2.668	2.678	2.637	2.531	2.497	2.494	2.520
	Ebn at Noon		301	298	294	289	283	279	287	295	297	299	301	302
	Edh at Noon		35	34	32	28	25	24	24	27	33	36	37	36
(44) All-Sky Solar Radiation	RadAvg		2124	1967	1759	1533	1299	1125	1276	1549	1885	2094	2215	2209
	RadStd		136	207	149	126	70	90	95	101	134	134	189	198

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page