

RUNDLE ISLAND, Australia

WMO: 943780

Lat: 23.532S

Lon: 151.277E

Elev: 20

StdP: 101.08

Time Zone: 10.00 (E10)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 14.1	(c) 15.1	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 15.4	(k) 18.3	(l) 14.3	(m) 18.5	(n) 7.3	(o) 200	(p) 0.621

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 2	(b) 2.4	(c) 29.2	(d) N/A	(e) 28.6	(f) N/A	(g) 28.2	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 5.4	(p) 0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 15.9	(b) 14.4	(c) 13.2	(e) 12.0	(f) 30.8	(g) 1.2	(h) 1.2	(i) 11.1	(j) 31.6	(k) 10.4	(l) 32.3	(m) 9.7	(n) 33.0	(o) 8.8	(p) 33.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	22.7	26.3	26.4	25.6	23.7	21.4	19.2	18.2	18.8	21.0	22.7	24.2	25.7		
	DBStd	3.15	1.20	1.23	1.23	1.16	1.46	1.67	1.33	1.34	1.34	1.17	1.22	1.21		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	39	0	0	0	0	1	11	17	9	1	0	0	0		
	CDD10.0	4648	504	458	482	411	353	275	256	274	328	394	426	487		
	CDD18.3	1646	246	224	224	161	96	36	14	25	79	136	176	229		
	CDH23.3	9486	2234	2081	1749	600	70	2	1	1	20	189	743	1796		
	CDH26.7	843	276	287	121	8	0	0	0	0	1	15	135			
(14) Wind	WSAvg	7.5	8.7	8.5	8.7	8.3	7.3	7.1	6.4	6.3	6.4	7.0	7.3	7.5		
(15) Precipitation	PrecAvg	849	140	158	102	52	37	41	30	30	29	43	69	116		
	PrecMax	1589	531	568	381	238	129	156	163	131	120	188	175	423		
	PrecMin	542	2	38	8	3	4	7	2	0	0	1	3	5		
	PrecStd	219	110	127	100	59	34	39	41	31	35	41	50	84		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.8	30.3	29.2	27.7	25.5	23.4	22.2	22.9	25.0	26.3	28.2	29.3		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	29.0	29.3	28.3	26.5	24.6	22.6	21.2	22.1	23.8	25.4	26.9	28.3		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	28.5	28.7	27.8	25.9	24.1	22.1	20.7	21.5	23.2	24.9	26.3	27.9		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	28.0	28.2	27.3	25.5	23.6	21.6	20.3	20.9	22.7	24.4	25.9	27.4		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	2.3	2.4	2.3	2.6	3.0	3.3	3.4	3.1	2.6	2.4	2.4	2.3		
		MCDBR	2.7	2.9	2.6	2.8	3.2	3.2	3.5	3.5	3.2	2.9	3.0	2.7		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.395	0.390	0.377	0.349	0.328	0.321	0.310	0.319	0.353	0.376	0.388	0.392		
	taud		2.537	2.558	2.580	2.646	2.650	2.668	2.678	2.637	2.531	2.497	2.494	2.520		
	Ebn at Noon		950	941	926	912	892	880	905	929	935	942	950	953		
	Edh at Noon		111	107	100	87	79	75	76	86	103	112	116	114		
(44) All-Sky Solar Radiation	RadAvg		6.70	6.20	5.54	4.83	4.09	3.55	4.02	4.88	5.94	6.60	6.98	6.96		
	RadStd		0.43	0.65	0.47	0.40	0.22	0.28	0.30	0.32	0.42	0.42	0.60	0.62		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page