

GANNET CAY, Australia

WMO: 943790

Lat: 21.980S

Lon: 152.473E

Elev: 8

StdP: 101.22

Time Zone: 10.00 (E10)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	17.7	18.5	N/A	N/A	N/A	N/A	N/A	N/A	14.5	20.6	13.9	20.6	8.3	180	0.512

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	1.5	28.6	N/A	28.2	N/A	28.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	4.7	110

Dehumidification DP/MCDB and HR

DP	HR	MCDB	1%			2%			0.4%			1%			Extreme Max WB	
			DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB		
			(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	(o)	(p)
14.8	13.7	12.8	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)	(r)
			DB	16.3	29.8	0.9	0.8	15.7	30.4	15.1	30.9	14.6	31.3	14.0	31.9	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	24.0	26.6	26.8	26.3	25.1	23.5	21.9	21.0	21.0	22.0	23.3	24.6	25.9	
	DBStd	2.30	0.85	0.87	0.86	0.82	1.05	1.27	1.21	1.02	0.95	0.92	0.86	0.92	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD18.3	1	0	0	0	0	0	1	1	0	0	0	0	0	
	CDD10.0	5111	514	471	506	454	420	358	342	342	359	412	439	493	
	CDD18.3	2069	256	238	248	204	162	108	84	83	109	154	189	234	
	CDH23.3	12432	2487	2419	2320	1401	472	55	6	2	25	287	999	1960	
	CDH26.7	907	271	339	188	13	1	0	0	0	0	0	2	93	
Wind		WSAvg	7.1	7.4	7.7	8.3	8.6	7.6	7.0	6.4	5.9	6.0	6.4	6.8	
Precipitation	PrecAvg	840	126	148	134	72	53	50	34	32	20	30	43	99	
	PrecMax	1503	331	520	521	218	236	147	178	167	111	103	231	347	
	PrecMin	375	28	20	12	8	11	10	3	1	1	2	6	17	
	PrecStd	250	74	101	124	54	41	34	38	39	23	25	54	75	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.7	29.5	28.7	27.6	26.5	24.7	23.9	23.6	24.6	26.0	27.1	28.4	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	2%	DB	28.4	28.7	28.2	27.1	25.7	24.3	23.4	23.1	24.0	25.4	26.6	27.9	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5%	DB	28.1	28.3	27.9	26.7	25.3	24.0	23.0	22.7	23.6	25.0	26.2	27.6	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	10%	DB	27.8	28.1	27.6	26.4	25.0	23.6	22.6	22.3	23.2	24.6	25.8	27.2	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Mean Daily Temperature Range	5% DB	MDBR	1.4	1.5	1.5	1.5	1.6	1.8	1.7	1.6	1.5	1.4	1.3	1.4	
		MCDBR	1.6	1.7	1.7	1.8	1.8	1.9	1.8	1.8	1.6	1.7	1.7	1.7	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Clear-Sky Solar Irradiance	taub	0.390	0.389	0.380	0.354	0.336	0.333	0.319	0.324	0.346	0.368	0.374	0.380		
	taud	2.568	2.582	2.599	2.652	2.656	2.660	2.683	2.652	2.570	2.533	2.548	2.575		
	Ebn at Noon	955	942	926	911	891	873	901	928	944	952	964	965		
	Edh at Noon	108	105	99	87	80	77	77	85	100	109	110	107		
All-Sky Solar Radiation	RadAvg	6.99	6.45	5.76	5.07	4.30	3.72	4.14	5.11	6.25	6.95	7.38	7.32		
	RadStd	0.35	0.74	0.52	0.34	0.25	0.32	0.25	0.30	0.28	0.37	0.60	0.56		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page