

SEVENTEEN SEVENTY, Australia

WMO: 943840

Lat: 24.157S

Lon: 151.887E

Elev: 155

StdP: 14.61

Time Zone: 10.00 (E10)

Period: 94-12

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	52.7	55.3	30.9	25.3	59.4	33.6	28.4	65.9	30.9	63.8	27.9	64.9	9.6	230	0.419

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	8.9	86.3	78.0	85.3	77.5	84.4	76.8	80.3	84.1	79.4	83.3	78.7	82.6	10.2	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.2	152.3	82.8	78.3	147.8	82.3	77.4	143.4	81.8	44.1	84.2	43.2	83.4	42.4	82.5	85.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
31.2	28.3	23.4		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	72.0	78.8	79.3	77.0	73.4	69.0	65.1	63.6	64.3	68.9	72.1	75.6	77.9
	DBStd	6.23	2.66	2.82	2.55	2.83	2.44	3.50	2.71	2.93	2.99	2.86	2.71	2.89
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	152	0	0	0	0	3	39	58	46	6	0	0	0
	CDD50	8044	892	821	836	703	589	453	423	443	566	685	767	866
	CDD65	2722	427	401	371	253	127	43	16	24	122	220	317	401
	CDH74	16755	3797	3657	2655	1006	104	11	2	1	100	553	1650	3219
	CDH80	2593	746	790	330	61	0	0	0	0	0	12	110	544
Wind	WSAvg	11.5	13.3	12.7	13.4	12.9	10.5	10.1	9.8	10.3	9.8	11.4	11.3	12.1
Precipitation	PrecAvg	41.7	6.5	7.3	4.9	3.6	2.8	2.3	1.5	1.5	1.7	2.2	2.8	4.9
	PrecMax	73.9	24.1	21.7	14.3	15.3	7.0	7.0	4.9	5.6	6.2	5.6	6.5	19.6
	PrecMin	29.7	0.3	1.8	0.6	0.3	0.3	0.5	0.0	0.0	0.0	0.1	0.0	0.7
	PrecStd	9.8	4.8	4.9	3.9	3.3	1.9	2.0	1.5	1.5	1.7	1.2	1.7	3.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	87.3	88.6	86.1	83.6	77.8	75.3	73.5	73.6	77.6	81.5	84.5	86.8
		MCWB	79.3	79.0	77.6	75.3	67.9	68.3	64.9	64.5	68.0	72.1	72.8	76.8
	2%	DB	85.9	86.8	84.7	81.4	76.5	73.5	71.4	71.9	76.5	79.5	82.4	85.3
		MCWB	78.4	78.4	76.9	73.2	68.5	67.3	63.9	64.7	68.1	71.8	71.5	77.1
	5%	DB	84.9	85.5	83.5	80.0	75.4	72.0	70.1	71.0	75.4	78.3	81.3	84.2
		MCWB	77.7	77.6	76.0	72.3	68.1	66.2	62.8	64.1	67.7	70.8	70.9	76.9
	10%	DB	83.8	84.3	82.2	78.6	74.2	70.9	68.9	69.8	74.3	77.1	80.3	83.1
		MCWB	77.0	76.7	74.9	71.8	67.4	65.3	62.0	63.1	67.2	69.3	70.4	76.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.8	81.1	80.9	78.3	73.3	71.9	69.1	69.0	73.0	75.7	77.1	80.5
		MCDB	85.3	85.8	83.7	81.6	75.3	74.1	71.1	71.4	75.0	78.9	80.8	83.9
	2%	WB	80.3	80.0	79.2	75.8	72.0	69.5	66.9	67.3	71.4	74.5	75.5	79.6
		MCDB	84.1	84.5	82.6	79.3	74.3	72.0	69.2	70.1	73.6	77.6	79.5	83.1
	5%	WB	79.3	79.1	77.9	74.3	70.7	68.1	65.4	66.3	70.2	73.3	74.6	78.7
		MCDB	83.0	83.5	81.7	78.2	73.5	71.0	68.5	69.0	73.3	76.5	79.0	82.5
	10%	WB	78.4	78.2	76.5	73.0	69.5	66.8	64.0	65.2	69.2	72.0	73.5	77.7
		MCDB	82.2	82.6	80.7	77.1	73.0	69.8	67.7	68.2	72.7	75.6	78.6	81.8
Mean Daily Temperature Range	5% DB	MDBR	8.9	8.9	9.4	9.9	10.2	10.0	10.9	10.8	10.2	9.2	9.0	8.8
		MCDBR	9.2	9.5	9.9	10.6	10.7	10.0	11.3	11.1	10.3	9.1	9.3	8.7
		MCWBR	5.2	4.7	5.2	6.3	6.7	6.8	7.8	7.6	6.2	5.7	5.1	5.3
	5% WB	MCDBR	8.6	8.7	8.3	9.2	8.5	8.0	9.8	8.9	8.5	8.3	7.9	7.8
		MCWBR	5.8	5.0	5.5	6.0	6.3	5.9	7.6	6.3	5.9	6.2	4.6	5.2
Clear-Sky Solar Irradiance	taub	0.392	0.387	0.371	0.346	0.327	0.319	0.307	0.319	0.350	0.375	0.376	0.395	
	taud	2.532	2.554	2.590	2.642	2.641	2.661	2.674	2.623	2.527	2.492	2.523	2.499	
	Ebn at Noon	302	299	295	290	283	279	287	294	297	299	305	302	
	Edh at Noon	36	34	31	28	25	24	24	28	33	36	36	37	
All-Sky Solar Radiation	RadAvg	2111	1944	1727	1515	1277	1105	1251	1532	1862	2047	2183	2181	
	RadStd	149	201	147	120	71	87	96	104	135	150	200	211	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page