

HERON ISLAND, Australia

WMO: 943860

Lat: 23.442S

Lon: 151.913E

Elev: 19

StdP: 14.69

Time Zone: 10.00 (E10)

Period: 94-07

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	58.6	60.7	41.9	39.2	63.3	44.3	43.0	64.1	36.2	65.6	31.2	66.2	11.5	190	0.521

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.9	88.4	78.3	87.2	77.5	86.0	76.8	80.5	85.0	79.4	84.0	78.6	83.3	10.2	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.2	151.8	83.2	78.1	146.3	82.7	77.2	141.5	82.3	44.2	85.3	43.1	84.3	42.2	83.4	84.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
29.4	26.9	24.7	55.2	90.1	1.2	1.9	54.3	91.5	53.6	92.7	52.9	93.8	52.0	95.2
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	74.8	81.2	81.1	79.9	76.7	72.2	68.9	67.0	68.4	71.5	74.3	77.1	79.5	(6)
	DBStd	5.56	2.34	2.61	2.00	2.58	2.89	3.48	2.58	2.64	2.25	2.13	2.27	2.63	(7)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD65	29	0	0	0	0	3	9	12	5	0	0	0	0	(9)
	CDD50	9045	969	870	926	801	687	567	528	569	646	754	812	916	(10)
	CDD65	3598	504	450	461	351	224	126	75	109	196	289	362	451	(11)
	CDH74	22920	5016	4431	4023	1941	362	77	4	38	307	916	2050	3755	(12)
	CDH80	4417	1315	1122	701	163	2	0	0	0	1	37	265	811	(13)
(14) Wind	WSAvg	13.6	13.7	14.0	14.5	14.5	14.3	14.8	14.1	13.7	12.1	12.5	12.4	13.2	(14)
(15) Precipitation	PrecAvg	36.9	3.9	5.2	3.7	4.9	3.3	4.0	2.5	2.0	1.0	1.7	1.5	3.1	(15)
	PrecMax	56.2	9.8	19.5	10.8	25.5	5.8	15.2	5.2	6.0	2.3	3.8	7.0	10.9	(16)
	PrecMin	22.3	1.1	0.4	1.1	0.2	0.9	0.9	0.6	0.2	0.0	0.3	0.3	0.9	(17)
	PrecStd	8.9	2.6	5.2	2.8	5.8	1.4	3.4	1.1	1.5	0.8	1.1	1.7	2.2	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.9	90.9	87.7	86.3	80.2	77.7	74.6	76.6	79.5	82.6	86.1	89.0	(19)
		MCWB	80.0	80.8	78.4	76.8	72.6	70.9	66.8	67.6	70.1	74.4	73.1	77.6	(20)
	2%	DB	88.3	88.7	86.1	83.6	78.3	76.1	73.2	75.1	78.0	81.1	84.4	87.3	(21)
		MCWB	78.5	78.3	77.1	74.7	70.1	69.3	65.2	66.1	68.6	73.2	73.6	77.6	(22)
	5%	DB	87.0	87.0	84.7	81.7	77.2	74.7	72.0	73.9	77.0	79.9	82.9	85.8	(23)
		MCWB	77.8	76.7	75.6	72.5	69.3	68.2	64.6	64.9	67.7	71.9	73.1	76.9	(24)
	10%	DB	85.6	85.4	83.7	80.3	76.0	73.4	71.0	72.6	75.9	78.6	81.5	84.2	(25)
		MCWB	77.0	76.2	74.7	71.8	68.7	67.8	64.1	63.9	66.9	70.3	72.1	75.6	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.8	81.9	80.4	78.6	75.0	73.7	69.7	68.9	71.5	77.5	77.1	81.2	(27)
		MCDB	86.7	86.4	84.8	82.7	77.7	74.6	72.3	74.4	76.6	81.6	81.7	85.3	(28)
	2%	WB	80.5	80.1	79.0	75.6	73.3	70.9	67.6	67.5	70.1	74.8	75.6	79.6	(29)
		MCDB	84.6	85.0	83.8	80.2	75.9	74.5	71.0	72.6	74.9	79.1	79.6	84.1	(30)
	5%	WB	79.3	79.0	78.0	74.6	71.8	69.7	66.3	66.6	69.3	73.7	74.6	78.6	(31)
		MCDB	83.9	84.1	82.7	79.3	75.2	73.5	70.5	71.6	74.1	77.3	78.9	82.7	(32)
	10%	WB	78.4	78.0	76.9	73.3	70.6	68.3	65.2	65.6	68.4	72.7	73.7	77.4	(33)
		MCDB	83.4	83.0	81.6	78.3	74.6	72.3	69.8	70.7	73.5	76.4	78.5	81.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	7.9	7.6	7.4	6.7	6.8	6.3	7.2	7.5	8.6	8.1	8.4	8.2	(35)
		MCDBR	9.3	9.1	8.6	8.1	7.8	7.0	7.9	8.7	9.5	9.4	10.1	9.4	(36)
	5% WB	MCWBR	4.0	3.9	3.9	4.3	5.9	4.5	5.7	5.4	5.0	4.5	4.9	3.8	(37)
		MCWBR	8.6	8.0	7.7	7.3	7.2	6.7	7.4	8.5	8.5	8.2	8.7	8.5	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.393	0.389	0.377	0.350	0.331	0.325	0.312	0.321	0.350	0.373	0.377	0.389	(40)
		taud	2.554	2.578	2.600	2.658	2.658	2.670	2.693	2.650	2.554	2.517	2.537	2.541	(41)
	Ebn at Noon	Ebn at Noon	302	299	294	289	282	278	286	294	298	300	305	303	(42)
		Edh at Noon	35	33	31	27	25	24	24	27	32	35	35	35	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	2176	1998	1789	1547	1299	1128	1277	1563	1911	2129	2272	2259	(44)
	RadStd	RadStd	126	218	151	116	70	92	93	99	124	129	178	190	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page