

HERON ISLAND, Australia

WMO: 943860

Lat: 23.442S

Lon: 151.913E

Elev: 6

StdP: 101.26

Time Zone: 10.00 (E10)

Period: 94-07

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.8	15.9	5.5	5.6	17.4	6.8	6.1	17.9	16.2	18.7	13.9	19.0	5.2	190	0.521

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.4	31.4	25.7	30.7	25.3	30.0	24.9	26.9	29.4	26.4	28.9	25.9	28.5	4.6	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	21.7	28.4	25.6	20.9	28.2	25.1	20.2	28.0	85.0	29.6	82.4	29.0	80.4	28.6	29.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.1	12.0	11.0	DB	12.9	32.3	0.7	1.1	12.4	33.1	12.0	33.7	11.6	34.3	11.1	35.1	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.8	27.4	27.3	26.6	24.8	22.3	20.5	19.5	20.2	22.0	23.5	25.0	26.4
	DBStd	3.09	1.30	1.45	1.11	1.43	1.61	1.93	1.43	1.47	1.25	1.18	1.26	1.46
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	16	0	0	0	0	2	5	7	3	0	0	0	0
	CDD10.0	5025	538	483	514	445	382	315	293	316	359	419	451	509
	CDD18.3	1999	280	250	256	195	124	70	42	61	109	161	201	251
	CDH23.3	12733	2787	2462	2235	1078	201	43	2	21	171	509	1139	2086
	CDH26.7	2454	731	623	389	91	1	0	0	0	1	21	147	451
Wind	WSAvg	6.1	6.1	6.3	6.5	6.5	6.4	6.6	6.3	6.1	5.4	5.6	5.5	5.9
Precipitation	PrecAvg	938	100	131	94	124	84	101	63	51	25	44	37	80
	PrecMax	1428	249	496	275	647	148	385	133	152	59	97	178	278
	PrecMin	567	29	10	27	6	23	23	16	6	1	8	8	23
	PrecStd	227	67	132	72	147	36	87	29	39	20	29	42	56
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.2	32.7	31.0	30.2	26.8	25.4	23.6	24.8	26.4	28.1	30.1	31.7
		MCWB	26.6	27.1	25.8	24.9	22.5	21.6	19.3	19.8	21.2	23.5	22.8	25.3
	2%	DB	31.3	31.5	30.0	28.7	25.7	24.5	22.9	23.9	25.5	27.3	29.1	30.7
		MCWB	25.8	25.7	25.0	23.7	21.2	20.7	18.4	18.9	20.3	22.9	23.1	25.3
	5%	DB	30.6	30.5	29.3	27.6	25.1	23.7	22.2	23.3	25.0	26.6	28.3	29.9
		MCWB	25.4	24.8	24.2	22.5	20.7	20.1	18.1	18.3	19.8	22.2	22.8	24.9
	10%	DB	29.8	29.6	28.7	26.8	24.5	23.0	21.7	22.6	24.4	25.9	27.5	29.0
		MCWB	25.0	24.6	23.7	22.1	20.4	19.9	17.8	17.7	19.4	21.3	22.3	24.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.7	27.7	26.9	25.9	23.9	23.1	20.9	20.5	22.0	25.3	25.0	27.3
		MCDB	30.4	30.2	29.3	28.2	25.4	23.7	22.4	23.5	24.8	27.6	27.6	29.6
	2%	WB	26.9	26.7	26.1	24.2	22.9	21.6	19.8	19.7	21.2	23.8	24.2	26.4
		MCDB	29.2	29.5	28.8	26.8	24.4	23.6	21.7	22.6	23.8	26.2	26.5	28.9
	5%	WB	26.3	26.1	25.6	23.7	22.1	21.0	19.1	19.2	20.7	23.2	23.7	25.9
		MCDB	28.8	28.9	28.2	26.3	24.0	23.0	21.4	22.0	23.4	25.2	26.0	28.2
	10%	WB	25.8	25.6	25.0	22.9	21.4	20.2	18.4	18.7	20.2	22.6	23.2	25.2
		MCDB	28.6	28.3	27.5	25.7	23.7	22.4	21.0	21.5	23.0	24.7	25.8	27.7
Mean Daily Temperature Range	5% DB	MDBR	4.4	4.2	4.1	3.7	3.8	3.5	4.0	4.2	4.8	4.5	4.6	4.5
		MCDBR	5.2	5.1	4.8	4.5	4.3	3.9	4.4	4.8	5.3	5.2	5.6	5.2
		MCWBR	2.2	2.1	2.2	2.4	3.3	2.5	3.2	3.0	2.8	2.5	2.7	2.1
	5% WB	MCDBR	4.8	4.4	4.3	4.1	4.0	3.7	4.1	4.7	4.7	4.5	4.9	4.7
		MCWBR	2.7	2.9	2.4	3.0	3.4	2.8	3.7	3.2	3.0	2.4	2.8	2.4
Clear-Sky Solar Irradiance	taub	0.393	0.389	0.377	0.350	0.331	0.325	0.312	0.321	0.350	0.373	0.377	0.389	
	taud	2.554	2.578	2.600	2.658	2.658	2.670	2.693	2.650	2.554	2.517	2.537	2.541	
	Ebn at Noon	952	942	927	911	890	876	903	928	938	946	960	956	
	Edh at Noon	110	105	98	86	79	75	75	85	101	110	111	111	
All-Sky Solar Radiation	RadAvg	6.86	6.30	5.64	4.88	4.09	3.56	4.03	4.93	6.03	6.71	7.16	7.12	
	RadStd	0.40	0.69	0.48	0.37	0.22	0.29	0.29	0.31	0.39	0.41	0.56	0.60	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page