

LADY ELLIOT ISLAND, Australia

WMO: 943880

Lat: 24.1117S

Lon: 152.7161E

Elev: 14

StdP: 14.69

Time Zone: 10.00 (E10)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	57.7	59.8	37.5	33.0	63.4	40.5	37.1	63.9	30.9	67.5	28.0	68.8	8.7	210	0.496

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.8	86.4	77.0	85.4	76.3	84.5	75.8	80.1	83.3	79.0	82.7	78.0	82.0	11.2	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.3	151.9	82.0	77.9	144.9	81.5	76.7	139.4	81.0	43.8	83.4	42.5	83.0	41.6	82.2	88.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 28.0	26.1	24.2	DB	52.1	88.3	2.2	1.1	50.5	89.0	49.2	89.7	47.9	90.3	46.3	91.1	(4)
(5)			WB	46.5	82.3	1.5	2.2	45.4	83.9	44.5	85.2	43.7	86.4	42.6	88.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	74.1	80.2	80.2	79.3	76.0	71.3	68.2	66.8	67.8	71.0	73.7	76.2	78.8	(6)
(7)		DBStd	5.47	2.04	2.07	2.06	2.19	3.23	3.44	3.36	3.28	2.61	2.26	2.12	2.17	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	49	0	0	0	0	2	12	21	13	1	0	0	0	(9)
(10)		CDD50	8794	938	847	907	780	662	546	522	553	630	733	785	891	(10)
(11)		CDD65	3368	473	427	442	330	199	108	78	101	181	268	335	426	(11)
(12)		CDH74	19782	4312	3930	3664	1571	301	35	17	38	221	716	1657	3320	(12)
(13)		CDH80	2794	839	716	504	66	1	0	0	0	0	11	130	527	(13)
(14)	Wind	WSAvg	13.5	14.3	15.6	15.4	15.7	13.3	13.3	12.1	12.0	11.6	12.4	12.5	13.3	(14)
(15)	Precipitation	PrecAvg	45.9	4.6	6.1	4.9	4.4	5.1	3.7	3.8	2.6	1.3	2.5	3.0	3.5	(15)
(16)		PrecMax	75.7	21.6	30.2	16.5	14.3	17.2	14.4	21.2	10.8	6.6	10.4	8.0	15.1	(16)
(17)		PrecMin	25.9	0.3	0.7	0.4	0.9	1.1	0.4	0.2	0.0	0.0	0.2	0.0	0.1	(17)
(18)		PrecStd	12.9	4.1	6.0	3.6	3.0	3.4	2.4	3.5	2.0	1.2	1.9	2.2	3.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	87.4	87.8	86.7	83.5	79.9	77.0	75.7	76.7	78.7	81.4	83.9	86.4	(19)
(20)			MCWB	77.9	78.3	77.3	74.2	70.8	71.0	67.3	67.8	70.0	72.6	74.3	76.6	(20)
(21)		2%	DB	86.3	86.5	85.4	81.8	78.2	75.2	74.1	75.1	77.4	80.0	82.6	85.1	(21)
(22)			MCWB	76.8	77.2	76.3	72.3	69.4	68.3	66.4	66.3	68.5	71.4	73.1	75.9	(22)
(23)		5%	DB	85.3	85.3	84.2	80.5	76.9	73.8	72.7	73.8	76.4	78.8	81.6	84.1	(23)
(24)			MCWB	76.2	76.4	75.6	71.7	68.9	67.3	65.7	65.3	67.5	70.3	72.2	75.2	(24)
(25)		10%	DB	84.2	83.9	82.9	79.4	75.6	72.8	71.5	72.4	75.3	77.7	80.4	83.0	(25)
(26)			MCWB	75.8	75.8	74.9	71.3	67.9	66.4	65.0	64.6	66.5	69.3	71.3	74.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.3	83.9	80.4	77.2	74.6	73.7	70.9	70.8	73.1	75.4	78.7	81.6	(27)
(28)			MCDWB	84.4	84.3	83.3	80.2	77.6	74.9	73.0	73.8	75.6	79.2	81.3	83.3	(28)
(29)		2%	WB	79.8	80.1	78.7	75.3	71.7	70.6	69.3	69.1	71.5	73.8	76.1	78.9	(29)
(30)			MCDWB	83.5	83.0	82.5	79.1	75.9	73.5	72.3	72.8	75.1	77.4	79.6	82.4	(30)
(31)		5%	WB	78.7	78.7	77.7	73.8	70.4	68.9	67.9	67.6	70.2	72.7	74.6	77.7	(31)
(32)			MCDWB	82.5	82.9	81.8	78.6	75.3	72.7	71.3	72.0	73.9	76.3	78.9	81.4	(32)
(33)		10%	WB	77.6	77.5	76.7	72.7	69.3	67.4	66.2	66.2	69.0	71.7	73.4	76.4	(33)
(34)			MCDWB	82.0	82.0	81.1	78.0	74.6	71.9	70.6	71.3	73.2	75.6	78.3	80.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.2	6.8	6.5	6.4	7.0	6.2	7.1	7.5	7.7	7.8	7.8	7.6	(35)
(36)			MCDBR	8.0	8.2	7.7	7.4	7.6	6.7	7.9	8.2	8.5	8.4	8.7	8.4	(36)
(37)			MCWBR	3.9	4.1	4.1	4.3	5.0	5.3	5.6	5.3	4.7	4.4	4.3	4.4	(37)
(38)		5% WB	MCDWB	7.2	7.2	6.9	6.5	6.7	6.1	6.4	7.2	7.2	7.6	7.9	7.6	(38)
(39)			MCWBR	5.2	5.1	4.8	5.0	5.6	6.2	6.0	6.3	5.8	5.6	6.1	5.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.389	0.383	0.374	0.345	0.329	0.323	0.312	0.322	0.350	0.371	0.373	0.388	(40)	
(41)		taud	2.561	2.589	2.603	2.674	2.660	2.675	2.690	2.645	2.550	2.521	2.549	2.539	(41)	
(42)		Ebn at Noon	303	300	294	290	282	278	286	293	297	300	306	304	(42)	
(43)		Edh at Noon	35	33	31	27	25	23	24	27	32	35	35	35	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2199	2004	1781	1535	1275	1102	1241	1538	1886	2091	2267	2246	(44)	
(45)		RadStd	134	205	151	109	64	89	94	100	123	135	180	204	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	-0.67	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page