

DENHAM, Australia

WMO: 944020

Lat: 25.9261S

Lon: 113.5319E

Elev: 32

StdP: 14.68

Time Zone: 8.00 (E08)

Period: 86-03

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	50.9	52.8	34.5	29.3	67.2	38.0	33.6	65.6	25.8	66.2	22.8	64.4	6.4	110	0.516

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	14.0	97.3	71.9	92.4	72.4	88.7	73.8	78.9	87.5	77.6	85.9	76.4	84.5	10.7	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.4	137.7	84.8	75.2	132.1	82.9	74.0	127.1	81.8	42.5	88.2	41.1	85.8	40.0	84.7	85.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
29.5	27.3	25.3	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			47.1	107.3	1.6	3.8	45.9	110.0	44.9	112.2	44.0	114.3	42.8	117.0
			43.3	81.7	1.9	1.5	41.9	82.8	40.7	83.7	39.6	84.5	38.2	85.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	71.0	77.7	80.8	78.8	74.8	69.0	64.1	62.5	62.9	66.0	68.3	72.5	75.4	(6)
	DBStd	7.24	3.97	5.05	4.35	3.82	3.80	3.08	3.01	3.43	3.26	3.46	4.05	3.94	(7)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD65	265	0	0	0	0	9	52	87	82	25	9	1	0	(9)
	CDD50	7671	860	864	893	743	588	424	388	401	481	567	675	787	(10)
	CDD65	2460	395	444	428	293	132	26	10	17	57	111	225	322	(11)
	CDH74	15808	2873	4234	3520	1570	351	32	16	49	108	306	961	1788	(12)
	CDH80	4856	824	1690	1132	351	38	0	1	4	22	52	272	470	(13)
(14) Wind	WSAvg	13.1	17.9	15.6	14.8	12.2	8.6	8.0	7.8	10.0	12.5	15.0	16.9	17.9	(14)
(15) Precipitation	PrecAvg	8.7	0.2	0.6	0.6	0.7	1.5	1.9	1.7	0.9	0.3	0.2	0.2	0.0	(15)
	PrecMax	16.8	2.5	5.7	8.2	3.6	5.4	6.3	5.9	2.9	0.9	1.8	2.0	1.2	(16)
	PrecMin	4.1	0.0	0.0	0.0	0.0	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.0	(17)
	PrecStd	3.4	0.5	1.1	1.4	0.9	1.3	1.3	1.5	0.7	0.2	0.4	0.5	0.2	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	102.7	105.3	100.2	92.7	84.4	77.6	76.3	79.1	83.7	85.4	95.8	97.2	(19)
		MCWB	70.4	72.1	70.7	68.9	66.7	61.6	61.1	59.1	60.7	63.7	67.0	70.1	(20)
	2%	DB	91.6	98.5	94.3	87.7	80.5	74.2	72.7	74.1	76.9	80.4	87.8	89.1	(21)
		MCWB	73.8	74.1	71.8	68.1	65.6	61.9	62.1	60.1	63.8	66.4	68.9	72.9	(22)
	5%	DB	87.2	92.6	89.0	83.8	77.8	71.9	70.4	71.3	74.0	77.0	82.1	84.4	(23)
		MCWB	75.7	75.2	73.6	71.1	67.0	62.8	61.8	61.6	64.3	66.7	70.0	73.0	(24)
	10%	DB	84.3	88.6	85.8	81.1	75.7	70.0	68.8	69.5	72.0	74.8	78.9	81.5	(25)
		MCWB	74.5	76.2	74.3	71.4	66.9	62.1	61.1	61.4	63.5	65.5	69.4	72.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.2	81.6	80.0	77.4	74.3	68.4	69.1	67.6	69.2	71.1	74.8	77.8	(27)
		MCDB	87.8	90.8	88.4	83.2	78.2	71.2	71.5	70.9	74.8	77.9	83.8	88.4	(28)
	2%	WB	77.3	79.6	78.0	75.6	72.0	66.9	66.1	65.4	67.3	69.3	72.9	75.4	(29)
		MCDB	86.0	88.4	85.8	80.6	76.1	70.1	69.7	69.4	72.9	76.2	81.5	84.6	(30)
	5%	WB	76.1	78.2	76.7	74.3	70.4	65.5	64.1	64.1	65.9	68.1	71.3	73.9	(31)
		MCDB	84.5	86.9	83.9	79.3	74.8	69.1	68.1	68.6	71.4	75.0	79.5	82.0	(32)
	10%	WB	74.9	76.9	75.7	73.1	69.0	64.0	62.8	62.7	64.6	66.8	69.9	72.6	(33)
		MCDB	82.8	85.9	82.6	78.2	73.7	68.1	67.0	67.6	70.3	73.1	77.3	80.2	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	12.1	14.0	12.8	12.9	13.6	12.6	13.3	13.8	13.2	13.4	12.7	12.1	(35)
		MCDBR	17.3	22.3	20.0	18.0	17.1	15.4	15.9	17.2	16.4	17.3	19.9	18.3	(36)
	5% WB	MCWBR	9.0	9.5	9.7	9.6	9.4	8.0	8.6	9.3	9.1	9.5	10.1	9.3	(37)
		MCWBR	14.3	15.3	13.8	12.9	13.1	11.4	11.9	12.9	13.1	14.4	15.5	14.7	(38)
(40) Clear-Sky Solar Irradiance	taub		0.365	0.370	0.353	0.332	0.312	0.306	0.298	0.303	0.320	0.329	0.337	0.345	(40)
		taud	2.571	2.583	2.612	2.653	2.675	2.670	2.687	2.651	2.575	2.560	2.561	2.581	(41)
	Ebn at Noon		310	304	300	293	286	281	288	298	306	313	317	317	(42)
		Edh at Noon	34	33	30	27	24	23	23	26	31	33	34	34	(43)
(44) All-Sky Solar Radiation	RadAvg		2587	2414	2063	1650	1326	1131	1201	1528	1956	2324	2575	2693	(44)
	RadStd		108	75	128	86	77	56	71	57	56	65	60	92	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	-3.15	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page